

Schedule 6 – Notification

These pages outline the information that the operator must provide.

Units of measurement used in information supplied under Part A and B requirements shall be appropriate to the circumstances of the emission. Where appropriate, a comparison should be made of actual emissions and authorised emission limits.

If any information is considered commercially confidential, it should be separated from non-commercial information, supplied on a separate sheet, and accompanied by an application for commercial confidentiality under the provisions of the PPC Regulations

Part A

Permit Number	LP3135SB
Name of Operator	Novera Energy Generation Ltd
Location of Installation	Docks Way Landfill gas generation site Docksway Landfill Site Maes Glas Newport Gwent NP20 2NS
Time and date of the detection	

(a) Notification requirements for any malfunction, breakdown or failure of equipment or techniques, accident, or fugitive emission which has caused, is causing or may cause significant pollution

To be notified within 24 hours of detection

Time and date of the event	16/8/25 06:20 – 18/08/25 08:36
Reference or description of the location of the event	Docksway GUP
Description of where any release into the environment took place	Docksway Landfill Site
Substance(s) potentially released	Landfill gas
Best estimate of the quantity or rate of release of substances	N/A within boundary of permit LP3135SB
Measures taken, or intended to be taken, to stop any emission	Gas plant restarted
Description of the failure or accident	GUP outage

(b) Notification requirements for the breach of a limit

To be notified within 24 hours of detection unless otherwise specified below

Emission point reference / source	
Parameter(s)	
Limit	
Measured value and uncertainty	
Date and time of monitoring	
Measures taken or intended to be taken, to stop the emission	

Time periods for notification following detection of a breach of a limit	
Parameter	Notification period

(c) Notification requirements for notification of any significant adverse environmental effect	
To be notified within 24 hours of detection	
Description of where the effect on the environment was detected	
Substance(s) detected	
Concentration of substance(s) detected	
Date of monitoring/sampling	

Part B

Any more accurate information on the matters for notification under Part A	Compressor trip
Measures taken, or intended to be taken, to prevent a recurrence of the incident	
Measures taken, or intended to be taken, to rectify, limit or prevent any pollution of the environment or harm which has been or may be caused by the emission	None reported
The dates of any unauthorised emissions from the installation in the preceding 24 months	N/A

Name*	██████████
Post	Compliance Manager
Signature	██
Date	18/08/2025 (Part A)

*authorised to sign on behalf of Novera Energy Generation No 2 Ltd