

WATER RESOURCES ACT 1991

Under Section 88 and Schedule 10 of the Water Resources Act 1991 and all other enabling powers the National Rivers Authority hereby gives this Notice

R E V I E W O F C O N S E N T

Page 1 of 5

To : Dŵr Cymru Cyfyngedig

Of : Plas y Ffynnon, Cambrian Way, Brecon, Powys LD3 7HP

In respect of previous Consent No. CG0029101 issued on 21st January, 1993

For : A discharge of sewage effluent

To : Afon Dysynni

From : Abergynolwyn Sewage Treatment Works

This Consent shall not be taken as providing a statutory defence against a charge of pollution in respect of any poisonous, noxious or polluting constituents not specified herein.

THE FOLLOWING REPLACE ALL PREVIOUS CONDITIONS

1. The discharge shall consist only of biologically treated sewage effluent.
2. The discharge shall be made in the manner and at the place specified as follows:-

Discharging via : A 150mm diameter pipe

Discharging to : Afon Dysynni

At OS Grid Ref. : SH 6739 0710

As shown marked : "Discharge Point" on the attached plan No. CG0029101.

3. Adequate facilities, approved in writing by the Authority, shall be provided to enable representative samples of the discharge to be safely and conveniently obtained at any time at a sampling chamber at SH 6739 0711 as shown marked "Sampling Point" on the attached plan No. CG0029101.

continued.....

WATER RESOURCES ACT 1991  
 Continuation Sheet

page 2 of 5


4. The maximum volume of effluent discharged under dry weather flow conditions shall not exceed 78.4 cubic metres per day.
5. The maximum rate of flow of effluent discharged shall not exceed 2.2 litres per second.
6. The maximum volume of effluent discharged shall not exceed 190 cubic metres per day.
7. Calibrated apparatus, approved in writing by the Authority, shall be provided and maintained in full working order, to permit the instantaneous rate of flow of effluent discharged to be measured accurately at any time.
8. The quality of the effluent discharged at all flow rates up to the maximum specified in condition 5 shall not be inferior to the following numerical limits, except as provided for in Annex 1:
  - (a) The 5 day Biochemical Oxygen Demand (BOD ATU), determined at 20 degrees Celsius after the suppression of nitrification using allyl thiourea, shall not exceed 50 milligrammes of Oxygen per litre of sample.
  - (b) The Suspended Solids concentration (dried at 105 degrees Celsius) shall not exceed 60 milligrammes per litre.
  - (c) The Ammoniacal Nitrogen concentration, expressed as Nitrogen, shall not exceed 30 milligrammes per litre.

continued.....

WATER RESOURCES ACT 1991  
 Continuation Sheet

page 3 of 5

9. The Authority shall be informed in writing as soon as is reasonably practicable of any information received by Dŵr Cymru to the effect that there has been or is likely to be discharged into the sewerage system connected to the works, a significant increase in the quantity of any of the substances listed in the attached Annex 2.
10. For the purposes of this consent dry weather flow shall mean the average daily flow to the treatment works during seven consecutive days without rain (excluding a period which includes public holidays) following seven days during which the rainfall did not exceed 0.25 mm on one day.
11. The terms and conditions of this consent shall come into force on the 30th June, 1995 or on the date of the new works commissioning, whichever is the sooner. The discharger shall give the Authority at least one month's written notice of the commissioning date.
12. The effluent shall at no time contain any matter other than matters specifically authorised or limited by numerical conditions in this consent, to such an extent as to cause the receiving waters to be poisonous or injurious to fish or the spawning ground, spawn or food of fish.

This Notice is given on: 7th June, 1994  
 by: 

on behalf of the Authority  
 Area Environmental Quality Manager

During the period ending with the: 6th June, 1996 the terms of this  
 Notice will not be altered without the written agreement of the person  
 making the discharge.

ANNEX 1

Where the number of samples taken in any period of twelve consecutive months falls within any of the ranges within Column 1 of the table below, the number of samples which are inferior to the numerical quality limit in force at the time for any determinand shall not exceed the appropriate permitted number as listed in Column 2. A sample shall only be considered as having failed in relation to the particular determinand(s) for which the specified quality limit is exceeded. A sample shall be considered to be satisfactory in relation to other determinands the concentration of which are equal to or lower than the specified limit. This annex shall not apply to the upper tier limits.

TABLE

<u>Column 1</u>	<u>Column 2</u>
Number of samples taken in any period of 12 months	Maximum number of samples permitted to exceed limit for given determinand
4-7	1
8-16	2
17-28	3
29-40	4
41-53	5
54-67	6
68-81	7
82-95	8
96-110	9
111-125	10
126-140	11
141-155	12
156-171	13
172-187	14
188-203	15
204-219	16
220-235	17
236-251	18
252-268	19
269-284	20
285-300	21
301-317	22
318-334	23
335-350	24
351-365	25

continued.....

Dr JOHN STONER - Rheolwr Cyffwrddol Rhannbarthol / Regional General Manager

ANNEX 2

SUBSTANCE

page 5 of 5

Mercury	Vanadium
Cadmium	PCSDs
g-Hexachlorocyclohexane	Cyfluthrin
DDT	Sulcofuron
Pentachlorophenol	Flucofuron
Hexachlorobenzene	Permethrin
Hexachlorobutadiene	Cyanide
Aldrin	Azinphos-ethyl
Dieldrin	Fenthion
Endrin	Parathion
Polychlorinated Biphenyls	Parathion-methyl
Dichlorvos	Trichloroethane
1,2 Dichloroethane	Dioxins
Trichlorobenzene	Isodrin
Atrazine	
Simazine	
Tributyltin compounds	
Triphenyltin compounds	
Trifluralin	
Fenitrothion	
Azinphos-methyl	
Malathion	
Endosulphan	
Carbon tetrachloride	
Chloroform	
Trichloroethylene	
Tetrachloroethylene	
Lead	
Chromium	
Zinc	
Copper	
Nickel	
Arsenic	
Iron	
pH	
Boron	

NGEL Y PENNANT

# Plan CG0029101

