

Permit Number: EPR/TP3639BH

Operator: 7 Steel Manufacturing (UK) Limited

Facility: Tremorfa Melt Shop

Form Number: Air 1 / 05/05/2020

Reporting of emissions to air for the period from 01/07/2025 to 31/07/2025

Emission Point	Substance / Parameter	Emission Limit Value	Reference Period	Result ^[1]	Test Method ^[2]	Sample Date and Times ^[3]	Uncertainty ^[4]
A1	Particulate Matter	5 mg/m ³	Daily (Maximum) average	4.20	BS ISO 10155	July	n/a*
A4	Particulate Matter	Ringleman Shade 1	Daily (Maximum) average	0	BS 2742	Daily	n/a

*MCERTS CEMS model does not quote uncertainty.

- [1] The result given is the maximum value (or the minimum value in the case of a limit that is expressed as a minimum) obtained during the reporting period, expressed in the same terms as the emission limit value. Where the emission limit value is expressed as a range, the result is given as the 'minimum – maximum' measured values.
- [2] Where an internationally recognised standard test method is used the reference number is given. Where another method that has been formally agreed with Natural Resources Wales is used, then the appropriate identifier is given. In other cases the principal technique is stated, for example gas chromatography.
- [3] For non-continuous measurements the date and time of the sample that produced the result is given. For continuous measurements the percentage of the process operating time covered by the result is given.
- [4] The uncertainty associated with the quoted result at the 95% confidence interval, unless otherwise stated.

Signed
(Authorised to sign as r



Date.....24/10/2025.....

Permit Number: EPR/TP3639BH

Operator: 7 Steel Manufacturing (UK) Limited

Facility: Tremorfa Melt Shop

Form Number: Air 1 / 05/05/2020


Reporting of emissions to air for the period from 01/08/2025 to 31/08/2025

Emission Point	Substance / Parameter	Emission Limit Value	Reference Period	Result ^[1]	Test Method ^[2]	Sample Date and Times ^[3]	Uncertainty ^[4]
A1	Particulate Matter	5 mg/m ³	Daily (Maximum) average	2.04	BS ISO 10155	August	n/a*
A4	Particulate Matter	Ringleman Shade 1	Daily (Maximum) average	0	BS 2742	Daily	n/a

*MCERTS CEMS model does not quote uncertainty.

- [1] The result given is the maximum value (or the minimum value in the case of a limit that is expressed as a minimum) obtained during the reporting period, expressed in the same terms as the emission limit value. Where the emission limit value is expressed as a range, the result is given as the 'minimum – maximum' measured values.
- [2] Where an internationally recognised standard test method is used the reference number is given. Where another method that has been formally agreed with Natural Resources Wales is used, then the appropriate identifier is given. In other cases the principal technique is stated, for example gas chromatography.
- [3] For non-continuous measurements the date and time of the sample that produced the result is given. For continuous measurements the percentage of the process operating time covered by the result is given.
- [4] The uncertainty associated with the quoted result at the 95% confidence interval, unless otherwise stated.

Signed
(Authorised to sign on behalf of the operator)



Date.....24/10/2025.....

Permit Number: EPR/TP3639BH

Operator: 7 Steel Manufacturing (UK) Limited

Facility: Tremorfa Melt Shop

Form Number: Air 1 / 05/05/2020

Reporting of emissions to air for the period from 01/09/2025 to 30/09/2025

Emission Point	Substance / Parameter	Emission Limit Value	Reference Period		Result ^[1]	Test Method ^[2]	Sample Date and Times ^[3]	Uncertainty ^[4]
A1	Particulate Matter	5 mg/m ³	Daily (Maximum)	average	2.48	BS ISO 10155	September	n/a*
A4	Particulate Matter	Ringleman Shade 1	Daily (Maximum)	average	0	BS 2742	Daily	n/a

*MCERTS CEMS model does not quote uncertainty.

- [1] The result given is the maximum value (or the minimum value in the case of a limit that is expressed as a minimum) obtained during the reporting period, expressed in the same terms as the emission limit value. Where the emission limit value is expressed as a range, the result is given as the 'minimum – maximum' measured values.
- [2] Where an internationally recognised standard test method is used the reference number is given. Where another method that has been formally agreed with Natural Resources Wales is used, then the appropriate identifier is given. In other cases the principal technique is stated, for example gas chromatography.
- [3] For non-continuous measurements the date and time of the sample that produced the result is given. For continuous measurements the percentage of the process operating time covered by the result is given.
- [4] The uncertainty associated with the quoted result at the 95% confidence interval, unless otherwise stated.

Signed
(Authorised to sign as represent



Date.....24/10/2025.....