

Schedule 5 – Notification

These pages outline the information that the operator must provide.

Units of measurement used in information supplied under Part A and B requirements shall be appropriate to the circumstances of the emission. Where appropriate, a comparison should be made of actual emissions and authorised emission limits.

If any information is considered commercially confidential, it should be separated from non-confidential information, supplied on a separate sheet and accompanied by an application for commercial confidentiality under the provisions of the EP Regulations.

Part A

Permit Number	KP3135KV
Name of operator	The Royal Mint Limited
Location of Facility	Llantrisant Pontyclun
Time and date of detection	11:35 on 21/08/2025 – emission report submitted.

(a) Notification requirements for any malfunction, breakdown or failure of equipment or techniques, accident, or emission of a substance not controlled by an emission limit which has caused, is causing or may cause significant pollution

To be notified within 24 hours of detection

Date and time of the event	
Reference or description of the location of the event	
Description of where any release into the environment took place	
Substances(s) potentially released	
Best estimate of the quantity or rate of release of substances	
Measures taken, or intended to be taken, to stop any emission	
Description of the failure or accident.	

(b) Notification requirements for the breach of a limit

To be notified within 24 hours of detection unless otherwise specified below

Emission point reference/ source	A32 – Emission Point to Air
Parameter(s)	Particulate Matter
Limit	5mg/m ³
Measures value and uncertainty	Result 11.2 mg/m ³ measurement of uncertainty +/- 1.7 mg/m ³ .
Date and time of monitoring	11:33 – 12:05 on 30/07/2025.
Measures taken, or intended to be taken, to stop the emission	A number of modifications have been implemented since the last emission exceedance reported on 27/02/2025. However, despite these efforts, further configuration of the system is required. The current decision is that an introduction of additional filtration is to be added to the system. This will be selected in consultation with an approved specialist.


Time periods for notification following detection of a breach of a limit

Parameter	Particulate Matter
Period of operation	During the period of 30/07/2025 to 21/08/2025 the plant ran for approximately

	180 hours. With a total of 64.8 tonnes of material.
(c) Notification requirements for the detection of any significant adverse environmental effect	
To be notified within 24 hours of detection	
Description of where the effect on the environment was detected	
Substances(s) detected	
Concentrations of substances detected	
Date of monitoring/sampling	

Part B – to be submitted as soon as practicable

Any more accurate information on the matters for notification under Part A.	
Measures taken, or intended to be taken, to prevent a recurrence of the incident	
Measures taken, or intended to be taken, to rectify, limit or prevent any pollution of the environment which has been or may be caused by the emission	
The Dates of any unauthorised emissions from the facility in the preceding 24 months	

Name*	
Post	Safety, Health & Environmental Specialist
Signature	
Date	22/08/2025

*authorised to sign on behalf of The Royal Mint Limited