









**Schedule 3 - Form Number: W1**

**Operator: Kepak**

**Permit Number: AP3433ES**

Installation: Dowlais Slaughterhouse

Release to Water

Release Point: W1, W2

Release for Quarter ending: [December 2024](#)

Reporting Form W1				
Parameter	Limit Value	Release Point W1	Release Point W2	Month and Date
Mineral oil and hydrocarbons mg/l	5	0.267	0.267	03/10/2024
Suspended Solids mg/l	50	6	4	03/10/2024
Mineral oil and hydrocarbons mg/l	5	0.407	0.327	14/11/2024
Suspended Solids mg/l	50	12	11	14/11/2024
Mineral oil and hydrocarbons mg/l	5	0.267	0.813	05/12/2024
Suspended Solids mg/l	50	6	16	05/12/2024

Signed on behalf of the Operator:



Date: 21/01/2025

**Schedule 3 - Form Number: S1**

**Operator: Kepak**

**Permit Number: AP3433ES**

Installation: Dowlais Slaughterhouse

Release to Sewer

Release Point: S1

Release for Quarter ending: [December 2024](#)

Reporting Form S1					
Parameter	Limit Value(s)	Min	Average	95 <sup>th</sup> Percentile Value	Maximum
pH	6-11	6.10	6.72	7.70	7.70
Total suspended solids mg/l	600	18	41.54	70	76.00
Total chemical oxygen demand (COD) mg/l	3600	48	237.38	399.60	414.00
Free or emulsified grease or oil mg/l	100	0.61	9.46	29.04	38.10
Anionic synthetic detergent as manoxol OT mg/l	100	0.025	0.025	0.025	0.025
Dissolved oxygen mg/l	-	0.5	0.68	1.44	2.40
Ammoniacal nitrogen as N mg/l	30	0.50	7.12	15.78	20.10
Daily flow m <sup>3</sup> /day	800	54.99	494.58	719.80	790
Maximum flow m <sup>3</sup> /h	34	2.29	20.61	29.99	32.92

Signed on behalf of the Operator:

Date: 21/01/2025

