

Schedule 3 - Form Number: W1

Operator: Kepak

Permit Number: AP3433ES

Installation: Dowlais Slaughterhouse

Release to Water

Release Point: W1, W2

Release for Quarter ending: [September 2025](#)

Reporting Form W1				
Parameter	Limit Value	Release Point W1	Release Point W2	Month and Date
Mineral oil and hydrocarbons mg/l	5	0.407	0.28	03/07/2025
Suspended Solids mg/l	50	6	5	03/07/2025
Mineral oil and hydrocarbons mg/l	5	0.333	0.313	07/08/2025
Suspended Solids mg/l	50	6	4	07/08/2025
Mineral oil and hydrocarbons mg/l	5	0.54	0.631	04/09/2025
Suspended Solids mg/l	50	9	14	04/09/2025

Signed on behalf of the Operator:

Date: 20/10/2025



Schedule 3 - Form Number: S1

Operator: Kepak

Permit Number: AP3433ES

Installation: Dowlais Slaughterhouse

Release to Sewer

Release Point: S1

Release for Quarter ending: [September 2025](#)

Reporting Form S1					
Parameter	Limit Value(s)	Min	Average	95th Percentile Value	Maximum
pH	6-11	6.10	6.77	8.06	8.30
Total suspended solids mg/l	600	12	37.85	66.00	72.00
Total chemical oxygen demand (COD) mg/l	3600	69.00	226.46	366.60	375.00
Free or emulsified grease or oil mg/l	100	3.01	8.32	15.12	17.70
Anionic synthetic detergent as manoxol OT mg/l	100	0.025	0.025	0.025	0.025
Dissolved oxygen mg/l	-	0.5	0.54	0.64	0.70
Ammoniacal nitrogen as N mg/l	30	0.41	12.68	26.10	26.10
Daily flow m ³ /day	800	8.76	484.86	655.77	709.45
Maximum flow m ³ /h	34	0.37	20.20	27.32	29.56

Signed on behalf of the Operator:

Date: 20/10/2025

