

CONSENT NO.	CG0071001
-------------	-----------



ASiantaeth YR
AMGYLCHEDD CYMRU
ENVIRONMENT
AGENCY WALES

WATER RESOURCES ACT 1991

SECTION 88 - SCHEDULE 10

(AS AMENDED BY THE ENVIRONMENT ACT 1995)

VARIATION OF CONSENT TO DISCHARGE

TO: Mr John Arthur Jones
Parc Cefni
Bodffordd
Ynys Mon LL77 7PJ

In pursuance of an application by the consent holder for variation of consent, the **ENVIRONMENT AGENCY** ("The Agency") in pursuance of its powers under the Water Resources Act 1991 **HEREBY VARIES ITS CONSENT** to the making of a discharge **OF SEWAGE EFFLUENT** as follows:

Biologically Treated Sewage and Trade Effluent

With respect to Consent No. CG0071001 issued 24th May 1967

FROM: Parc Cefni

AT: Bodffordd, Ynys Mon LL77 7PJ

TO: Cefni Reservoir Bypass Channel

SUBJECT TO the conditions set out in the following schedule(s):

Biologically Treated Sewage and Trade Effluent

Schedule No. CG0071001 01

Subject to the provisions of Paragraphs 7 and 8 of Schedule 10 of the Water Resources Act 1991, no notice shall be served by the Agency, which alters the effect of variations made to this consent, without the agreement in writing of the consent holder, during a period of 4 years from the date this variation is issued.

This variation of consent is issued on the 20th day of May 2004
This variation of consent takes effect on the 9th day of September 2004

Signed

Siân Owens

Environment Management Team Leader

Asiantaeth yr Amgylchedd Cymru
Parc Menai, Ffordd Penlan, Bangor, Gwynedd, LL57 4DE. Ffon: 01248 670770 Ffacs: 01248 670561

Environment Agency Wales
Parc Menai, Penlan Road, Bangor, Gwynedd, LL57 4DE. Tel: 01248 670770 Fax: 01248 670561



CONSENT NO.	CG0071001
SCHEDULE NO.	CG0071001 01
DATE ISSUED	20th May 2004



**ASiantaeth Yr
Amgylchedd Cymru
Environment
Agency Wales**

CONDITIONS OF CONSENT TO DISCHARGE

Biologically Treated Sewage and Trade Effluent ("the Discharge")

FROM: Parc Cefni, Bodffordd, Ynys Mon LL77 7PJ

1. (a) The Discharge shall not contain any poisonous, noxious or polluting matter or solid waste matter.
- (b) Provided that the Discharge hereby consented is made in accordance with the following conditions of this consent, such discharge shall not be taken to be in breach of condition (a) above by reason of containing substances or having properties identified in and controlled by these conditions.

NATURE

2. The Discharge shall consist solely of biologically treated sewage and trade effluent , arising from Parc Cefni, Bodffordd, Ynys Mon LL77 7PJ.

LOCATION

3. The Discharge shall be made in the manner and at the place specified as:
 - (a) discharging via a 150 millimetre diameter pipe;
 - (b) discharging to the Cefni Reservoir Bypass Channel;
 - (c) at National Grid Reference SH 43361 76875;
 - (d) shown marked 'Discharge Point' on Plan CG0071001 attached as Annex 1.

CONSENT NO.	CG0071001
SCHEDULE NO.	CG0071001 01



**ASiantaeth Yr
Amgylchedd Cymru
Environment
Agency Wales**

SAMPLING POINTS

4. An appropriately labelled sample point shall be provided and maintained at National Grid Reference SH 43340 76860, as shown marked 'Sampling Point' on Plan CG0071001, so that a representative sample of the Discharge may be obtained. The consent holder shall ensure that all constituents of the Discharge pass through the said sampling point at all times and in any legal proceedings it shall, for the purposes of Section 10 of the Rivers (Prevention of Pollution) Act 1961, be presumed, until the contrary is shown that any sample of the Discharge taken at the said sampling point is a sample of what was discharging into controlled waters.

VOLUME

5. The volume of the Discharge shall not exceed 19.3 cubic metres per day.

FLOW MEASUREMENT

6. At the request of the Agency, the Consent Holder shall install, operate and maintain a means of flow measuring to a specification and at a location required by the Agency, to enable the daily volume and instantaneous flow of the discharge to be recorded. The Consent Holder shall calibrate, operate and maintain the flow monitoring and recording system to a standard agreed or specified by the Agency. The flow and maintenance records shall be provided to the Agency as and when requested.

COMPOSITION

7. The Discharge shall not contain more than;
 - (i) 20 milligrammes per litre of biochemical oxygen demand (measured after 5 days at 20 °C with nitrification suppressed by the addition of allyl-thiourea)
 - (ii) 30 milligrammes per litre of suspended solids (measured after drying at 105 °C);

CONSENT NO.	CG0071001
SCHEDULE NO.	CG0071001 01



**ASiantaeth Yr
Amgylchedd Cymru
ENVIRONMENT
AGENCY WALES**

MAINTENANCE

8. The works shall be operated and maintained in accordance with good operational practice such that:
- (a) it remains fully operational except at times of unavoidable mechanical or electrical breakdown which shall be attended to, and the Agency informed of the failure, as soon as practicable after the failure;
 - (b) following a failure all equipment shall be returned to normal operation as soon as practicable;
 - (c) tanks shall be desludged at sufficient frequency and in such a manner to prevent excessive carryover of suspended solids.

START DATE

9. There shall be no discharge under the terms of this consent until the 9th September 2004 or the start of commissioning of the works whichever is the sooner. The Consent Holder shall give the Agency at least 28 days written notice before making the discharge.


CONSENT NO.	CG0071001
SCHEDULE NO.	CG0071001 01



ASiantaeth YR
AMGYLCHEDD CYMRU
ENVIRONMENT
AGENCY WALES

ANNEX 1

Plan CG0071001



Reproduced from the Ordnance Survey mapping with the permission of the Controller of Her Majesty's Stationary Office © Crown copyright. Unauthorised reproduction infringes Crown copyright and may lead to prosecution or civil proceedings. Licence No: GD03177G

