

Wildcat Hydromotive
Helygog, Brithdir
Dolgellau
Gwynedd LL40 2TT

Tel: 01341 450 200

Email: wildcathydro@btconnect.com

30th August 2019

FAO Jennifer Pocock
Permit Receipt Team
Ty Cambria
29 Heol Casnewydd
Cardiff CF24 0TP

Re: Afon Mynach, Licence no: 23/64/4/0077

Dear Jennifer

I refer to our recent telephone conversation regarding licence renewal on the above site.

While planning permission was agreed, we were then advised that we needed a full sound test as there is a domestic property on the other side of the noisy river. Also, a factory opposite with plant hire and sales! We contacted Ted Stowell of Allied Hydro as we had previously worked together on other sites and we did have a professional sound test meter for this purpose.

Having carried out these tests, the information sent sent via Mrs J Jones (Snowdonia National Oaks) to a Mr E Thomas (Gwynedd Council). This was immediately rejected on the grounds of 'Not enough detailed information'. In response to this outcome, we then contacted a specialist sound test company to carry 24 hour tests from all points.

These tests were carried in great detail and incurred considerable expense. The findings were sent to Mr Thomas and we were, again, told 'Not enough detail provided'.

Further tests were carried out for a period of 18 months and incredibly, the same reply was received on each occasion. At this point, we began to have reservations whether Mr Thomas possessed the necessary qualifications to make these decisions. Litigation was considered.

The upshot of this, was that we received a reply stating that they were now prepared to accept the original test figures from Ted Stowell and myself!

We are now 2 years behind schedule, added to that, I had a serious coronary episode which resulted in my being admitted to hospital as an emergency case.





I hope you will take this information into consideration on my licence application.
I enclose form WRD and all relevent documentation.

Thanking you for your time in this unfortunate matter.

Yours sincerely,

Ian Richardson






REV	DESCRIPTION	DRAWN	CHECKED	APPROV'D	DATE
PROJECT	MYNACH	PROJECT No.	257		
ADDRESS					
DRAWING TITLE					
EXISTING RESERVOIR DAM GENERAL ARRGT					
& PROPOSED WEIR BOX					
DRAWING NUMBER	257-602	SCALE	1:100	DATE	29/01/19
				REVISION	C

Turbine Full Load Output	21.6	21.6
Load Factor	%	92.0
Turbine Full Load Consumption	l/s	70

Turbine Full Load Output
 Load Factor
 Turbine Full Load Consumption



Annual Operator Summary

	Average Water Consumed By Turbine l/s	Average Turbine Power Output kW	Total Monthly Production kWh
January	68.8	21.2	15605
February	68.8	21.3	14281
March	68.2	21.2	15763
April	64.4	20.5	14737
May	60.3	19.5	14497
June	55.0	18.0	12983
July	54.1	17.7	13141
August	55.4	17.7	13192
September	58.4	18.7	13461
October	65.7	20.5	15249
November	68.5	21.3	15316
December	68.9	21.3	15831
Annual	63.0	19.9	174255

Turbine Flow (l/s)

Exceedance Probability (Q#)	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
5	70	70	70	70	70	70	70	70	70	70	70	70
10	70	70	70	70	70	70	70	70	70	70	70	70
20	70	70	70	70	70	70	70	70	70	70	70	70
30	70	70	70	70	70	70	70	70	70	70	70	70
40	70	70	70	70	70	70	70	70	70	70	70	70
50	70	70	70	70	70	70	70	70	70	70	70	70
60	70	70	70	70	70	67	64	70	70	70	70	70
70	70	70	70	70	70	51	50	59	70	70	70	70
80	70	70	70	70	55	39	38	41	48	70	70	70
90	70	70	70	53	37	27	25	24	30	65	70	70
95	70	70	70	40	29	22	19	14	21	43	70	70
99	57	57	48	28	18	15	13	9	12	25	50	60
Average	68.8	68.8	68.2	64.4	60.3	55.0	54.1	55.4	58.4	65.7	68.5	68.9

Turbine Output (kW)

Exceedance Probability (Q#)	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
5	21.6	21.6	21.6	21.6	21.6	21.6	21.6	21.6	21.6	21.6	21.6	21.6
10	21.6	21.6	21.6	21.6	21.6	21.6	21.6	21.6	21.6	21.6	21.6	21.6
20	21.6	21.6	21.6	21.6	21.6	21.6	21.6	21.6	21.6	21.6	21.6	21.6
30	21.6	21.6	21.6	21.6	21.6	21.6	21.6	21.6	21.6	21.6	21.6	21.6
40	21.6	21.6	21.6	21.6	21.6	21.6	21.6	21.6	21.6	21.6	21.6	21.6
50	21.6	21.6	21.6	21.6	21.6	21.6	21.6	21.6	21.6	21.6	21.6	21.6
60	21.6	21.6	21.6	21.6	21.6	20.5	19.9	21.6	21.6	21.6	21.6	21.6
70	21.6	21.6	21.6	21.6	21.6	18.7	16.2	18.2	21.6	21.6	21.6	21.6
80	21.6	21.6	21.6	21.5	20.0	15.4	15.1	16.2	17.7	21.6	21.6	21.6
90	21.6	21.6	21.6	19.3	14.8	10.9	9.8	9.5	12.0	20.1	21.6	21.6
95	21.6	21.6	20.5	15.9	11.5	8.6	7.5	4.9	8.4	15.9	21.6	21.6
99	17.5	17.7	17.5	11.1	7.2	5.9	4.4	3.2	4.2	9.8	18.2	18.4
Average	21.2	21.3	21.2	20.5	19.5	18.0	17.7	17.7	18.7	20.5	21.3	21.3

Specific Output (kw/l/s)	l/s	kw/l/s
0 sflow<	14.1	0.35
14.1 sflow<	28.1	0.40
28.1 sflow<	42.1	0.40
42.1 sflow<	56.1	0.37
56.1 sflow<	70.1	0.31
70.1 sflow<	84.1	0.23



**Cyfoeth
Naturiol
Cymru
Natural
Resources
Wales**

FULL LICENCE TO ABSTRACT WATER

The Natural Resources Body for Wales (hereafter referred to as "the Body") grants this licence to:-

Ian Richardson

("the Licence Holder")

Helygog
Brithdir
Dolgellau
Gwynedd
LL40 2SA

This licence authorises the Licence Holder to abstract water from the source of supply described in the Schedule of Conditions to this licence and subject to the provisions of that Schedule. The licence commences from the effective date shown below and shall remain in force until the date of expiry shown below, subject to Condition 9.12.

Signed

ADavies

Date of issue28 June 2013

Anwen Davies
Permitting Team Leader
Wales Permitting Centre (Cardiff)
Natural Resources Wales
Cambria House
29 Newport Road
Cardiff
CF24 0TP

Date effective28 June 2013

Date of expiry 31 March 2018

Date of original issue29 June 2007

The licence should be kept safe and its existence disclosed on any sale of the property to which it relates. Please read the 'important notes' on the cover to this licence.

Note: References to "the map" are to the map which forms part of this licence.
References to "the Body" are to the Natural Resources Body for Wales or any successor body.

Swyddfa'r Parc Cenedlaethol / National Park Office
Penrhyndeudraeth
Gwynedd LL48 6LF

(01766) 770274 / Rhif ffacs/Fax No (01766) 771211
cynllunio@eryri.llyw.cymru



Gofynner am / Ask for: Mrs Jane Jones

Dyddiad / Date: 20/07/17

Mr. Ian Richardson
Helygog
Brithdir
Dolgellau
Gwynedd
LL40 2SA

Rhif Cais: NP5/54/40A

Disgrifiad y Datblygiad:
**Adeiladu ty tyrbîn newydd mewn cysylltiad
a cynllun trydan dwr presennol.**

Safle / Lleoliad:
The Old Creamery, Rhydymain.

Annwyl Syr,

Ysgrifennaf atoch ynglŷn â'r cais cynllunio ar gyfer
y datblygiad a ddisgrifir uchod. Atodir yr Hysbysiad
o Benderfyniad sy'n rhoi caniatâd cynllunio.

Mae'r Hysbysiad o Benderfyniad yn bwysig. Fe
ddylech ei ddarllen ar y cyd â'r cais ac unrhyw
ddogfennau neu gynlluniau a gymeradwywyd.

Rhaid ymgymryd â'r datblygiad yn llwyr unol â'r
cynlluniau a'r manylion a gymeradwywyd, gan
sicrhau y cydymffurfir yn llawn â'r holl amodau. Os
bydd angen cymeradwyaeth pellach a / neu
gyflwyno rhagor o fanylion ar gyfer unrhyw un o'r
amodau cyn i'r datblygiad neu'r defnydd ddechrau,
rhaid bodloni gofynion yr amod cyn ymgymryd â'r
datblygiad. Fe all methu â chyflawni'r datblygiad
yn llwyr unol â'r cynlluniau a gymeradwywyd a /
neu fethu â chydymffurfio ag unrhyw un o'r
amodau annilysu eich caniatâd cynllunio ac fe all y
datblygiad fod yn un diawdurdod.

Darllenwch yr Hysbysiad o Benderfyniad yn ofalus
a gwnewch yn siŵr eich bod yn deall ac yn
cydymffurfio â gofynion unrhyw amodau.

Os nad ydych chi'n deall unrhyw un o'r gofynion
hyn, mae croeso i chi gysylltu â ni - cofiwch
ddyfynnu'r cyfeirnod sy'n ymddangos ar yr
Hysbysiad o Benderfyniad.

Application No. : NP5/54/40A

Development Description:
**Erection of new turbine house in association
with an existing hydro electric scheme.**

Site / Location:
The Old Creamery, Rhydymain.

Dear Sir,

I refer to the planning application relating to the
development as described above. Attached is the
Decision Notice granting planning permission.

The Decision Notice is important. You must read it
together with the application and any approved plans
or documents.

Development must be carried out in complete
accordance with the approved plans and details,
together with the full compliance of all conditions. If
any of the conditions require further approval and/or
the submission of further details before development
starts or the use begins, the requirements of the
condition must be satisfied before a start is made on
the development. Failure to carry out the development
in complete accordance with the approved plans
and/or failure to comply with any conditions may
invalidate your planning permission and the
development may be unauthorised.


Please carefully read the Decision Notice and ensure
that you understand and comply with the requirements
of any conditions.

If you do not understand any of these requirements
please contact us quoting the reference number on the
Decision Notice.

Full Abstraction Licence
 Ref. No.: 23/64/4/0077
 Mr I Richardson
 Afon Mynach



Asiantaeth yr
 Amgylchedd Cymru
 Environment
 Agency Wales



Reproduced from the Ordnance Survey mapping with the permission of the Controller of Her Majesty's Stationery Office © Crown copyright. Unauthorised reproduction infringes Crown copyright and may lead to prosecution or civil proceedings. Licence No: GD03177G