

Permit Number: EPR/BV7460ID Operator: Vishay Newport Limited

Facility: Newport Semiconductor Plant Form Number: Water1 / 14/09/2020

**Reporting of emissions to water (other than to sewer) and land for the period from 1/07/2025 to 31/12/2025**

Emission Point	Substance / Parameter	Emission		Reference Period	Result <sup>[1]</sup>	Test Method <sup>[2]</sup>	Sample Date and Times <sup>[3]</sup>	Uncertainty <sup>[4]</sup>
		Limit Value						
W1	Oil and grease	None visible		Spot sample	None visible (See comments below in bold)	Visual check	Weekly & routine checks	N/A
	pH	Minimum 6, Maximum 9		Spot sample	Min. 5.6 Max. 8.5	SCA Blue Book 14 ISBN 0117514284 or as agreed in writing with Natural Resources Wales	Remained in spec - Numerous instances of each – continuous log	±pH0.05

Notes:

[1] The result given is the maximum value (or the minimum value in the case of a limit that is expressed as a minimum) obtained during the reporting period, expressed in the same terms as the emission limit value. Where the emission limit value is expressed as a range, the result is given as the 'minimum – maximum' measured values.

[2] Where an internationally recognised standard test method is used the reference number is given. Where another method that has been formally agreed with Natural Resources Wales is used, then the appropriate identifier is given. In other cases the principal technique is stated, for example gas chromatography.

[3] For non-continuous measurements the date and time of the sample that produced the result is given. For continuous measurements the percentage of the process operating time covered by the result is given.

[4] The uncertainty associated with the quoted result at the 95% confidence interval, unless otherwise stated.

[5] For 95 % of all measured values according to look up table.

Signed .....  
(Authoriser)

Date...22<sup>nd</sup> January 2026.....

Permit Number: EPR/BV7460ID

Operator: Vishay Newport Limited

Facility: Newport Semiconductor Plant Form Number: Sewer1 / 14/09/2020

**Reporting of emissions to sewer for the period from 01/07/2025 to 31/12/2025**

Emission Point	Substance / Parameter	Emission		Result <sup>[1]</sup>	Test Method <sup>[2]</sup>	Sample Date and Times <sup>[3]</sup>	Uncertainty <sup>[4]</sup>
		Limit Value	Reference Period				
S1	Suspended solids	No limit set	Spot sample	Min. 13 mg/l Max. 29 mg/l	BS EN 872, BS 6068-2.54	29 <sup>th</sup> Sep 2025 @ 10:30 14 <sup>th</sup> Oct 2025 @ 11:40	Not Known
	Chemical oxygen demand	No limit set	Spot sample	Min. 50 mg/l Max. 92 mg/l	BS 6068-2.34	All other samples 50 mg/l 27 <sup>th</sup> Nov 2025 @ 11:16	Not Known
	Flow	No limit set	Continuous reported as daily average	Ave. 1,141 m <sup>3</sup> /day	As agreed in writing with Natural Resources Wales	N/A - Average	±4.826% (MCERTS)
	Copper	No limit set	Spot sample	<0.1 mg/l	BS EN ISO 15586:2003, BS 6068-2.84:2003	All samples <0.1 mg/l	Not known
	Nickel	No limit set	Spot sample	<0.1 mg/l	BS 6068-2.29, ISO 8288	All samples <0.1 mg/l	Not known
	Zinc	No limit set	Spot sample	<0.1 mg/l	BS 6068-2.29, ISO 8288	All samples <0.1 mg/l	Not known
	Chromium	No limit set	Spot sample	<0.1 mg/l	BS EN 1233, BS 6068-2.38, ISO 11083	All samples <0.1 mg/l	Not known
	Sulphate	No limit set	Spot sample	Min. 100 mg/l Max. 237 mg/l	SCA Blue Book 136 ISBN 0117522406	27 <sup>th</sup> Nov 2025 @ 11:16 29 <sup>th</sup> Sep 2025 @ 10:30	Not known
	pH	Minimum 6, Maximum 11	Continuous reported as maximum and minimum over reporting period	Min. 7.5 Max. 8	SCA Blue Book 14 ISBN 0117514284 or agreed in writing with Natural Resources Wales	27 <sup>th</sup> Nov 2025 @ 11:16 14 <sup>th</sup> Oct 2025 @ 11:40	±pH0.05

Notes:

[1] The result given is the maximum value (or the minimum value in the case of a limit that is expressed as a minimum) obtained during the reporting period, expressed in the same terms as the emission limit value. Where the emission limit value is expressed as a range, the result is given as the 'minimum – maximum' measured values.

[2] Where an internationally recognised standard test method is used the reference number is given. Where another method that has been formally agreed with Natural Resources Wales is used, then the appropriate identifier is given. In other cases the principal technique is stated, for example gas chromatography.

[3] For non-continuous measurements the date and time of the sample that produced the result is given. For continuous measurements the percentage of the process operating time covered by the result is given.

[4] The uncertainty associated with the quoted result at the 95% confidence interval, unless otherwise stated.

[5] For 95 % of all measured values according to look up table

[6] MCERTS uncertainty updated following latest inspection by CSA Group

Signed .....  ..

Date.....22<sup>nd</sup> January 2026.....

(Authorised to sign as representative of Operator)