



Element, Unit C6, Emery Court, The Embankment Business Park, Heaton Mersey, Stockport, SK4 3GL
Your Element Contact: Richard Carter (+44(0)7585 894 426)
E: richard.carter@element.com

Stack Emissions Testing Report Commissioned by
Duynie Ingredients

Installation Name & Address

Duynie Ingredients
Coed Abden Road
Wrexham Industrial Estate
Wrexham
LL13 9UH

Stack Reference

Boiler 1

Dates of the Monitoring Campaign

25th - 26th September 2025

Job Reference Number

EMT14377

Report Written by

Stephen Taylor
Team Leader
MCERTS Level 2
MM 23 1803
TE1 TE3 & TE4

Report Approved by

Donal O Faogain
Technical Report Writer
MCERTS Level 2
MM13 1259
TE1 TE2 TE3 TE4

Report Date

8th October 2025

Version

Version 1

Signature of Report Approver



TITLE PAGE

CONTENTS

EXECUTIVE SUMMARY

Monitoring Objectives	3
Monitoring Results	4
Monitoring Dates & Times	5
Process Details	6
Monitoring & Analytical Methods	7
Summary of Sampling Deviations	7
Sampling Location	8
Plant Photos / Sample Points	9

APPENDIX 1 - Monitoring Personnel & List of Equipment

APPENDIX 2 - Raw Data, Sampling Equations & Charts

Opinions and interpretations expressed herein are outside the scope of Element's ISO 17025 accreditation.

This test report shall not be reproduced, except in full, without the written approval of Element.

Executive Summary

(Page 1 of 7)

MONITORING OBJECTIVES

Duynie Ingredients , Wrexham

Boiler 1

25th - 26th September 2025

Overall Aim of the Monitoring Campaign

Element were commissioned by Duynie Ingredients to carry out stack emissions testing on the Boiler 1 at Wrexham.

The aim of the monitoring campaign was to perform testing, as requested by the customer, for a number of prescribed pollutants. There are no emission limits set for any of the pollutants at this time.

Special Requirements

There were no special requirements.

Target Parameters

Oxides of Nitrogen (as NO₂), Carbon Monoxide

Executive Summary
(Page 2 of 7)

MONITORING RESULTS

Duynie Ingredients , Wrexham
Boiler 1
25th - 26th September 2025

where MU = Measurement Uncertainty associated with the Result

Parameter	Concentration				Mass Emission			
	Units	Result	MU +/-	Limit	Units	Result	MU +/-	Limit
Oxides of Nitrogen (as NO ₂)	¹ mg/m ³	75.2	4.8	-	g/hr	246	24.1	-
Carbon Monoxide	¹ mg/m ³	1.9	1.4	-	g/hr	6.1	4.5	-
Oxygen	% v/v Wet 4.80	% v/v Dry 5.6	0.30					
Water Vapour	% v/v	13.8	0.59					
Stack Gas Temperature	°C	123						
Stack Gas Velocity	m/s	3.8	0.22					
Volumetric Flow Rate (ACTUAL)	m ³ /hr	5224	391					
Volumetric Flow Rate (REF)	¹ m ³ /hr	3270	245					

NOTE: VOLUMETRIC FLOW RATE & VELOCITY DATA TAKEN FROM THE PRELIMINARY VELOCITY TRAVERSE.

¹ Reference Conditions (REF) are: 273K, 101.3kPa, without correction for water vapour content, 3% oxygen.

Executive Summary

(Page 3 of 7)

MONITORING DATE(S) & TIMES

Duynie Ingredients , Wrexham

Boiler 1

25th - 26th September 2025

Parameter	Units	Concentration	Units	Mass Emission	Sampling Date(s)	Sampling Times	Duration mins
Oxides of Nitrogen (as NO ₂)	R1 mg/m ³	75.2	g/hr	246	26/09/2025	12:12 - 13:12	60
Carbon Monoxide	R1 mg/m ³	1.9	g/hr	6.1	26/09/2025	12:12 - 13:12	60
Oxygen	R1 % v/v	4.8			26/09/2025	12:12 - 13:12	60
Water Vapour	R1 % v/v	13.8			26/09/2025	12:12 - 13:12	60
Velocity Traverse	R1				26/09/2025	11:58 - 12:08	

All results are expressed at the respective reference conditions.

Executive Summary
(Page 4 of 7)

PROCESS DETAILS

Duynie Ingredients , Wrexham
Boiler 1
25th - 26th September 2025

Standard Operating Conditions

Parameter	Value
Process Status	Normal Operating Capacity
Capacity (of 100%) and Tonnes / Hour	Variable On Demand
Continuous or Batch Process	Continuous
Feedstock (if applicable)	Natural Gas
Abatement System	N/A
Abatement System Running Status	N/A
Fuel	Natural Gas
Plume Appearance	None Visible

Executive Summary

(Page 5 of 7)

MONITORING & ANALYTICAL METHODS

Duynie Ingredients , Wrexham

Boiler 1

25th - 26th September 2025

Parameter	Monitoring				Analysis				Overall Status	LOD (Average)
	Standard	Technical Procedure	Sampling Status	Testing Lab	Analytical Procedure	Analytical Technique	Analysis Status	Analysis Lab		
Water Vapour	EN 14790	MD 005	MCERTS	EET	MD 005	Gravimetric	MCERTS	EET	MCERTS	0.10 % v/v
Oxides of Nitrogen (as NO ₂)	EN 14792	MD 021	MCERTS	EET	Chemiluminescence by Horiba PG-250				MCERTS	0.41 mg/m ³
Carbon Monoxide	EN 15058	MD 021	MCERTS	EET	NDIR by Horiba PG-250				MCERTS	1.96 mg/m ³
Oxygen	EN 14789	MD 021	MCERTS	EET	Dry Zirconia Cell by Horiba PG-250				MCERTS	0.1 %
Velocity & Vol. Flow Rate	EN 16911-1 (MID)	MD 041	MCERTS	EET	Pitot Tube and Thermocouple				MCERTS	1.2 m/s

ANALYSIS LABORATORIES

(with short name reference as appears in the table above)

Element (Stockport Lab - EET)	ISO 17025 Accreditation Number: UKAS 4279
-------------------------------	---

SUMMARY OF SAMPLING DEVIATIONS

Parameter	Run	Deviation
Velocity & Vol. Flow Rate	All	Only one out of two required sampling lines was available, however the number of sample points used on the available line were increased to the minimum required by the Standard

SUITABILITY OF SAMPLING LOCATION

Duct Characteristics

Parameter	Units	Value
Type	-	Circular
Depth	m	0.70
Width	m	-
Area	m ²	0.38
Port Depth	cm	8
Orientation of Duct	-	Vertical
Number of Ports	-	1
Sample Port Size	-	5" BSP

Location of Sampling Platform

General Platform Information	Value
Permanent / Temporary Platform	MEWP
Inside / Outside	Outside

Platform Details

EA Technical Guidance Note M1 / EN 15259 Platform Requirements	Value
Sufficient working area to manipulate probe and operate the measuring instruments	Yes
Platform has 2 levels of handrails (approx. 0.5m & 1.0m high)	N/A
Platform has vertical base boards (approx. 0.25m high)	N/A
Platform has chains / self closing gates at top of ladders	N/A
There are no obstructions present which hamper insertion of sampling equipment	Yes
Safe Access Available	Yes
Easy Access Available	No

Sampling Location / Platform Improvement Recommendations

The sampling location meets all the requirements specified in EA Guidance Note M1 and EN 15259, and therefore there are no improvement recommendations.

EN 15259 Homogeneity Test Requirements

There is no requirement to perform a EN 15259 Homogeneity Test on this Stack.

Sampling Plane Validation Criteria (from EN 15259)

Criteria in EN 15259	Units	Traverse 1	Required	Compliant
Lowest Differential Pressure	Pa	8.6	> 5 Pa	Yes
Mean Velocity	m/s	3.77	-	-
Lowest Gas Velocity	m/s	3.70	-	-
Highest Gas Velocity	m/s	3.93	-	-
Ratio of Above	: 1	1.06	< 3 : 1	Yes
Maximum Angle of Swirl	°	7.00	< 15°	Yes
No Local Negative Flow	-	Yes	-	Yes


PLANT PHOTOS

Photo 1

Photo 2



SAMPLE POINTS



- where
- = isokinetic point sampled at
 - = isokinetic point not sampled at
 - = combustion gases sample point
 - = non-isokinetic sample point



APPENDICES

APPENDIX CONTENTS

APPENDIX 1 - Stack Emissions Monitoring Personnel, List of Equipment & Methods and Technical Procedures Used

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

STACK EMISSIONS MONITORING PERSONNEL

Position	Name	MCERTS Accreditation	MCERTS Number	Technical Endorsements
Team Leader	Stephen Taylor	MCERTS Level 2	MM 23 1803	TE1 TE3 & TE4
Technician	Tom Dixon	MCERTS Level 1	MM 23 1802	TE1

LIST OF EQUIPMENT

Extractive Sampling		Instrumental Analysers		Miscellaneous Items	
Equipment Type	Equipment I.D.	Equipment Type	Equipment I.D.	Equipment Type	Equipment I.D.
Control Box DGM (1)	-	Horiba PG-250	CAT 9.29	Digital Manometer 500	CAT 3.265
Control Box DGM (2)	-	Horiba PG-250	-	Digital Manometer 10000	-
Box Thermocouples (1)	-	Servomex 4900	-	Digital Temperature Meter	-
Box Thermocouples (2)	-	Eco Physics CLD 822Mh	-	Stopwatch	CAT 14.98
Umbilical (1)	-	ABB AO2020-URAS26	-	Barometer	CAT 13.62
Umbilical (2)	-	Testo 350 XL	-	Stack Thermocouple 0.5m	-
Oven Box (1)	-	JCT JCC P1 Cooler	CAT 4.0030	Stack Thermocouple 1.0m	-
Oven Box (2)	-	Gasmet DX4000	-	Stack Thermocouple 1.5m	-
Heated Probe (1)	-	Gasmet Sampling System	-	1m Heated Line (1)	-
Heated Probe (2)	-	Sick 3006	-	1m Heated Line (2)	-
Heated Probe (3)	-	M&C PSS	CAT 12.174	1m Heated Line (3)	-
S-Pitot (1)	CAT 215.71	Mass Flow Controller (1)	CAT 6.23	5m Heated Line (1)	-
S-Pitot (2)	-	Mass Flow Controller (2)	CAT 6.24	15m Heated Line (1)	-
L-Pitot	-	Mass View (1)	CAT 25.94	20m Heated Line (1)	CAT 20.277
Site Balance	CAT 17.108	Mass View (2)	CAT 25.121	20m Heated Line (2)	-
500g / 1Kg Check Weights	CAT 17.108	Hioki 5043 (V)	-	Dual Channel Heater Controller	-
Last Impinger Arm	-	Easylogger EN-EL-12 Bit	-	Single Channel Heater Controller	-
Callipers	-	Bioaerosols Temperature Logger	-	Laboratory Balance	-
Tubes Kit Thermocouple	-	Electronic Refrigerator	-	Tape Measure	CAT 16.58

METHODS & TECHNICAL PROCEDURES USED

Parameter	Standard	Technical Procedure
Water Vapour	EN 14790	MD 005
Oxides of Nitrogen (as NO ₂)	EN 14792	MD 021
Carbon Monoxide	EN 15058	MD 021
Oxygen	EN 14789	MD 021
Velocity & Vol. Flow Rate	EN 16911-1 (MID)	MD 041

PRELIMINARY STACK SURVEY: CALCULATIONS

General Stack Details

Stack Details (from Traverse)	Units	Value
Stack Diameter / Depth, D	m	0.70
Stack Width, W	m	-
Stack Area, A	m ²	0.38
Average Stack Gas Temperature, T _a	°C	123.2
Average Stack Gas Pressure	Pa	8.9
Average Stack Static Pressure, P _{static}	kPa	-0.033
Average Barometric Pressure, P _b	kPa	102.3
Average Pitot Tube Calibration Coefficient, C _p	-	0.84

Stack Gas Composition & Molecular Weights

Component	Conc ppm	Conc Dry % v/v	Conc Wet % v/v	Volume Fraction r	Molar Mass M	Density kg/m ³ p	Conc kg/m ³ p _i
CO ₂ (Estimated)	-	10.00	8.62	0.1000	44.01	1.9635	0.19635
O ₂	-	5.57	4.80	0.0557	32.00	1.4277	0.07955
N ₂	-	84.43	72.79	0.8443	28.01	1.2498	1.05522
Moisture (H ₂ O)	-	-	13.79	0.1379	18.02	0.8037	0.11082

Where: $p = M / 22.41$
 $p_i = r \times p$

Calculation of Stack Gas Densities

Determinand	Units	Result
Dry Density (STP), P _{STD}	kg/m ³	1.331
Wet Density (STP), P _{STW}	kg/m ³	1.258
Dry Density (Actual), P _{Actual}	kg/m ³	0.926
Average Wet Density (Actual), P _{ActualW}	kg/m ³	0.875

Where: P_{STD} = sum of component concentrations, kg/m³ (not including water vapour)
 P_{STW} = sum of all wet concentrations / 100 x density, kg/m³ (including water vapour)
 $P_{Actual} = P_{STD} \times (T_{STP} / (P_{STP})) \times ((P_{static} + P_b) / T_a)$
 $P_{ActualW}$ (at each sampling point) = $P_{STW} \times (T_c / P_s) \times (P_a / T_a)$

Calculation of Stack Gas Volumetric Flowrate, Q

Duct gas flow conditions	Units	Actual	REF ¹
Temperature	°C	123.2	0.0
Total Pressure	kPa	102.3	101.3
Moisture	%	13.79	13.79
Oxygen (Dry)	%	5.6	N/A
Oxygen (Wet)	%	4.8	3.0

Gas Volumetric Flowrate (from Traverse)	Units	Result
Gas Volumetric Flowrate (Actual)	m ³ /hr	5224
Gas Volumetric Flowrate (STP, Wet)	m ³ /hr	3634
Gas Volumetric Flowrate (STP, Dry)	m ³ /hr	3133
Gas Volumetric Flowrate REF ¹	m ³ /hr	3270

PRELIMINARY STACK SURVEY: VELOCITY TRAVERSE TO EN 16911-1 (MID)

(1 of 1)

Parameter	Units	Value
Date of Survey	-	26/09/2025
Time of Survey	-	11:58 - 12:08
Atmospheric Pressure	kPa	102.3
Average Stack Static Pressure	Pa	-33
Result of Pitot Stagnation Test	-	Pass
Are Water Droplets Present?	-	No
Device Used	S-Type Pitot with KIMO MP 210 (500Pa)	

Parameter	Units	Value
Initial Pitot Leak Check	-	Pass
Final Pitot Leak Check	-	Pass
Orientation of Duct	-	Vertical
Pitot Tube, C _p	-	0.84
Number of Lines Available	-	1
Number of Lines Used	-	1

Sampling Line A						
Traverse Point	Depth m	ΔP Pa	Temp °C	Wet Density kg/m ³	Velocity m/s	Swirl °
STATIC (Units: Pa)		-32.7				
Mean		8.9	123.2	0.875	3.77	
1	0.05	8.8	123.2	0.875	3.75	6.0
2	0.18	8.6	123.2	0.875	3.70	7.0
3	0.53	8.6	123.3	0.875	3.70	7.0
4	0.65	9.7	123.2	0.875	3.93	6.0

PRELIMINARY STACK SURVEY: VELOCITY TRAVERSE TO EN 16911-1 (MID) - MEASUREMENT UNCERTAINTY

(1 of 1)

Performance characteristics (Uncertainty Components)	Uncertainty	Value	Units
Standard Uncertainty on the coefficient of the Pitot Tube	$u(k)$	0.005	-
Standard Uncertainty associated with the mean local dynamic pressures	$u(\Delta p_i)$	1.046	Pa
- Resolution	$u(res)$	0.00087	
- Calibration	$u(cal)$	0.008	
- Drift	$u(drift)$	0.083	
- Lack of Fit	$u(fit)$	0.002	
- Overall corrections to dynamic measurements	$u(C_f)$	0.094	
Standard uncertainty associated with the molar mass of the gas	$u(M)$	0.00008	-
- $\varphi_{O_2,w}$	-	4.804	
- $\varphi_{CO_2,w}$	-	8.621	
- Oxygen, dry	$u(\phi_{O_2,d})$	0.171	
- Carbon Dioxide, dry	$u(\phi_{CO_2,d})$	0.306	
- Water Vapour	$u(\phi_{H_2O})$	0.703	
- Oxygen, wet	$u(\phi_{O_2,w})$	0.152	
- Carbon Dioxide, wet	$u(\phi_{CO_2,w})$	0.273	
Standard uncertainty associated with the stack temperature	$u(T_c)$	2.022	K
Standard uncertainty associated with the absolute pressure in the duct	$u(p_c)$	175.695	Pa
- Atmospheric Pressure	$u(p_{atm})$	175.692	
- Static Pressure	$u(p_{stat})$	1.046	
Standard uncertainty associated with the density in the duct	$u(\rho)$	0.00537	-
Standard uncertainty associated with the local velocities	$u(v_i)$	0.223	Pa
Standard uncertainty associated with the mean velocity	$u(\bar{v})$	0.115	m/s
Standard uncertainty associated with the mean velocity (95% Confidence)	$U_c(v)$	0.225	m/s
Standard uncertainty associated with the mean velocity (95% Confidence), relative	$U_{c,rel}(v)$	5.96	%
Standard uncertainty associated with the volume flow rate (95% Confidence)	$U_c(qV,w)$	390.9	m ³ /hr
- $u^2(a)/a^2$	-	0.00053	
- $u^2(qV,w)/q^2V,w$	-	0.00146	
- $u^2(qV,w)$	-	39774	
- $u(qV,w)$	-	199.4	
Standard uncertainty associated with the volume flow rate (95% Confidence), relative	$U_{c,rel}(qV,w)$	7.48	%

WATER VAPOUR: RESULTS SUMMARY

Duynie Ingredients , Wrexham
Boiler 1

Sample Runs

Parameter	Units	Run 1	Mean
Concentration	% v/v	13.8	13.8
Uncertainty	±% v/v	0.59	0.59

General Sampling Information

Parameter	Value
Standard	EN 14790
Technical Procedure	MD 005

WATER VAPOUR: SAMPLING DETAILS

Sample Runs

Parameter	Units	Run 1
Sampling Times	-	12:12 - 13:12
Sampling Dates	-	26/09/2025
Sampling Device	-	MFC / MV
Duration	mins	60
Volume Sampled (STP, Dry)	m ³	0.1846
Volume Sampled (STP, Wet)	m ³	0.2142
Sample Flow Rate	l/min	2.98
Liquid Trap Start Mass	g	4042.5
Liquid Trap End Mass	g	4063.1
Silica Trap Start Mass	g	1451.4
Silica Trap End Mass	g	1454.5
Total Mass Of Water Vapour	g	23.7
Calculated Water Vapour	% v/v	13.79

Where: MFC stands for Mass Flow Controller, MV stands for Mass View Flowmeter

WATER VAPOUR: QUALITY ASSURANCE

Sample Runs

Leak Test Results	Units	Run 1
Mean Sampling Rate	l/min	3.0
Pre-Sampling Leak Rate	l/min	0.02
Post-Sampling Leak Rate	l/min	0.02
Allowable Leak Rate	l/min	0.06
Leak Test Acceptable	-	Yes

Water Droplets	Units	Run 1
Are Water Droplets Present	-	No

Measurement Uncertainty	Units	Run 1
Measurement Uncertainty (MU)	%	4.3
Allowable MU	%	20.0
MU Acceptable	%	Yes

Silica Gel	Units	Run 1
Less than 50% Faded	%	Yes

Test Conditions	Units	Run 1
Ambient Temperature Recorded?	-	Yes

Method Deviations

Nature of Deviation	Run Number
(x = deviation applies to the associated run)	1
There are no deviations associated with the sampling employed.	x

WATER VAPOUR: MEASUREMENT UNCERTAINTY CALCULATIONS

Measured Quantities	Value		Standard uncertainty		
	Symbol	Run 1	Symbol	Units	Run 1
Sampled Volume (STP)	V _m	0.1846	uV _m	m ³	0.0037
Repeatability of Weighing	R _w	23.70	uR _w	g	0.15
Reading of Balance	R _b	23.70	uR _b	g	0.12
Leak	L	0.67		%	-

Measured Quantities	Uncertainty as a Percentage		Requirement of Standard
	Units	Run 1	
Sampled Volume (STP)	%	2.00	≤2%
Repeatability of Weighing	%	0.63	No Requirement
Reading of Balance	%	0.50	No Requirement
Leak	%	0.67	≤2%

Measured Quantities	Uncertainty in Measurement Units			Sensitivity Coefficient
	Symbol	Units	Run 1	
Sampled Volume (STP)	V _m	m ³	0.1846	74.67
Repeatability of Weighing	R _w	g	23.70	0.58
Reading of Balance	R _b	g	23.70	0.58
Leak	L	% v/v	0.05	1.00

Measured Quantities	Uncertainty in Result	
	Units	Run 1
Sampled Volume (STP)	% v/v	0.276
Repeatability of Weighing	% v/v	0.087
Reading of Balance	% v/v	0.069
Leak	% v/v	0.053

Parameter	Units	Run 1
Combined uncertainty	% v/v	0.30
Expanded uncertainty (95% confidence)	% v/v	0.59
Expanded uncertainty (95% confidence), estimated with Method Deviations	% v/v	0.59
Uncertainty if Water Droplets are present	% v/v	N/A
Reported Uncertainty	% v/v	0.59
Expanded uncertainty (95% confidence)	%	4.3
Expanded uncertainty (95% confidence), estimated with Method Deviations	%	4.3
Uncertainty if Water Droplets are present	%	N/A
Reported Uncertainty	%	4.3

OXIDES OF NITROGEN (as NO₂): RESULTS SUMMARY

Duynie Ingredients , Wrexham
Boiler 1

Sample Runs

Parameter	Units	Run 1	Mean
Concentration	mg/m ³	75.2	75.2
Uncertainty	±mg/m ³	4.8	4.8
Mass Emission	g/hr	246	246
Uncertainty	±g/hr	24.1	24.1

General Sampling Information

Parameter	Value
Standard	EN 14792
Technical Procedure	MD 021
Probe Material	Stainless Steel
Filtration Type / Size	0.1µm Glass Fibre
Heated Head Filter Used	Yes
Heated Line Temperature	180°C
Date & Result of Last Converter Check	10/03/2025 - 95.8%
Span Gas Type	Nitrogen Monoxide
Span Gas Reference Number	12.0734
Span Gas Expiry Date	07/04/2027
Span Gas Start Pressure (bar)	150
Gas Cylinder Concentration (ppm)	401
Span Gas Uncertainty (%)	2
Zero Gas Type	Nitrogen (5 Grade)
Number of Sampling Lines Used	1 / 1
Number of Sampling Points Used	1 / 1
Sample Point I.D.'s	A1

NOTE: Dilution performed to achieve correct span value

FORMAT: Number Used / Number Required


FORMAT: Number Used / Number Required

Reference Conditions

Reference Conditions are: 273K, 101.3kPa, without correction for water vapour content, 3% oxygen.

OXIDES OF NITROGEN (as NO₂): DATA TREND

Graphical Trend of Data



OXIDES OF NITROGEN (as NO₂): SAMPLING DETAILS & QUALITY ASSURANCE

Sampling Details

Parameter	Units	Run 1
Sampling Times	-	12:12 - 13:12
Sampling Dates	-	26/09/2025
Instrument Range	ppm	500
Span Gas Value	ppm	401.0

Quality Assurance

Conditioning Unit Temperature	Units	Run 1
Average Temperature	°C	2.8
Allowable Temperature	< °C	4.0
Temperature Acceptable	-	Yes

Zero Drift	Units	Run 1	
CAL 1	Zero at Analyser (Pre)	ppm	0.00
	Zero at Analyser (Post)	ppm	-0.40
	Zero Drift	ppm	-0.40
	Zero Drift	%	0.10
	Drift Correction Applied	2-5%	No
	Allowable Zero Drift	± %	5.00
	Zero Drift Acceptable	-	Yes

Span Drift	Units	Run 1	
CAL 1	Span at Analyser (Pre)	ppm	401.00
	Span at Analyser (Post)	ppm	401.40
	Span Drift	ppm	0.40
	Zero Adj. Span Drift	%	0.20
	Drift Correction Applied	2-5%	No
	Allowable Span Drift	± %	5.00
	Span Drift Acceptable	-	Yes

Test Conditions	Units	Run 1
Run Ambient Temperature Range	°C	18 - 20

Method Deviations

Nature of Deviation	Run Number
(x = deviation applies to the associated run)	1
There are no deviations associated with the sampling employed.	

OXIDES OF NITROGEN (as NO₂): MEASUREMENT UNCERTAINTY CALCULATIONS

Performance characteristics	RUN 1	Units
Limit value	-	mg/m ³ (REF)
Allowable MU	10.0	%
Measured concentration	78.49	mg/m ³ (STP, dry)
Ratio NO / NO ₂	5	%
Range Used	500.0	ppm
Range Used [A]	1026.1	mg/m ³
Cal gas conc.	401.0	ppm
Conversion	2.05	ppm to mg/m ³
MCERTS Range [B]	125.0	mg/m ³
Lower of [A] or [B]	125.0	mg/m ³
Cal gas conc.	823.0	mg/m ³

Performance characteristics	RUN 1	Units
Response time	60	seconds
Number of readings in measurement	60	-
Repeatability at zero	0.40	% full scale
Repeatability at span level	0.40	% full scale
Deviation from linearity	0.56	% of value
Zero drift	-0.10	% full scale
Span drift	0.20	% full scale
Volume or pressure flow dependence	0.40	% of full scale
Atmospheric pressure dependence	0.30	% of value/kPa
Ambient temperature dependence	0.18	% full scale/10K
Combined interference	0.60	% range
Dependence on voltage	0.40	% full scale/10V
Converter efficiency	95.8	%
Losses in the line (leak)	1.00	% of value
Uncertainty of calibration gas blending	1.40	% of value
Uncertainty of calibration gas	2.00	% of value

Performance characteristic	RUN 1	Units
Standard deviation of repeatability at zero	use rep at span	mg/m ³
Standard deviation of repeatability at span level	0.05	mg/m ³
Lack of fit	0.40	mg/m ³
Drift	-0.38	mg/m ³
Volume or pressure flow dependence	0.00	mg/m ³
Atmospheric pressure dependence	0.11	mg/m ³
Ambient temperature dependence	0.03	mg/m ³
Combined interference (from MCERTS Certificate)	0.43	mg/m ³
Dependence on voltage	0.05	mg/m ³
Converter efficiency	0.10	mg/m ³
Losses in the line (leak)	0.45	mg/m ³
Uncertainty of calibration gas blending	0.63	mg/m ³
Uncertainty of calibration gas	0.91	mg/m ³

Measurement uncertainty	Result	RUN 1	Units
Combined uncertainty		78.49	mg/m ³
Expanded uncertainty		1.40	mg/m ³
Expanded uncertainty	k = 1.96	2.74	mg/m ³
Uncertainty corrected to std conds. (O ₂)		3.20	mg/m ³ (REF)

	RUN 1	Units
Expanded uncertainty (no O ₂) - at 95% Confidence	3.49	% of Value
Expanded uncertainty (no O ₂) - at 95% Confidence	N/A	% at ELV
Overall Allowable uncertainty (no O ₂) - at 95% Confidence	N/A	% at ELV
Result of Compliance with Uncertainty Requirement	N/A	-

	RUN 1	Units
Expanded uncertainty (with O ₂) - at 95% Confidence	6.36	% of Value
Expanded uncertainty (with O ₂) - at 95% Confidence	N/A	% at ELV
Overall Allowable uncertainty (with O ₂) - at 95% Confidence	N/A	% at ELV
Result of Compliance with Uncertainty Requirement	N/A	-

Requirement for SRM is that Uncertainty should be <10% of the value at the ELV, on a dry gas basis, or if O₂ correction is applied less than 10% + the uncertainty associated with the O₂ correction (using sqrt of sum squares to add uncertainty components).

CARBON MONOXIDE: RESULTS SUMMARY

Duynie Ingredients , Wrexham
Boiler 1

Sample Runs

Parameter	Units	Run 1	Mean
Concentration	mg/m ³	1.9	1.9
Uncertainty	±mg/m ³	1.4	1.4
Mass Emission	g/hr	6.1	6.1
Uncertainty	±g/hr	4.5	4.5

General Sampling Information


Parameter	Value	
Standard	EN 15058	
Technical Procedure	MD 021	
Probe Material	Stainless Steel	
Filtration Type / Size	0.1µm Glass Fibre	
Heated Head Filter Used	Yes	
Heated Line Temperature	180°C	
Span Gas Type	Carbon Monoxide	
Span Gas Reference Number	12.0734	
Span Gas Expiry Date	07/04/2027	
Span Gas Start Pressure (bar)	150	
Gas Cylinder Concentration (ppm)	395.1	NOTE: Dilution performed to achieve correct span value
Span Gas Uncertainty (%)	2	
Zero Gas Type	Nitrogen (5 Grade)	
Number of Sampling Lines Used	1 / 1	FORMAT: Number Used / Number Required
Number of Sampling Points Used	1 / 1	FORMAT: Number Used / Number Required
Sample Point I.D.'s	A1	

Reference Conditions

Reference Conditions are: 273K, 101.3kPa, without correction for water vapour content, 3% oxygen.

CARBON MONOXIDE: DATA TREND

Graphical Trend of Data



CARBON MONOXIDE: SAMPLING DETAILS & QUALITY ASSURANCE

Sampling Details

Parameter	Units	Run 1
Sampling Times	-	12:12 - 13:12
Sampling Dates	-	26/09/2025
Instrument Range	ppm	500
Span Gas Value	ppm	395.1

Quality Assurance

Conditioning Unit Temperature	Units	Run 1
Average Temperature	°C	2.8
Allowable Temperature	< °C	4.0
Temperature Acceptable	-	Yes

Zero Drift	Units	Run 1	
CAL 1	Zero at Analyser (Pre)	ppm	0.00
	Zero at Analyser (Post)	ppm	0.70
	Zero Drift	ppm	0.70
	Zero Drift	%	0.18
	Drift Correction Applied	2-5%	No
	Allowable Zero Drift	± %	5.00
	Zero Drift Acceptable	-	Yes

Span Drift	Units	Run 1	
CAL 1	Span at Analyser (Pre)	ppm	395.10
	Span at Analyser (Post)	ppm	394.00
	Span Drift	ppm	-1.10
	Zero Adj. Span Drift	%	0.46
	Drift Correction Applied	2-5%	No
	Allowable Span Drift	± %	5.00
	Span Drift Acceptable	-	Yes

Test Conditions	Units	Run 1
Run Ambient Temperature Range	°C	18 - 20

Method Deviations

Nature of Deviation	Run Number
(x = deviation applies to the associated run)	1
There are no deviations associated with the sampling employed.	

CARBON MONOXIDE: MEASUREMENT UNCERTAINTY CALCULATIONS

Performance characteristics	RUN 1	Units
Limit value	-	mg/m ³ (REF)
Allowable MU	6.0	%
Measured concentration	1.96	mg/m ³ (STP, dry)
Range Used	500.0	ppm
Range Used [A]	624.6	mg/m ³
Cal gas conc.	395.1	ppm
Conversion	1.25	ppm to mg/m ³
MCERTS Range [B]	95.0	mg/m ³
Lower of [A] or [B]	95.0	mg/m ³
Cal gas conc.	493.6	mg/m ³

Performance characteristics	RUN 1	Units
Response time	60	seconds
Number of readings in measurement	60	-
Repeatability at zero	0.40	% full scale
Repeatability at span level	0.40	% full scale
Deviation from linearity	0.63	% of value
Zero drift	0.18	% full scale
Span drift	-0.46	% full scale
Volume or pressure flow dependence	0.40	% of full scale
Atmospheric pressure dependence	0.30	% of value/kPa
Ambient temperature dependence	0.05	% full scale/10K
Combined interference	0.73	% range
Dependence on voltage	0.40	% full scale/10V
Losses in the line (leak)	1.49	% of value
Uncertainty of calibration gas blending	1.40	% of value
Uncertainty of calibration gas	2.00	% of value

Performance characteristic	RUN 1	Units
Standard deviation of repeatability at zero	use rep at span	mg/m ³
Standard deviation of repeatability at span level	0.05	mg/m ³
Lack of fit	0.35	mg/m ³
Drift	0.50	mg/m ³
Volume or pressure flow dependence	0.00	mg/m ³
Atmospheric pressure dependence	0.08	mg/m ³
Ambient temperature dependence	0.01	mg/m ³
Combined interference (from MCERTS Certificate)	0.40	mg/m ³
Dependence on voltage	0.05	mg/m ³
Losses in the line (leak)	0.02	mg/m ³
Uncertainty of calibration gas blending	0.02	mg/m ³
Uncertainty of calibration gas	0.02	mg/m ³

Measurement uncertainty	Result	RUN 1	Units
Combined uncertainty		1.96	mg/m ³
Expanded uncertainty	k = 1.96	0.73	mg/m ³
Expanded uncertainty		1.44	mg/m ³
Uncertainty corrected to std conds. (O ₂)		1.68	mg/m ³ (REF)

	RUN 1	Units
Expanded uncertainty (no O ₂) - at 95% Confidence	73.40	% of Value
Expanded uncertainty (no O ₂) - at 95% Confidence	N/A	% at ELV
Overall Allowable uncertainty (no O ₂) - at 95% Confidence	N/A	% at ELV
Result of Compliance with Uncertainty Requirement	N/A	-

	RUN 1	Units
Expanded uncertainty (with O ₂) - at 95% Confidence	73.59	% of Value
Expanded uncertainty (with O ₂) - at 95% Confidence	N/A	% at ELV
Overall Allowable uncertainty (with O ₂) - at 95% Confidence	N/A	% at ELV
Result of Compliance with Uncertainty Requirement	N/A	-

Requirement for SRM is that Uncertainty should be <6% of the value at the ELV, on a dry gas basis, or if O₂ correction is applied less than 6% + the uncertainty associated with the O₂ correction (using sqrt of sum squares to add uncertainty components).

OXYGEN: RESULTS SUMMARY

Duynie Ingredients , Wrexham
Boiler 1

Sample Runs

Parameter	Units	Run 1	Mean
Concentration	% v/v	4.8	4.8
Uncertainty	±% v/v	0.26	0.26

General Sampling Information

Parameter	Value
Standard	EN 14789
Technical Procedure	MD 021
Probe Material	Stainless Steel
Filtration Type / Size	0.1µm Glass Fibre
Heated Head Filter Used	Yes
Heated Line Temperature	180°C
Span Gas Type	Synthetic Air (5 Grade)
Span Gas Reference Number	11.0688
Span Gas Expiry Date	31/01/2030
Span Gas Start Pressure (bar)	180
Gas Cylinder Concentration (% v/v)	21.53
Span Gas Uncertainty (%)	2
Zero Gas Type	Nitrogen (5 Grade)
Number of Sampling Lines Used	1 / 1
Number of Sampling Points Used	1 / 1
Sample Point I.D.'s	A1


NOTE: Dilution performed to achieve correct span value

FORMAT: Number Used / Number Required

FORMAT: Number Used / Number Required

OXYGEN: DATA TREND

Graphical Trend of Data



OXYGEN: SAMPLING DETAILS & QUALITY ASSURANCE

Sampling Details

Parameter	Units	Run 1
Sampling Times	-	12:12 - 13:12
Sampling Dates	-	26/09/2025
Instrument Range	% v/v	25.0
Span Gas Value	% v/v	5.0

Quality Assurance

Conditioning Unit Temperature	Units	Run 1
Average Temperature	°C	2.8
Allowable Temperature	< °C	4.0
Temperature Acceptable	-	Yes

Zero Drift	Units	Run 1	
CAL 1	Zero at Analyser (Pre)	% v/v	0.00
	Zero at Analyser (Post)	% v/v	0.03
	Zero Drift	% v/v	0.03
	Zero Drift	%	0.55
	Drift Correction Applied	2-5%	No
	Allowable Zero Drift	± %	5.00
	Zero Drift Acceptable	-	Yes

Span Drift	Units	Run 1	
CAL 1	Span at Analyser (Pre)	% v/v	5.42
	Span at Analyser (Post)	% v/v	5.27
	Span Drift	% v/v	-0.15
	Zero Adj. Span Drift	%	3.60
	Drift Correction Applied	2-5%	Yes
	Allowable Span Drift	± %	5.00
	Span Drift Acceptable	-	Yes

Test Conditions	Units	Run 1
Run Ambient Temperature Range	°C	18 - 20

Method Deviations

Nature of Deviation	Run Number
(x = deviation applies to the associated run)	1
There are no deviations associated with the sampling employed.	

OXYGEN: MEASUREMENT UNCERTAINTY CALCULATIONS

Performance characteristics	RUN 1	Units
Limit value	N/A	%vol
Allowable MU	6.0	%
Measured concentration	4.80	%vol
Range Used	25.0	%vol
Cal gas conc.	21.5	%vol

Performance characteristics	RUN 1	Units
Response time	60	seconds
Number of readings in measurement	60	-
Repeatability at zero	0.04	% full scale
Repeatability at span level	0.04	% full scale
Deviation from linearity	0.05	% of value
Zero drift	0.55	% full scale
Span drift	0.00	% full scale
Volume or pressure flow dependence	0.20	% of full scale
Atmospheric pressure dependence	0.30	% of value/kPa
Ambient temperature dependence	-0.07	% full scale/10K
Combined interference	0.56	% range
Dependence on voltage	0.02	% full scale/10V
Losses in the line (leak)	1.60	% of value
Uncertainty of calibration gas	2.00	% of value

Performance characteristic	RUN 1	Units
Standard deviation of repeatability at zero	use rep at span	%vol
Standard deviation of repeatability at span level	0.01	%vol
Lack of fit	0.01	%vol
Drift	0.07	%vol
Volume or pressure flow dependence	0.00	%vol
Atmospheric pressure dependence	0.02	%vol
Ambient temperature dependence	-0.01	%vol
Combined interference (from MCERTS Certificate)	0.08	%vol
Dependence on voltage	0.00	%vol
Losses in the line (leak)	0.04	%vol
Uncertainty of calibration gas	0.06	%vol

Measurement uncertainty	Result	RUN 1	Units
Combined uncertainty		4.80	%vol
Expanded uncertainty		0.13	%vol
Expanded uncertainty	k = 1.96	0.26	%vol

Expanded uncertainty (no O ₂) - at 95% Confidence	RUN 1	Units
	5.31	% of Value
Result of Compliance with Uncertainty Requirement	COMPLIANT	-

Requirement for SRM is that Uncertainty should be 0.3% vol absolute or 6% relative whichever is the lower, on a dry gas basis. Source, EN 14789.

VERSION HISTORY

Version Number	Record of changes made within this version of the document
V1	The original document issued to the client