

This statement does not stop us from taking additional enforcement action if further relevant information comes to light or offences continue.

4. Details of our assessment

On Wednesday the 18th of February I arrived at Tredegar Park, Newport to carry out an inspection on their Sewage Treatment Plant. Permitted discharge of secondary treated sewage effluent containing no trade effluent to the River Ebbw. Permit Number AB0038601.

I met with Park Supervisor M. Rogers, who agreed to escorted me around the site. The weather was overcast and dry. My site inspection commenced at 12 pm.

Observations

I proceeded to identify the location of the Sewage Treatment Plant. Please see Fig 1,2 and 3 below.



Fig 1 Sewage Treatment Plant



Fig 2 Sewage Treatment Plant



Fig 3 Sewage Treatment Plant

Mr Rogers stated he did not have the key to the control unit, so I could not assess it during my inspection. However, the unit appeared operational, with power on and a low hum. An alarm system was also present.

I opened the first chamber of the Sewage Treatment Plant and noted a slight odour and minor solids, which are normal for the primary stage. The solids were noticeably reduced in the following treatment stage

Please see Fig 4 below.



Fig 4 First chamber of the Sewage Treatment Plant

I could not access the final chamber because the locks could not be opened, so I was unable to assess it during my inspection.

I continued to check the discharge location point at National Grid Reference ST 29340

86050. I can confirm this is accurate as stipulated by the Permit. Please see Fig 5 below.



Fig 5 National Grid Reference of Discharge Point

There was no discharge during my inspection, and the outfall plinth showed no signs of oil or grease. It was in good condition and remained accessible. Please see Fig 6 below.



Newport Council's Parks & Outdoor Recreation Development & Improvement Officer, B. Light, arrived on site. We had previously corresponded by email, and he had recently sent me an engineer's report from TT Pumps regarding the Sewage Treatment Plant. The TT Pumps report confirmed the plant is in good working order. A few maintenance tasks were identified and are being arranged, but none affect the plant's operational status.

This concluded my inspection. I left site at 12.30pm

Breaches of permit condition: ·

No breaches observed.

Other advisory Comments:

Please ensure that Park staff have access to keys or lock combinations at all times.

Action required by date specified:

- Provide the documented maintenance programme for the site including engineers report. (Action already completed)

Contact details:

If you have any queries regarding this CAR form or to provide an update on any actions above, please contact me using the following details:

Gavin Summerhill (Environment Officer)

gavin.summerhill@cyfoethnaturiolcymru.gov.uk

If we do not receive the information requested within specified deadline and have not been informed as to why there is a delay then we may serve a Regulation 60 Notice requiring the information under Environmental Permitting (England and Wales) Regulations 2016.

If you have any queries about this report, or to discuss completion of any actions, please contact the NRW Officer named above.

Important information

Legal status of this report

Your permit is issued to you under the Environmental Permitting Regulations. You have a responsibility to comply with the conditions of your permit and prevent pollution/harm to the environment. You must also ensure that you comply with any other relevant legislation that may apply to your site's operations.

This report explains the findings of our assessment and any action you are required to take. We categorise non-compliance using our guidance for assessing non-compliance at regulated sites.

When we find potential non-compliance/s we will normally give you advice on how to maintain compliance.

To correct non-compliance, we may:

- require you to take specific actions
- issue a notice
- review the conditions of your permit.

Any advice and guidance we give will be without prejudice to any other enforcement response that we consider may be required.

Assessment results and non-compliance categories (used in section 1):

Assessment result	Description
Assessed (A)	Assessed or assessed in part, no evidence of non-compliance found
Action only (X)	Action required for the permit condition assessed to avoid non-compliance. No non-compliance scored at this time
Ongoing (O)	Ongoing non-compliance, not scored

Non-compliance category	Description
C1 Major	Potential to have a major, serious, persistent and/or extensive impact or effect on the environment, people and/or property
C2 Significant	Potential to have a significant impact or effect on the environment, people and/or property
C3 Minor	Potential to have a minor or minimal impact or effect on the environment, people and/or property
C4 No environmental impact	Non-compliance at a regulated site that cannot foreseeably have any impact on the environment, people and/or property

Full list of water quality action criteria (used in section 1 and 2):**WQ A: Management**

- WQ-A1 General management

WQ B: Operations

- WQ-B1 Permitted activities
- WQ-B2 The site
- WQ-B3 Operating techniques
- WQ-B4 Improvement programme
- WQ-B5 Pre-operational conditions

WQ C: Emissions and monitoring

- WQ-C1 Emissions to water
- WQ-C2 Emissions to land
- WQ-C3 Emissions of substances not controlled by emission limits
- WQ-C4 Monitoring
- WQ-C5 Installation of monitoring boreholes

WQ D: Information

- WQ-D1 Records
- WQ-D2 Reporting
- WQ-D3 Notifications

Enforcement response

Any non-compliance with a permit condition is an offence and we may take legal action against you. Action we take can include prosecution, serving a notice on you and/or suspension or revocation of your permit. See our Enforcement and Sanctions Guidance for further information.

Data protection notice

You should make sure that anyone named in this report knows that the information it contains will be processed by Natural Resources Wales to fulfil its regulatory and monitoring functions and to maintain the relevant public register(s).

We may also use and/or disclose the report in connection with:

- offering or providing you with our literature or services relating to environmental matters
- consulting with the public, public bodies and other organisations (e.g. Health and Safety Executive, local authorities) on environmental issues
- carrying out statistical analysis, research and development on environmental issues
- providing public register information to enquirers
- investigating possible breaches of environmental law
- assessing customer service satisfaction and improving our service
- Freedom of Information Act or Environmental Information Regulations requests.

We may also pass it on to our agents or representatives to do these things on our behalf.

Disclosure of information – this report will be available to view on-line

If you think this report contains commercially confidential information that should not be placed on our public register, you must contact your local Natural Resources Wales office within **fifteen working days** of receiving this report, using the contact details in the accompanying email or letter. You must give a full explanation of why it should not be added to our public register, including specifying which information is commercially confidential. We will assess your request and respond to you within twenty working days to let you know if we agree to your request.

Disputing the Content of this Compliance Assessment Report Form

If you disagree with the content of this Compliance Assessment Report form, you should submit your concerns, in writing, to the regulating officer who issued it within **15 working days** of its issue. This will be treated as a **Stage 1 review**.

If you are not satisfied with the outcome of the stage 1 review, you may request a **Stage 2 appeal**. This request must be submitted **within 21 working days** of receiving the response from the stage 1 review.

Further details on our review and appeal process are available at: [Natural Resources Wales / Appeal a regulatory decision from Natural Resources Wales](#)

Concerns Not Related to the Content of this Compliance Assessment Report Form

If your concerns do not relate to the content of the Compliance Assessment Report form, you should first attempt to resolve the issue with the regulating officer or their line manager.

If the issue remains unresolved, please contact our **Customer Contact Team**:

- **Telephone:** 0300 065 3000 (Monday to Friday, 09:00–17:00)
- **Email:** enquiries@naturalresourceswales.gov.uk

They will provide details on how to escalate your concerns through our **Complaints and Commendations procedure**.

If you are dissatisfied with our response, you may contact the **Public Services Ombudsman for Wales**:

- **Telephone:** 0300 790 0203
- **Email:** ask@ombudsman.wales

Welsh Language Standards

We are committed to establishing Natural Resources Wales as a naturally bilingual organisation. We will provide compliance reports in your preferred language.