



MCERTS - EDM Inspection Report

Henllan (South) WwTW

02 October 2025

Report No. CFS/ 19255 v1





Site Information



Site Name:	Henllan (South) WwTW	
Consent/Permit Holder:	Dŵr Cymru Welsh Water	
Site Address:	Off B4334 Henllan Ceredigion SA44 5TE	
Site Contact:	Statutory & Regulatory Maintenance Manager	
Contact Phone Number:	mcerts@dwrwymru.com	
Site Ref or Postcode:	50634	
Grid Ref (Sensor):	SN 35425 40255	
Consent/Permit No:	BN0013701	
Location of EDM Sensor:	Last in line overflow	
Number of EDMs:	2	
Instrument Type:	Type A (non contact) - R	
Instrument/Device(s):	Vega Vegamet 862 with C 22	
Level Meter Serial Number:	69625544	
Sensor Serial Number:	Main - 68858868 Backup - 68858870	
Date of Inspection:	02/10/2025	
Inspector:	Tom Green - MI 25 036	
Inspection Report No:	CFS/ 19255 v1	
Survey Pack:	H	* Kit Inventory and calibration data recorded on central QMS database
Uncertainty:	± 2.1mm (Main Sensor) ± 2.1mm (Backup Sensor)	PASS PASS
Site Compliance:	Following a site inspection, the measurement system was found to meet the requirements of the Environment Agency <i>MCERTS: requirements for installing and using event duration monitors - MCERTS Performance Standard.</i> Published 28th August 2024	

issued

Site Details

Site Description
Henllan (South) WwTW is a sewage treatment works with RBC treatment (see process diagram).
Location of Event Monitor(s)
The EDM is located above the Dual sided storm weirs
Overflow Point(s) Requiring Event Monitoring
Last in line overflow (See Process Diagram.)
Verification / Calibration
The sensor was mounted on a rigid bracket with a removable datum plate to reference the sensor height relative to the hydraulic datum. The reference height of the datum plate has been set accurately and recorded.
Site Maintenance Arrangements, Evidence and Suitability
A routine maintenance schedule has not been confirmed but is required as part of the consent holders Quality Management System, as audited by CSA. The level measurement system was found to be in a satisfactory condition at the time of the Inspection.
MCERTS Approved Product
The installed meter has a valid MCERTS Approved product certificate. Certificate number: CSA MC210360/01
System Observed in Operation
The EDM was not observed in a storm condition during the inspection. However, there is no evidence to suggest that the system would not be suitable, during a storm event.
Indicated Discharge Status
The indicated discharge status can be observed on site by: A secondary display/indicator.
Telemetry Arrangements
The Event Monitor data is collected on the SCADA system. The data is transmitted using an analogue 4/20mA signal
Inspector's Judgements or Comments About the Installation
V1 report issued with the following amendments: On/Off spill points adjusted. Telemetry commissioned 18/12/2025



MCERTS EDM Location



MCERTS EDM Main Sensor (Top) & Back Up (Bottom)



MCERTS EDM Display



Storm Overflow Weir

	Device name VEGAMET 862 Serial number 69625544
Meas. loop 1 Primary EDM	319mm Scaled
Meas. loop 2 Backup EDM	375.78mm Sensor value
	OK

Distance A (max. adjustment)
0 mm

Distance B (min. adjustment)
694 mm

Adjustment values of the meas. loop 2

Max. adjustment in percent
100.00 %

Sensor value A
2.00 mm

Min. adjustment in percent
0.00 %

Sensor value B
694.00 mm

 Device name VEGAPULS C 22 Serial number 68858868	Device name VEGAPULS C 22 Serial number 68858870
46.02 % Percent	46.02 % Lin. percent
319 mm Scaled	319 mm Scaled
OK	OK

Meter & Sensor Details

%

Scaling variable
Height


Scaling unit
mm

Scaling format
#####

Scaling 100 %
694 mm


Scaling 0 %
0 mm

Empty Distance & Scaling



Site Name	Henllan (South) WwTW		EDM Level Meter	Vega Vegamet 862 with C 22	Location	Storm Overflow (Main Sensor)
Event Duration Monitor	Date	02 October 2025				
Total Uncertainty	2.1 mm					

DUAL SIDED STORM WEIRS



Depth Readings	
319	319
319	319
319	319
319	319
319	319
VAR +1	1.00

Measured Temp.	0 °C
Instrument Temp.	0 °C
Error	0.0 mm
Datum Level	319 mm
Instrument Level	319 mm
Error	0 mm
Sensor height above spill	529 mm
Accuracy	0.09 %
Error	0.48 mm
Estimate of wave height	4 mm
Repeatability^{#1}	0.4 mm
Total Uncertainty	2.1 mm

Sensor Height	700 mm
Base Level	1237 mm (Staff Reading)
Lowest Weir Level	1066 mm (Staff Reading)
Spill Height	171 mm

Analogue Output	0 mm - 4mA
	694 mm - 20mA
Storm Event Activated	171 mm - 7.94 mA
Event De-Activated	170 mm - 7.92 mA

Bracket Level	518	Staff Reading
Bobbin	White	(400 mm)
Datum Reference Height	319	mm

Compliance Check	
Uncertainty < ±5mm	OK
Logging Intervals <2min	OK
Sensor location upstream from weir	Not applicable
Sensor distance to weir	OK
Sensor securely mounted	OK
Sensor Height	OK
Sunshade Required	No
Sunshade Installed	No
Sensor in channel centre	OK


Notes: #1 Repeatability uses IS4359 14.5.1
Total Uncertainty uses Error items in 'bold'

V1 report issued with the following

All dimensions in mm, unless stated otherwise.

Site Name	Henllan (South) WwTW		EDM Level Meter	Vega Vegamet 862 with C 22	Location	Storm Overflow (Backup Sensor)
Event Duration Monitor	Date	02 October 2025				
Total Uncertainty	2.1 mm					

DUAL SIDED STORM WEIRS



Depth Readings	
319	319
319	319
319	319
319	319
319	319
VAR +1	1.00

Measured Temp.	0 °C
Instrument Temp.	0 °C
Error	0.0 mm
Datum Level	319 mm
Instrument Level	319 mm
Error	0 mm
Sensor height above spill	529 mm
Accuracy	0.09 %
Error	0.48 mm
Estimate of wave height	4 mm
Repeatability^{#1}	0.4 mm
Total Uncertainty	2.1 mm

Sensor Height	700 mm
Base Level	1237 mm (Staff Reading)
Lowest Weir Level	1066 mm (Staff Reading)
Spill Height	171 mm

Analogue Output	0 mm - 4mA
	694 mm - 20mA
Storm Event Activated	171 mm - 7.94 mA
Event De-Activated	170 mm - 7.92 mA

Bracket Level	518	Staff Reading
Bobbin	White	(400 mm)
Datum Reference Height	319	mm

Compliance Check	
Uncertainty < ±5mm	OK
Logging Intervals <2min	OK
Sensor location upstream from weir	Not applicable
Sensor distance to weir	OK
Sensor securely mounted	OK
Sensor Height	OK
Sunshade Required	No
Sunshade Installed	No
Sensor in channel centre	OK

Notes: #1 Repeatability uses IS4359 14.5.1
Total Uncertainty uses Error items in 'bold'

All dimensions in mm, unless stated otherwise.

V1 report issued with the following

The drawings and the contents of this report have been prepared for the exclusive use and benefit of the named recipient. Unless we provide prior written consent, no part of this report should be reproduced distributed or communicated to any third party except for the purposes of obtaining MCERTS certification directly from CSA. We do not accept any liability for any inaccuracy arising from any drawings contained in this report which are provided for the sole purpose of identification in connection with the contents of this report.