

Schedule 5 - Notification

These pages outline the information that the operator must provide.

Units of measurement used in information supplied under Part A and B requirements shall be appropriate to the circumstances of the emission. Where appropriate, a comparison should be made of actual emissions and authorised emission limits.

If any information is considered commercially confidential, it should be separated from non-confidential information, supplied on a separate sheet and accompanied by an application for commercial confidentiality under the provisions of the EP Regulations.

Part A

Permit Number	EPR/BX9471IU
Name of operator	TATA Steel Trostre
Location of Facility	Trostre Llanelli Carmarthenshire SA14 9SD
Time and date of the detection	02/03/2026

(a) Notification requirements for any activity that gives rise to an incident or accident which significantly affects or may significantly affect the environment	
To be notified within 24 hours	
Date and time of the event	02/03/2026
Reference or description of the location of the event	Effluent flume "Kline junction" prior to where "Kline" section joins the main flume south of the works. OS maps grid reference: SS 52785 99163
Description of where any release into the environment took place	Ground to the South of flume.
Substances(s) potentially released	Plant effluent tested as: PH: 9.2 Total Chrome: 1.99 PPM COD: 898 PPM Iron: 99.4 PPM
Best estimate of the quantity or rate of release of substances	Unknown at time of writing
Measures taken, or intended to be taken, to stop any emission	Sandbags used to initially stop flow. Further Investigation and repair of the flume to be carried out.

Description of the failure or accident.	Visible flow into internal wall of flume.
-----------------------------------------	-------------------------------------------

(b) Notification requirements for the breach of a permit condition	
To be notified within 24 hours	
Emission point reference/ source	

Permit Number
EPR/BX9471IU

Page 1

14/09/2018


Parameter(s)	
Limit	
Measured value and uncertainty	
Date and time of monitoring	
Measures taken, or intended to be taken, to stop the emission	

Time periods for notification following detection of a breach of a limit	
Parameter	Notification period

(c) In the event of a breach of permit condition which poses an immediate danger to human health or threatens to cause an immediate significant adverse effect on the environment:	
To be notified within 24 hours	
Description of where the effect on the environment was detected	
Substances(s) detected	
Concentrations of substances detected	
Date of monitoring/sampling	

Part B - to be submitted as soon as practicable

Any more accurate information on the matters for notification under Part A.	From the routine visual inspection of the flume, a small body of standing liquid was noticed adjacent to the external wall of the flume. Upon further inspection of the flume internally, disturbance in the flow within flume was identified, showing signs of a leak in the flume wall. Thermal drone survey carried on the 23/01/26 showed no indication of a leak present in this location.
Measures taken, or intended to be taken, to prevent a recurrence of the incident	Further investigation and repair to flume to be carried out. Thermal imaging survey to be repeated to ensure the repair has been successful.
Measures taken, or intended to be taken, to rectify, limit or prevent any pollution of the environment which has been or may be caused by the emission	Repairs carried out, groundwater and soil sampling to be carried out to understand if any further actions are required.
The dates of any unauthorised emissions from the facility in the preceding 24 months.	06/02/2025

Name*	JAMES DAVIES
Post	WORKS MANAGER
Signature	
Date	02/03/2026

Permit Number
EPR/BX9471IU

Page 2

14/09/2018