

This form covers all DCWW operations environmental pollution and MCerts Flow meter issues.

The Originator must mark either box A or B and then Email the form as detailed below for onward transmission to the EA / NRW.

Unplanned Event

Planned Event

To the ORC at Linea for onward transmission to EA / Natural Resources Wales

E-mail: @dwrcymru.com

Telephone:

**To Be Completed By DCWW:**

Name:	<input type="text"/>	Job Role:	Ops Supervisor
Date:	18/10/2024	Time:	20:15
Office:	<input type="text"/>	Phone:	<input type="text"/>
Fax:	<input type="text"/>	E mail:	<input type="text"/> @dwrcymru.com

**Details Of Notification:**

Asset Type (WwTW, Pstn, CSO, EO, service reservoir, trunk sewer, WTW, storm treatment etc)	SPS	Permit No:	BM0004402
Location:	Ewenny No.2	Grid Ref:	SS9089077498
		Watercourse:	Afon Ewenni
Date of Occurrence:	18/10/2024 20:00:00	Expected Duration:	6 Hours

Photographic Evidence	<input type="text"/>				
Brief Outline:	Pumps not pumping permitted flow				
Remedial Action:	Maintenance organising to lift pumps, Tanker also on the way to drop the well level .				
Actions Taken to Reduce Future Risks:	Ops monitoring site				
Environmental Impact:	None Expected				
Potential Compliance / Permit Consequence – relevant include all	MCERTs	Final Effluent	FPF (Flow)	EDM	Pollution
	<input type="text"/>	<input type="text"/>	<input type="text"/>	Yes	<input type="text"/>
Updates:	To follow				

DCWW Ref:	181024200	Message No:	<input type="text"/>	Update / Final:	Initial
ORC Analyst:	<input type="text"/>	Date:	18/10/2024	Time:	20:15