

SOURCE OF SEWAGE	NO.	HL/DAY	TOTAL	OL/DAY	TOTAL	NITROGEN	
Domestic dwelling/Residential building	1	150	150	60	60	8	8
Hotel guests	100	250	25000	94	9400	10	1000
Prestige hotel		300	0	105	0	12	0
Conference suite guests		350	0	150	0	15	0
Old people/care home		350	0	110	0	13	0
Nursing/convalescent home		350	0	110	0	13	0
Hospitals		450	0	140	0		Assess
Day staff in above establishments	20	90	1800	38	760	5	100
Day schools-not including canteen		50	0	25	0	5	0
Day schools-including canteen		90	0	38	0	5	0
Industrial unit/office without canteen		50	0	25	0	5	0
Industrial unit/office with canteen		100	0	38	0	5	0
Bar guests	500	12	6000	15	7500	5	2500
Function Room - staff & guests		15	0	19	0	2.5	0
Fast food type café		12	0	15	0	4	0
Restaurants and canteens without WDU		12	0	15	0	2.5	0
Haute cuisine' restaurants		30	0	38	0	4	0
Golf Club - staff & players		20	0	19	0	5	0
Sports centres - staff & clients	30	50	1500	19	570	4	120
Public toilets @ parks, picnic sites etc		10	0	19	0	4	0
Holiday camps		227	0	94	0	10	0
Little chef/Happy eater type meals		12	0	12	0	4	0
Little chef/Happy eater type staff		90	0	38	0	5	0
Petrol station wc visitor		10	0	12	0	2.5	0
Travel lodge guests		80	0	50	0	6	0
Residential caravans		150	0	60	0	8	0
Touring vans with site toilet block	50	100	5000	44	2200	8	400
Tenting with site toilet block	250	75	18750	44	11000	8	2000
TOTALS			58200		31490		6128
DOMESTIC POPULATION EQUIVALENT			388		524.8333		766