



Sample Test Report

Yaidon, Penrhos
Kington
Herefordshire
HR5 3LH
01544 230364

Client **Baskerville Hall Hotel, HR3 5LE**

The results reported relate to samples received by Mayglöthling Waste Ltd. The results given below are reasonable estimates and are not within the Scope of UKAS or MCERTS accreditation.

Sample Details

Sample Date	Sample Time	Weather Conditions	Sample Point	Sample Observations
25/07/2025	-	-	Final Effluent	Clear straw coloured liquid with little odour

Sample Ident	Property id	Address	Sample Test Date	pH	COD	Turbidity	Ammonia	BOD	Suspended Solids
					mg/l	JTU	mg/l	mg/l	mg/l
25	-	Baskerville Hall Hotel, HR3 5LE	28/07/2025	-	12	10	22.2	4	10

--

Notes	Within reasonable range
-------	--------------------------------

Determinand	Test Method
Ammonia	By Nesler Photometry
COD	By ISO15705 / Photometry
BOD	By estimation based on COD
Suspended Solids	By Turbidity assessment