

Water Resources Act 1991
as amended by the Environment Act 1995
Consent to Discharge
Certificate of Holder



ENVIRONMENT
AGENCY

Part A

To: DWR CYMRU CYFYNGEDIG
CONSENTS REGULATION OFFICER
PLAS-Y-FFYNNON
CAMBRIAN WAY
BRECON LD3 7HP

The Environment Agency ("the Agency") hereby confirm that the above named person is a/the registered holder of consent CG0054601

Nature of Discharge(s); TRADE EFF/POTABLE WATER/CONTINUOUS
at PENYCEFN RESERVOIR DOLGELLAU

Note: This certificate should be kept with the consent document for future reference. If you transfer responsibility for the discharge to somebody else you must pass the consent to them and tell the Agency within 21 days. **Responsibility for the consent cannot be disclaimed by the holder but the registration of holder may be transferred to a successor.** To do this please complete the form below, then tear it off and return it to the address shown. If you fail to transfer the consent, even though you are no longer on the site, you may still be liable for prosecution for pollution. If you transfer the consent but do not tell us, you will be committing an offence. In case of any queries please contact your local Environment Agency office.

Part B Please complete in block capitals or type.

To:

Water Resources Act 1991: Notice of transfer of consent to discharge

Consent:

Name:

Address:

I/We* hereby serve notice on the Agency that I/we* am/are* no longer a/the* Holder of the above consent which will be/was* transferred to: * delete as appropriate

Name(s) of new holder(s):

Address:

Post Code:

Date of Transfer to new Holder(s):

Signed:

Dated:


Name (block capitals):

Position:

(to be completed when signing
on behalf of corporate bodies)







EG00546-01

79 85 / 1872

IPC/IC/167

C.203/11 and ME/3/10

3rd June, 1965.

Dear Sir,

Rivers (Prevention of Pollution) Acts 1951 to 1961
Penycoed Water Service Area

With reference to your application of 14th April 1965, the Gwynedd River Authority, in pursuance of their powers under the above Acts, hereby consent to the bringing into use of a new outlet for the discharge of reservoir and filter washwaters and the making of new discharges of reservoir and filter washwaters into that stream in Coed Penycoed, Dolgellau in accordance with the plans numbered 167A/20 and 167A/10 and subject to the following conditions:-

1. The volume of the discharge of reservoir water, to be made about once a year, shall not exceed 10,000 gallons and the rate of discharge shall not exceed 1,500 gallons per hour.
2. The volume of the discharge of filter washwater, to be made about twice a week, shall not exceed 30,000 gallons at any one time, and the rate of discharge shall not exceed 4,000 gallons per hour.
3. The pH value of the discharges, both of reservoir and filter washwaters, shall be of the order 7.0 to 9.0.
4. The chlorine content of the discharges, both of reservoir and filter washwaters, shall not exceed 0.5 p.p.m.
5. The suspended solids content of the discharges, both of reservoirs and filter washwaters, shall not exceed 30 p.p.m.

The terms of this consent will not, without the consent in writing of the person to whom this consent is given (or his successor), be altered before the expiration of the period ending with the 1st day of July 1967.

6. Sampling facilities shall be provided so as to enable the Authority's Sampling Officers to sample the discharges prior to admixture with the waters of the receiving stream.

R

Yours faithfully,

Muller

Chief of the Authority

The Merioneth Water Board,
Glanwerydd,
High Street,
BARMOUTH,
Merioneth.

Copy sent for information to:-
Messrs. G.D.C. Braine and Partners,
25/27, St. Mary Street,
Cardiff.

