

## Part A

Permit Number	<b>EA/EPRYP3937SH/V007</b>
Name of Operator	Mekatek Limited
Location of Installation	Amex Park, Johnstown, Carmarthen, SA31 3NF
Location of the emission	W1
Time and date of the emission	February 2026 (spot sample)

Substance(s) emitted	Media <i>eg air, groundwater</i>	Best estimate of the quantity or the rate of emission	Time during which the emission took place
BOD	Source emissions to water	82 mg/l of BOD identified within the monthly spot sample.	27/02/2026

Measures taken, or intended to be taken, to stop the emission	<p>Additional samples containers have been ordered and additional 'ad-hoc' sample to be sent for analysis outside of the standard monitoring programme for the site</p> <p>26.04.2026 – Analysis results of check sample sent on identification of exceedance returned a value of 0.1mg/l.</p> <p>The standard monitoring spot sample taken on 31<sup>st</sup> March 2026 returned a value of 6mg/l.</p> <p>Both of these results are well within the consent limits.</p> <p>There was no evidence of shock loading, temperature is considered a potential cause for the exceedance on the basis of eliminating other potential causes.</p>
---	---

## Part B

Any more accurate information on the matters for notification under Part A.	
Measures taken, or intended to be taken, to prevent a recurrence of the incident	
Measures taken, or intended to be taken, to rectify, limit or prevent any pollution of the environment or harm which has been or may be caused by the emission	Additional work is being considered following exceedances in mercury and TOC in 2025. The operator will add BOD to the project list for consideration in this

	work.
The dates of any unauthorised emissions from the installation in the preceding 24 months.	December 2025 July 2025 May 2025 November 2024 October 2024

Name	Dan Lewis
Post	Technical and Compliance Director
Signature	
Date	21/03/2026