

CONSENT NO.

AN0379201



ASiantaeth yr
Amgylchedd Cymru
Environment
Agency Wales

WATER RESOURCES ACT 1991

SECTION 88 - SCHEDULE 10

(AS AMENDED BY THE ENVIRONMENT ACT 1995)

CONSENT TO DISCHARGE

TO: Environment Quality Scientist
Dŵr Cymru Cyfyngedig
Pentwyn Road
Nelson
Treharris
CF46 6LY

In pursuance of an application by the consent holder for variation of consent, the **ENVIRONMENT AGENCY** ("The Agency") in pursuance of its powers under the Water Resources Act 1991 **HEREBY CONSENTS** to the making of a discharge **OF SEWAGE EFFLUENT**, as follows:

Settled Storm Sewage

FROM: Goytre Sewage Treatment Works.

AT: Nantyberry, Abergavenny, NP7 9DW.

TO: The River Usk.

HEREAFTER SUBJECT TO the conditions set out in the following schedule(s):


Settled Storm Sewage Schedule No. AN037920101

Subject to the provisions of Paragraphs 7 and 8 of Schedule 10 of the Water Resources Act 1991, no notice shall be served by the Agency, which alters the effect of this consent, without the agreement in writing of the consent holder, during a period of 4 years from the date this consent is issued.

This consent is issued on the 30th day of MARCH 2005
and takes effect on the 31st day of March 2005.

Signed 
Team Leader -Regulatory Water Quality





CONSENT NO.	AN0379201
SCHEDULE NO.	AN037920101
DATE ISSUED	30/3/05



ASiantaeth Yr
Amgylchedd Cymru
Environment
Agency Wales

CONDITIONS OF CONSENT TO DISCHARGE

Settled Storm Sewage ("the Discharge")

FROM: Goytre Sewage Treatment Works.

NATURE

1. The Discharge shall consist solely of settled storm sewage.

LOCATION

2. The Discharge shall be made in the manner and at the place specified as:
 - (a) discharging via a 225mm diameter pipe;
 - (b) discharging to The River Usk;
 - (c) at National Grid Reference SO 34455 05405;
 - (d) shown marked 'Consent Point' on Plan AN0379201 attached as Annex 2.

SAMPLE POINT

3. An appropriately labelled sample point shall be provided and maintained at National Grid Reference SO 33044 05775, as shown marked 'Sample Point' on Plan AN0379201/S, so that a representative sample of the Discharge may be obtained. The consent holder shall ensure that all constituents of the Discharge pass through the said sampling point at all times and in any legal proceedings it shall, for the purposes of Section 10 of the Rivers (Prevention of Pollution) Act 1961, be presumed, until the contrary is shown that any sample of the Discharge taken at the said sampling point is a sample of what was discharging into controlled waters.

VOLUME

4. The Discharge shall occur when and only for as long as, the storm tanks are full. The discharge of storm sewage to the storm tank shall only occur when the rate of flow at the storm sewage separating weir is in excess of 11.3 litres per second due to rainfall and/or snowmelt. The storm tanks shall be emptied and their contents returned for full treatment as soon as practicable after cessation of the overflow to the storm tanks.
5. The capacity of the storm tanks shall be at least 126 cubic metres.





CONSENT NO.	AN0379201
SCHEDULE NO.	AN037920101



ASIANTAETH YR
AMGYLCHEDD CYMRU
ENVIRONMENT
AGENCY WALES

COMPOSITION

6. (a) The Discharge shall have passed, without prior comminution or maceration, through a screening device having apertures no greater than 6 millimetres in two dimensions.
- (b) The screening device shall be maintained in an efficient operational condition.
- (c) All screenings must be removed and disposed of in a manner such as to prevent entry to the discharge.

WORKS OPERATION

7. a) The works shall be operated and the effluent shall be treated in a manner which, so far as reasonably practicable, minimises the polluting effects of the Discharge made from the works on controlled waters.
- b) This condition does not require any alteration of the works or a change in the type of treatment used.

RECORDING AND REPORTING

8. (a) The consent holder shall establish and operate a documented maintenance programme and record all non-routine actions undertaken that may have adversely affected the operation of the storm tanks. Copies of the programme shall be made available for inspection by the Agency's officers at all reasonable times.
- (b) On request the consent holder shall supply the Agency with a written report on the maintenance and all non-routine actions that may have adversely affected the operation of the storm tanks.
9. The consent holder shall notify the Agency in writing if any known or planned introduction or material change in respect of discharges from trade premises to the sewerage system occurs, that may increase or introduce into the effluent any "dangerous substance" (set out in Annex 2 to this notice as updated from time to time and notified to the consent holder in writing), and any other substance considered by the consent holder as having or likely to have a significant effect on the receiving waters.





CONSENT NO.	AN0379201
SCHEDULE NO.	AN037920101




ASiantaeth Yr
Amgylchedd Cymru
Environment
Agency Wales

SUBSTANTIAL CHANGE

10. A discharge shall not be made from the works if it would cause a significant increase in the polluting effects of the Discharge on controlled waters as a result of a new or altered discharge of trade effluent into the works.
11. A discharge of trade effluent into the works is new if -
- (a) it is made by the sewerage undertaker and is of a kind not made into the works by the undertaker immediately before the date of effect of this variation; or
 - (b) it is made by a third party and the discharge is authorised on or after that date.
12. A discharge of trade effluent into the works is altered if -
- (a) it is made by the sewerage undertaker and its composition or quantity changes significantly on or after the date of effect of this variation; or
 - (b) it is made by a third party and the alteration of the discharge is authorised on or after that date.
13. An increase in the polluting effects of the Discharge on controlled waters is not significant for the purposes of this condition if it relates to any characteristic of the Discharge which is specifically regulated by conditions in this consent but it may be significant if it is caused by a change in some other characteristic of the Discharge.
14. For the purposes of this condition "trade effluent" means -
- (a) any discharge by the sewerage undertaker other than
 - (i) domestic sewage from premises connected directly or indirectly to the works; or
 - (ii) surface water run-off;
 - (b) any discharge by a third party which is authorised under Chapter III of Part IV of the Water Industry Act 1991 or which is accepted as a result of a contract with the sewerage undertaker.





CONSENT NO.	AN0379201
SCHEDULE NO.	AN037920101



ASiantaeth Yr
Amgylchedd Cymru
ENVIRONMENT
AGENCY WALES

UNAUTHORISED DISCHARGES

15. A Discharge made from the works shall not contain any poisonous, noxious or polluting matter or solid waste matter which is attributable to any unauthorised discharge into the works.
- (a) A Discharge into the works is unauthorised if it is made by a third party and either there is no obligation to receive it or conditions subject to which there is an obligation to receive it are not observed.
- (b) Nothing in this, or any other, condition of this consent prevents anyone from relying on any defence available to them under Section 87 of the Water Resources Act 1991.

START DATE

16. There shall be no discharge under the terms of this consent until the 31st March 2005 or the start of commissioning of the settled storm overflow whichever is the sooner.





ANNEX 1




ASiantaeth Yr
Amgylchedd Cymru
ENVIRONMENT
AGENCY WALES

- | | |
|--|------------------------------|
| 1. Mercury and its compounds | 2. Cadmium and its compounds |
| 3. Hexachlorocyclohexane (lindane and related compounds) | |
| 4. Carbon tetrachloride | |
| 5. DDT (the isomers of 1,1,1-trichloro-2,2 bis{p-chlorophenyl} ethane) | |
| 6. Pentachlorophenol (PCP) | 7. Aldrin |
| 8. Dieldrin | 9. Endrin |
| 10. Isodrin | 11. Hexachlorobenzene (HCB) |
| 12. Hexachlorobutadiene (HCBd) | 13. Chloroform |
| 14. Polychlorinated biphenyls | 15. Dichlorvos |
| 16. 1,2-Dichloroethane | 17. Trichlorobenzene |
| 18. Atrazine | 19. Simazine |
| 20. Tributyltin compounds | 21. Triphenyltin compounds |
| 22. Trifluralin | 23. Fenitrothion |
| 24. Azinphos-methyl | 25. Malathion |
| 26. Endosulfan | 27. Lead |
| 28. Chromium | 29. Zinc |
| 30. Copper | 31. Nickel |
| 32. Arsenic | 33. *Iron |
| 34. *pH outside range 5.5 to 9.0 | 35. *Boron |
| 36. Vanadium | 37. PCSD'S |
| 38. Cyfluthrin | 39. Sulcofuron |
| 40. Flucifuron | 41. Permethrin |
| 42. 4-Chloro-3-methyl-phenol | 43. 2-Chlorophenol |
| 44. 2,4-Dichlorophenol | 45. 2,4-D (ester) |
| 46. 2,4-D (non ester) | 47. 1,1,1-Trichloroethane |
| 48. 1,1,2-Trichloroethane | 49. Bentazone |
| 50. Benzene | 51. Biphenyl |
| 52. Chloronitrotoluenes | 53. Demeton |
| 54. Dimethoate | 55. Linuron |
| 56. MCPA | 57. Mecoprop |
| 58. Mevinphos | 59. Napthalene |
| 60. Omethoate | 61. Toluene |
| 62. Triazophos | 63. Xylene |
| 64. Cyanide | 65. Azinphos-ethyl |
| 66. Fenthion | 67. Parathion |
| 68. Parathion-methyl | 69. Trichloroethylene |
| 70. Tetrachloroethylene | 71. Dioxins |
| 72. PAHs | 73. Nonyl phenol |
| 74. Nonyl phenyl ethoxylate | 75. Di-ethylhexyl phthalate |
| 76. Bisphenol-A | 77. Diazinon |
| 78. Chlorfenvinphos | 79. Chlorotoluron |
| 80. Isoproturon | 81. Diuron |
| 82. Propetamphos | 83. Flumethrin |
| 84. Amitraz | 85. High-Cis Cypermethrin |
| 86. Cyromazine | 87. Deltamethrin |
| 88. Cypermethrin | |

This list is applicable as at 1 December 1998 and will be updated as and when changes to the relevant legislative requirements occur.

*Notification to the Agency by the Consent holder is only required in respect of changes to trade effluents likely to cause significant changes to the pH value, and/or iron or boron concentrations, of the crude sewage.





Eich cyf/Your ref.

Ein cyf/Our ref. ACSC/CUST/SE/MS/AN0379201

Dyddiad/Date: 04 April 2005

Dwr Cymru
Pentwyn Road
Nelson
Treharris
Caerphilly
CF46 6YA



ASiantaeth Yr
Amgylchedd Cymru
Environment
Agency Wales

P/R-



Dear Dr. Kiel

WATER RESOURCES ACT 1991, SCHEDULE 10 (AS AMENDED BY THE ENVIRONMENT ACT 1995) APPLICATION FOR VARIATION OF CONSENT TO DISCHARGE SEWAGE EFFLUENT BY DWR CYMRU FROM GOYTRE STW, NANTYDERRY, ABERGAVENNY NP7 9DW (INTERMITTENT DISCHARGE). APPLICATION NO: AN0379201

Further to your application for variation, the Agency has decided that consent should be given subject to conditions under the provisions of Section 88 of the Water Resources Act 1991. I enclose the Agency's formal notice of the variations made to the conditions of the consent to discharge sewage effluent at Goytre STW, Nantyerry, Abergavenny NP7 9DW (Intermittent discharge).

Under the present Scheme of Charges for Discharges to Controlled Waters an annual charge will be made for all consents to discharge, except where the discharge is of sewage effluent of five cubic metres or less per day. This charge is based on information derived from the conditions attached to the consent to discharge. A change in conditions may therefore result in a change in annual charge, you may therefore receive a revised bill in due course.


If you are not satisfied with the new conditions of the consent you may appeal against the decision to the Secretary of State for the Environment at National Assembly for Wales at Cathays Park, Cardiff CF10 3NQ.

Please take careful note that if the holder of the consent changes, you must inform the Agency **IN WRITING** as soon as possible of the name of the new holder. This is to ensure that the rights and charges associated with the Consent are transferred to the new holder. A certificate of Holder notice will be sent to you shortly which is designed for this purpose, and should be kept safely with the Consent until required.

Asiantaeth yr Amgylchedd Cymru
Plas Yr Afon, Parc Busnes Llancirwg, Llancirwg, Caerdydd, CF3 0EY
Ffon: 029 20770088 Ffacs: 029 20798555
www.environment-agency.gov.uk

Environment Agency Wales
Rivers House, St Mellons Business Park, St Mellons, Cardiff, CF3 0EY
Tel: 029 20770088 Fax: 029 20798555
www.environment-agency.gov.uk






If you have any queries regarding the enforcement of this consent, please do not hesitate to contact John Tomala, Team Leader Environment Management, Environment Agency Wales.

Yours sincerely

GARY INIGHT
External Relations Team Leader





PIR




ASiantaeth YR
AMGYLCHEDD
ENVIRONMENT
AGENCY

WATER RESOURCES ACT 1991 (schedule 10)

(as amended by the Environment Act 1995)

Application for new consent to discharge

Intermittent Discharge

<p>Regional/Area Address:</p> <p>The Regional Finance Manager Environment Agency Welsh Region PO Box 425 St Mellons Business Park CARDIFF CF3 0LT</p>	<p><i>Official Use Only</i> Dist/Area Ref: 1303</p> <p>Application No. AN0379201 Date Received: 19/11/04. Fee Received:</p> 
--	--

Each applicant must complete the main form and may need to complete a separate annexe if appropriate. Please look through the form and read the notes carefully before you complete it. Processing of your application will be aided by full and accurate completion of all relevant sections and provisions of the necessary plans. If you have any queries regarding the form please contact the person given in the notes.

NOTE:

All information contained within this application will be made available on the public register unless there is a request to withhold any of it. Any such request should provide a full justification stating why the information needs to be withheld (see note xiii).

1 SITE ADDRESS

1.1 Address or other sufficient description of land or premises to which this application applies.

Goytre STW Nantyderry Abergavenny

Post Code:

NP7 9DW

2 DETAILS OF DISCHARGE(S)

2.1 State the nature of the discharge(s) (see note i and ii) - tick one or more boxes as appropriate:

- Sewage Effluent - volume of 5 cubic metres per day or less
- Sewage Effluent - volume greater than 5 cubic metres per day (**complete annexe 1**)
- Sewage Effluent discharged under storm or emergency conditions (**complete annexe 2**)
- Cooling Water (**complete annexe 3**)
- Trade Effluent (*including site drainage*) (**complete annexe 3**)
- Others (*please specify*)

2.2 Please state the maximum quantity it is proposed to discharge in any one day
Briefly state how this figure was calculated (see note ii).

N/A

2.3 a) Indicate proposed means of discharge - tick as appropriate and show on plan:
(for 1, 2 & 3 please state dimensions below)

- | | | | | | |
|------------|-------------------------------------|-------------|--------------------------|--|--------------------------|
| 1. Pipe | <input checked="" type="checkbox"/> | 4. Borehole | <input type="checkbox"/> | 7. Sub-Irrigation System | <input type="checkbox"/> |
| 2. Channel | <input type="checkbox"/> | 5. Well | <input type="checkbox"/> | 8. Combination of 6 & 7 | <input type="checkbox"/> |
| 3. Culvert | <input type="checkbox"/> | 6. Soakaway | <input type="checkbox"/> | 9. Other (<i>please specify below</i>) | <input type="checkbox"/> |

225 mm

b) National Grid Reference(s) of point(s) of discharge (see note iii).

S	0	3	4	4	5	5	0	5	4	0	5
---	---	---	---	---	---	---	---	---	---	---	---

(please indicate on accompanying plans)

2.4 a) The Agency will normally require adequate provision for the taking of samples of the discharge in a safe and convenient manner at any time. Please indicate the means proposed (see note iv) - tick as appropriate and show on plan:

- At the outlet At a manhole or sampling chamber

Other (*please specify*)

b) National Grid Reference(s) of sampling point(s) (if different from 2.3 b) above).

S	0	3	3	0	4	4	0	5	7	7	5
---	---	---	---	---	---	---	---	---	---	---	---

(please indicate on accompanying plans)

c) What flow measurement facilities will be provided (see note v)?
Please give details.

None

2.5 a) Type of Treatment Plant(s) to be used (*please specify make and model*) - tick as appropriate:

Septic Tank Package Sewage Treatment Works Other

b) Will the treatment process involve the use of any chemicals (eg ferric salts, polyelectrolytes). If yes please give details.

2.6 a) On what date do you anticipate the discharge will commence?

b) If you require the consent for a limited time period please give dates; from:

to:

c) If the discharge is not continuous please detail the period/circumstances when it will occur.

The spill will occur when the flow to the works has exceeded the FFT of 11.3 l/s for a period of time sufficient for the storm tanks to fill. (3.09 hours at FFT).

2.7 a) Are there any existing consents for discharges from the premises (see note vi)?

If yes, please give the reference numbers *(Any further information should be given in Section 5.3).*

AC0116401

b) Has any person had a Prohibition Notice serviced on them in respect of this site?

If yes, please give the reference number.

3 SITE DETAILS

3.1 Please give the name of the relevant Planning Authority.

Monmouthshire

3.2 Please give details of the premises - tick as appropriate:

- | | | | |
|--|--------------------------|-----------------------------------|-------------------------------------|
| 1. Single Dwelling | <input type="checkbox"/> | 6. Fish Farm | <input type="checkbox"/> |
| 2. Multiple Dwellings | <input type="checkbox"/> | 7. Mineral Workings | <input type="checkbox"/> |
| 3. Industrial Premises | <input type="checkbox"/> | 8. Water Services plc STW | <input checked="" type="checkbox"/> |
| 4. Vehicle Parking Area | <input type="checkbox"/> | 9. Water Supply | <input type="checkbox"/> |
| 5. Commercial Premises <i>(please specify)</i> | <input type="checkbox"/> | 10. Other <i>(please specify)</i> | <input type="checkbox"/> |

3.3 Please indicate source of the water supply - tick as appropriate: **Not Applicable**

- | | | | |
|--|--------------------------|---|--------------------------|
| 1. Well | <input type="checkbox"/> | 5. River (please give name below) | <input type="checkbox"/> |
| 2. Borehole | <input type="checkbox"/> | 6. Estuary (please give name below) | <input type="checkbox"/> |
| 3. Precipitation (eg rain or snow) | <input type="checkbox"/> | 7. Coastal Water (please give name below) | <input type="checkbox"/> |
| 4. Mains (please state water supply company) | <input type="checkbox"/> | <input type="text"/> | |

4 DETAILS OF RECEIVING ENVIRONMENT

4.1 Receiving Medium - tick the category(s) to which the proposed discharge(s) is(are) to be made:

- | | | | |
|--|-------------------------------------|---------------------------------|--------------------------|
| 1. Estuarial Water (tidal river or stream) | <input type="checkbox"/> | 5. Into Land | <input type="checkbox"/> |
| 2. River or Stream (non-tidal) | <input checked="" type="checkbox"/> | 6. Onto Land | <input type="checkbox"/> |
| 3. Canal | <input type="checkbox"/> | 7. Directly into Groundwater | <input type="checkbox"/> |
| 4. Lake, Lock or Pond | <input type="checkbox"/> | 8. Coastal Water (see note vii) | <input type="checkbox"/> |

State name of receiving water if known:

4.2 In the case of sub-irrigation systems, soakaways or boreholes: **Not Applicable**

- (a) Is any part of the system within 5 metres of the boundary of the premises?
- (b) Is any part of the system within 10 metres of a watercourse?
- (c) Is any part of the system within 50 metres of a borehole or spring?
- (d) For wells and boreholes state dimension(s) in metres.
- (e) For sub-irrigation systems, soakaway pits, wells and boreholes, state maximum depth in metres.
- (f) For boreholes, state details of lining in metres:
- (i) Depth of lining
 - (ii) Depth of perforated lining
 - (iii) Depth of unperforated lining
- (g) A percolation test must be carried out in accordance with British Standard BS6297:1983. Have the results been provided?

4.3 Is there a foul sewer available to which the discharge(s) could be made (see note viii)?

If yes, please give the reasons it is not practical to connect to it (eg distance, flow etc).

DECLARATION

I/We:

1. apply under the Water Resources Act 1991 (as amended by the Environment Act 1995) for consent to discharge, as described in this Application. "This Application" means this page, all the other pages of this form and any attached annexes, the attached plan(s), any other sheets attached, and any other written information supplied to support the application.
2. enclose the required application fee, payable to the Environmental Agency (see note x).
3. enclose 3 copies of the plan(s) and location maps with all relevant information clearly marked (see note xi).
4. will pay required advertising costs (see note xii).
5. confirm that I/we* will notify the Environment Agency of any changes in the information in this application which might be material to the continuation of the consent.
6. confirm that the information given in this application and any questions which the Environment Agency may have about it is/will* be true to the best of my/our* knowledge, information and belief and am/are* not aware of any other facts or information which might affect the granting of a consent, or conditions which might be put on it (see note xiii).
7. confirm that I/we* will pay any annual charges due should a consent be granted YES/NO*. If no please indicate who will be completing section 5.2 above (see note xiv).

(* Delete as appropriate)

SIGNED:	<i>Lewis Keel</i>	PRINT NAME:	<i>LEWIS KEEL</i>
ON BEHALF OF:	<i>DWR GIMRU CYF</i>	DATED:	<i>17/11/04</i>

CONFIDENTIALITY

I/we apply for commercial confidentiality and enclose a full written justification (see note xv).

SIGNED:	DATED:
----------------------	---------------------

PLEASE RETURN THIS FORM TO THE ADDRESS GIVEN ON THE FRONT PAGE



ANNEXE 2 SEWAGE EFFLUENT DISCHARGED IN STORM OR EMERGENCY CONDITIONS

Please complete this annexe if you are proposing to make a discharge of sewage in emergency or storm conditions (if the effluent is to contain a trade component Annex 3 should also be completed).

*Official Use Only
Application No.*

1. Site Name.

Goytre STW

2. State the type of discharge - tick as appropriate:

Storm tanks

Combined Sewer Overflow from sewerage system

Combined Sewer Overflow from pumping station

Emergency overflow from sewerage system

Emergency overflow from pumping station

Other (please specify)

3. For effluents discharging from sewage treatment works, is the storm/emergency effluent discharged via the same outlet as the treated effluent?

Yes

If no please give: a) the National Grid Reference of the treated effluent outlet.

b) the consent or application number covering the treated effluent discharge

AC0116401

If yes please give the National Grid Reference of the storm/emergency sampling point (see notes)

S O 3 3 0 4 4 0 5 7 7 5

4. For effluents discharging from combined sewer overflows, is the discharge via a dedicated pipe?

Y/N

If no please give the National Grid Reference of the overflow into the sewer.

5. Overflow settings

- a) Overflow setting to storm tanks
- b) Maximum flow to storm tanks
- c) Overflow setting to storm sewage overflow
- d) Maximum flow to storm sewage overflow

6. Storage capacity

- a) Volume of Storm tanks
- b) Retention time of storm tanks at ^{3PG+I+3E} maximum flow
- c) Storage capacity of sewer/wet well

7. Please provide full details of the design criteria that have been used to support this application.

8. Will facilities be provided to raise alarms (eg telemetry)?

If yes, please give details.

9. Will facilities be provided to prevent the discharge of gross solids?

If yes, please give details (for screens give bar spacing or aperture).

Screening to 6 mm in two directions

10. What provisions will be made to deal with:

- a) power failure (eg standby generators)?

- b) mechanical breakdown (eg standby pumps)?

- c) rising main failure?

- d) tanker access?

Notes (see also the notes on the main form):

Full details of the design criteria must be provided in order for the application to be determined. If you have any queries about what information is required please contact the person given in notes attached to the main form.



ANNEXE 4
WELSH REGION SUPPLEMENTARY INFORMATION ANNEXE

Please complete this annexe for every proposed discharge.

Official Use Only
Application No.

For all proposed discharges:

1. Site Name.

Goytre

2. Is this application being made to reinstate a lapsed Consent?

No

If so, please state the Number of the lapsed Consent:

IMPORTANT: If you are in need of advice on either part of Question 2, please contact the Agency Regional Consents Section on 01222 770088.

3. If the proposed discharge is to be made down a pipe, channel or culvert (as given in Section 2.3 of the main application form), please state the diameter (including units):

225 mm

4. Please indicate the anticipated cost of the proposed scheme, including any alternatives which may have been considered:

£500,000

5. Is there any trade effluent component in the proposed discharge?

No

If yes, please confirm here that you have completed and enclosed Annexe 3:

Tick

6. Will the proposed discharge be pumped or made under gravity? (please circle)

If pumped, please state the maximum pump rate in l/sec:

For proposed discharges of sewage in storm or emergency conditions:

7. Please confirm here that you have completed and enclosed both Annexes 1 and 2:

8. Please state: **See also Calculation number 1287-00-1002 Revision A**

Population served (head)	1640
Consumption (l/head/day) default = 180	180
Infiltration (m ³ /day)	89
Industrial effluent flow (m ³ /day)	0
Dry Weather Flow (m ³ /day)	384
Soc A (l/sec)	30
Predicted spill frequency (per annum)	Not Known

IMPORTANT NOTES FOR ALL CONSENT APPLICATIONS:

1. **Whoever signs the declaration on the main application form takes responsibility for the discharge, and will become the registered consent holder, if consent is given. In the case of a 'body corporate' (eg a public limited company ('plc'), limited, company, local authority), the 'body corporate' will be the registered consent holder, and the person with the delegated authority to sign on behalf of the 'body corporate' should give their job title.**
2. **Agents making an application on behalf of a client, must attach their clients written authority.**
3. **If the name and/or address of the applicant changes after submission of this application to the Environment Agency, the applicant must inform the Agency in writing.**