

Permit with introductory note

The Environmental Permitting (England & Wales) Regulations 2016

The First Milk Cheese Company Limited

**Haverfordwest Creamery
Pembroke Road
Merlins Bridge
Haverfordwest
Pembrokeshire
SA61 1JN**

Permit number

EPR/XP3830UR

Haverfordwest Creamery

Permit number EPR/XP3830UR

Introductory note

This introductory note does not form a part of the permit

The main features of the permit are as follows.

Haverfordwest Creamery is located in Merlins Bridge, less than 1 km south of Haverfordwest town centre. The installation covers an area of approximately six acres within a predominantly residential setting to the south of Haverfordwest. The closest residential receptors are located within 100 m of the installation boundary.

The site is within 10 km of the Pembrokeshire Marine Special Area of Conservation (SAC), West Wales Marine SAC, Cleddau Rivers SAC and Pembrokeshire Bat Sites and Bosherton Lakes SAC. The site is within 2 km of Western Cleddau River Site of Special Scientific Interest (SSSI), Gas Works Lane Section (Haverfordwest) SSSI and Milford Haven Waterway SSSI. The site is approximately 0.7 km to the south of Haverfordwest Air Quality Management Area, which is designated for annual NOx.

The key operations regulated in this permit are the processing of milk to produce cheese and whey products, the effluent treatment process and associated combustion processes. Some refrigeration activity is carried out within the installation to preserve food materials.

The main activities of cheese production include: receipt and storage of milk, which is then pasteurised; producing curds and whey by adding bacteria and rennet which coagulates the milk. The curds are then separated, cooked, compressed and cut to form cheese chips. These are then salted, compressed to form large blocks of cheese under vacuum and then cut into 20kg blocks. The cheese is then packed, stored and dispatched.

The separated whey is used to produce skimmed whey and whey cream. The whey cream is further treated by pasteurisation and ageing. The site is also authorised for the packing of butter and pasteurisation of skimmed whey. This can be concentrated to 32 to 35% suspended solids by evaporation.

There are four emission points to air, all are from combustion processes. Three emission points (A1 to A3) are from three natural gas fuelled boilers, each with a net rated thermal input of 8MW. A maximum of two boilers can operate at any one time, resulting in a maximum aggregated net rated thermal input of 16 MW. These are classed as existing Medium Combustion Plant (MCP) and excluded Specified Generators (SG) as part of an installation as defined in Chapter II of the Industrial Emissions Directive. The remaining emission point (A4) is from a natural gas fuelled Combined Heat and Power (CHP) engine with a net rated thermal input of 2.7 MW. This unit is classed as a new MCP and is also an excluded SG as part of an installation. Each boiler and the CHP engine vent via separate flues, giving rise to the four emission points. These flues are enclosed within a single stack structure and are therefore represented as a single location on the site plan.

Foul water, process condensate effluent and contaminated surface water are treated at a dedicated, on-site effluent treatment plant (ETP) which is included within this permit.

There are three emission points to surface water, two are of uncontaminated surface water run-off, one to Merlins Brook (W1) and one to a soakaway from two land drains (WL1). The remaining emission point to surface water (W2) is from the ETP into the Western Cleddau river via a pipeline.

To offset the nutrient input from the W2 emission point into a designated waterway (Cleddau Rivers SAC & Pembrokeshire Marine SAC), the operator has implemented a scheme which delivers nutrient efficiency savings at a group of dairy farms which supply milk to Haverfordwest Creamery. An agreed programme of on-farm mitigation methods are employed to offset the nutrient (nitrate and phosphate) and sediment load discharged into the Western Cleddau River. The pollution reductions at scheme member farms must equal, or be greater than, the amount of nutrients discharged by the effluent plant to the Western Cleddau.

The site participates in a Climate Change Agreement for the Dairy Sector (reference: DIAL/T00061).

The status log of the permit sets out the permitting history, including any changes to the permit reference number.

Status log of the permit

Description	Date	Comments
Application received BV7788ID	08/03/2005	Application for permit
Additional information received	25/08/2005 12/09/2005	
Permit determined BV7788ID	12/10/2005	
Permit transfer application received	12/02/2007	
Additional information received	24/05/2007	
Permit transferred	02/07/2007	
Application EPR/XP3830UR/V002 (PAS Ref BP332KU)	Duly made 31/12/2009	
Additional information received	27/05/2010	
Additional information received	17/06/2010	
Variation determined EPR/XP3830UR/V002	29/07/2010	
Application EPR/XP3830UR/V003 (variation and consolidation)	Duly made 20/03/2013	Application to add an effluent treatment plant and to update the permit to modern conditions.
Variation determined EPR/XP3830UR/V003	29/07/2013	Varied and consolidated permit issued in modern condition format.
Application EPR/XP3830UR/V004	Duly made 18/12/2019	Application too add a Standard Rules Permit: SR2018 No7 Medium Combustion Plant within current installation boundary.
Additional information received	13/01/2020	Information regarding details of the Medium Combustion Plant.
Variation determined EPR/XP3830UR/V004	04/02/2020	Varied permit issued to The First Milk Cheese Company Limited.
Regulation 61 Notice sent to the Operator	28/04/2020	Issue of a Notice under Regulation 61(1) of the EPR. Natural Resources Wales initiated review and variation to vary the permit following the publication of the revised Best Available Techniques (BAT) Reference Document (BRef) for the Food, Drink and Milk Industries.
Application EPR/XP3830UR/V005 (variation and consolidation)	Duly made 26/05/2020	Application to convert SR2018 No7 Medium Combustion Plant to bespoke Medium Combustion Plant following the revision of the SR2018 No7 standard rules permit.
Additional information	09/06/2020	Information regarding detailed air

received			dispersion modelling.
Variation determined EPR/XP3830UR/V005	21/07/2020		Varied and consolidated permit issued to The First Milk Cheese Company Limited.
Regulation 61 Notice response	12/10/2020		Response received from the operator.
NRW initiated variation determined EPR/XP3830UR/V006	08/04/2022		Varied permit issued to Operator. Natural Resources Wales initiated review and variation to vary the permit following the publication of the revised Best Available Techniques (BAT) Reference Document (BRef) for the Food, Drink and Milk Industries.
Variation application EPR/XP3830UR/V007 (PAN-019159)	Duly made 24/01/2023		Application to increase production capacity by 178 tonnes per day
Additional information requested (PAN-019159)	17/02/2023		1 st Schedule 5 Notice sent requesting information on containment measures, odour and noise management, and cleaning in place meeting BAT.
Additional information requested (PAN-019159)	19/05/2023		2 nd Schedule 5 Notice sent requesting information on spill modelling and H1 risk assessment.
Additional information received (PAN-019159)	13/03/2023		Response to 1 st Schedule 5 received on 13/03/23.
Additional information received (PAN-019159)	23/06/2023		Response to 2 nd Schedule 5 received on 23/06/23.
Regulation 61(1) notice	28/07/2023		Request for operator to provide information on all Medium Combustion Plant within the range 5-50MW net rated thermal input.
Variation refused PAN-019159	05/12/2023		Variation fully refused. Refusal notice sent to Operator.
Variation application EPR/XP3830UR/V007 (PAN-027140)	Duly made 27/01/2026		Variation to: Increase production capacity by 227 tonnes per day. Install a new chemical precipitation process at the Effluent Treatment Plant. Change the 3 existing 8MWth boilers to MCP with emission limits.
Additional information requested	17/02/2026		Schedule 5 Notice sent requesting information on: surface water risk assessment, storage capacity, containment, OPRA spreadsheet.
Additional information received	03/03/2026		Initial Schedule 5 Notice response received.
Additional information	11/03/2026		Schedule 5 Notice follow-up email

requested			and further informal information request on noise and EMS.
Additional information received	13/03/2026		Response received on EMS.
Additional information received	18/03/2026		Response received on noise and EMS.
Additional information received	19/03/2026		Response received on containment.
Additional information received	23/03/2026		Response received on containment.
Additional information received	31/03/2026		Response received on containment.
Additional information received	20/04/2026		Response received on containment and EMS.
Additional information received	24/04/2026		Response received on containment.
Variation determined EPR/XP3830UR/V007 (variation and consolidation)	TBC		Varied and consolidated permit issued.

End of introductory note

Permit

The Environmental Permitting (England and Wales) Regulations 2016

Permit number
EPR/XP3830UR

This is the consolidated permit referred to in the variation and consolidation notice for application EPR/XP3830UR/V007 authorising

The First Milk Cheese Company Limited (“the operator”),

whose registered office is

The Lake District Creamery
Station Road
Aspatria
Wigton
Cumbria
CA7 2AR

company registration number **05893846**

to operate an installation at

Haverfordwest Creamery
Pembroke Road
Merlins Bridge
Haverfordwest
Pembrokeshire
SA61 1JN

to the extent authorised by and subject to the conditions of this permit.

Name	Date
TBC	TBC

Authorised on behalf of Natural Resources Wales

Conditions

1 Management

1.1 General management

1.1.1 The operator shall manage and operate the activities:

- (a) in accordance with a written management system that identifies and minimises risks of pollution, including those arising from operations, maintenance, accidents, incidents, non-conformances, closure and those drawn to the attention of the operator as a result of complaints; and
- (b) using sufficient competent persons and resources.

1.1.2 Records demonstrating compliance with condition 1.1.1 shall be maintained.

1.1.3 Any person having duties that are or may be affected by the matters set out in this permit shall have convenient access to a copy of it kept at or near the place where those duties are carried out.

1.2 Energy efficiency

1.2.1 The operator shall:

- (a) take appropriate measures to ensure that energy is used efficiently in the activities;
- (b) review and record at least every four years whether there are suitable opportunities to improve the energy efficiency of the activities; and
- (c) take any further appropriate measures identified by a review.

1.3 Efficient use of raw materials

1.3.1 The operator shall:

- (a) take appropriate measures to ensure that raw materials and water are used efficiently in the activities;
- (b) maintain records of raw materials and water used in the activities;
- (c) review and record at least every four years whether there are suitable alternative materials that could reduce environmental impact or opportunities to improve the efficiency of raw material and water use; and
- (d) take any further appropriate measures identified by a review.

1.4 Avoidance, recovery and disposal of wastes produced by the activities

1.4.1 The operator shall take appropriate measures to ensure that:

- (a) the waste hierarchy referred to in Article 4 of the Waste Framework Directive is applied to the generation of waste by the activities; and
- (b) any waste generated by the activities is treated in accordance with the waste hierarchy referred to in Article 4 of the Waste Framework Directive; and
- (c) where disposal is necessary, this is undertaken in a manner which minimises its impact on the environment.

- 1.4.2 The operator shall review and record at least every four years whether changes to those measures should be made and take any further appropriate measures identified by a review.

2 Operations

2.1 Permitted activities

- 2.1.1 The operator is only authorised to carry out the activities specified in schedule 1 table S1.1 (the “activities”).

2.2 The site

- 2.2.1 The activities shall not extend beyond the site, being the land shown edged in green on the site plan at schedule 7 to this permit.

2.3 Operating techniques

- 2.3.1 (a) The activities shall, subject to the conditions of this permit, be operated using the techniques and in the manner described in the documentation specified in schedule 1, table S1.2, unless otherwise agreed in writing by Natural Resources Wales.
- (b) If notified by Natural Resources Wales that the activities are giving rise to pollution, the operator shall submit to Natural Resources Wales for approval within the period specified, a revision of any plan or other documentation (“plan”) specified in schedule 1, table S1.2 or otherwise required under this permit which identifies and minimises the risks of pollution relevant to that plan, and shall implement the approved revised plan in place of the original from the date of approval, unless otherwise agreed in writing by Natural Resources Wales.
- 2.3.2 Any raw materials or fuels listed in schedule 2 table S2.1 shall conform to the specifications set out in that table.
- 2.3.3 The operator shall ensure that where waste produced by the activities is sent to a relevant waste operation, that operation is provided with the following information, prior to the receipt of the waste:
- (a) the nature of the process producing the waste;
- (b) the composition of the waste;
- (c) the handling requirements of the waste;
- (d) the hazardous property associated with the waste, if applicable; and
- (e) the waste code of the waste.
- 2.3.4 The operator shall ensure that where waste produced by the activities is sent to a landfill site, it meets the waste acceptance criteria for that landfill.
- 2.3.5 For the following activities referenced in schedule 1, table S1.1 (A8 and A9) the activities shall be operated using the techniques and, in the manner, described in schedule 1, table S1.2A.

2.4 Improvement programme

- 2.4.1 The operator shall complete the improvements specified in schedule 1 table S1.3 by the date specified in that table unless otherwise agreed in writing by Natural Resources Wales.

- 2.4.2 Except in the case of an improvement which consists only of a submission to Natural Resources Wales, the operator shall notify Natural Resources Wales within 14 days of completion of each improvement.

2.5 Pre-operational conditions

- 2.5.1 The operations specified in schedule 1 table S1.4 shall not commence until the measures specified in that table have been completed.

3 Emissions and monitoring

3.1 Emissions to water, air or land

- 3.1.1 There shall be no point source emissions to water, air or land except from the sources and emission points listed in schedule 3 tables S3.1, S3.2 and S3.3.
- 3.1.2 The limits given in schedule 3 shall not be exceeded.
- 3.1.3 Periodic monitoring shall be carried out at least once every 5 years for groundwater and 10 years for soil, unless such monitoring is based on a systematic appraisal of the risk of contamination.

3.2 Emissions of substances not controlled by emission limits

- 3.2.1 Emissions of substances not controlled by emission limits (excluding odour) shall not cause pollution. The operator shall not be taken to have breached this condition if appropriate measures, including, but not limited to, those specified in any approved emissions management plan, have been taken to prevent or where that is not practicable, to minimise, those emissions.
- 3.2.2 The operator shall:
- (a) if notified by Natural Resources Wales that the activities are giving rise to pollution, submit to Natural Resources Wales for approval within the period specified, an emissions management plan which identifies and minimises the risks of pollution from emissions of substances not controlled by emission limits;
 - (b) implement the approved emissions management plan, from the date of approval, unless otherwise agreed in writing by Natural Resources Wales.
- 3.2.3 All liquids in containers, whose emission to water or land could cause pollution, shall be provided with secondary containment, unless the operator has used other appropriate measures to prevent or where that is not practicable, to minimise, leakage and spillage from the primary container.

3.3 Odour

- 3.3.1 Emissions from the activities shall be free from odour at levels likely to cause pollution outside the site, as perceived by an authorised officer of Natural Resources Wales, unless the operator has used appropriate measures, including, but not limited to, those specified in any approved odour management plan, to prevent or where that is not practicable to minimise the odour.
- 3.3.2 The operator shall:
- (a) if notified by Natural Resources Wales that the activities are giving rise to pollution outside the site due to odour, submit to Natural Resources Wales for approval within the period specified, an odour management plan which identifies and minimises the risks of pollution from odour;
 - (b) implement the approved odour management plan, from the date of approval, unless otherwise agreed in writing by Natural Resources Wales.

3.4 Noise and vibration

- 3.4.1 Emissions from the activities shall be free from noise and vibration at levels likely to cause pollution outside the site, as perceived by an authorised officer of Natural Resources Wales, unless the operator has used appropriate measures, including, but not limited to, those specified in any approved noise and vibration management plan to prevent or where that is not practicable to minimise the noise and vibration.
- 3.4.2 The operator shall:
- (a) if notified by Natural Resources Wales that the activities are giving rise to pollution outside the site due to noise and vibration, submit to Natural Resources Wales for approval within the period specified, a noise and vibration management plan which identifies and minimises the risks of pollution from noise and vibration;
 - (b) implement the approved noise and vibration management plan, from the date of approval, unless otherwise agreed in writing by Natural Resources Wales.

3.5 Monitoring

- 3.5.1 The operator shall, unless otherwise agreed in writing by Natural Resources Wales, undertake the monitoring specified in the following tables in schedule 3 to this permit:
- (a) point source emissions specified in tables S3.1, S3.2 and S3.3;
- 3.5.2 The operator shall maintain records of all monitoring required by this permit including records of the taking and analysis of samples, instrument measurements (periodic and continual), calibrations, examinations, tests and surveys and any assessment or evaluation made on the basis of such data.
- 3.5.3 Monitoring equipment, techniques, personnel and organisations employed for the emissions monitoring programme and the environmental or other monitoring specified in condition 3.5.1 shall have either MCERTS certification or MCERTS accreditation (as appropriate), where available, unless otherwise agreed in writing by Natural Resources Wales.
- 3.5.4 Permanent means of access shall be provided to enable sampling/monitoring to be carried out in relation to the emission points specified in schedule 3 tables S3.1 and S3.2 unless otherwise agreed in writing by Natural Resources Wales.
- 3.5.5 For the following activities referenced in schedule 1, table S1.1 (A8 and A9) the first monitoring measurements will be carried out
- (a) For new MCP within four months of the issue date of the permit or the date when the MCP is first put into operation, whichever is later; and
 - (b) For existing MCP within four months of the issue date of the permit, unless otherwise agreed in writing by Natural Resources Wales.
- 3.5.6 For the following activities referenced in schedule 1, table S1.1 (A8 and A9) monitoring shall not take place during periods of start up or shut down.

4 Information

4.1 Records

- 4.1.1 All records required to be made by this permit shall:
- (a) be legible;

- (b) be made as soon as reasonably practicable;
- (c) if amended, be amended in such a way that the original and any subsequent amendments remain legible, or are capable of retrieval; and
- (d) be retained, unless otherwise agreed in writing by Natural Resources Wales, for at least 6 years from the date when the records were made, or in the case of the following records until permit surrender:
 - (i) off-site environmental effects; and
 - (ii) matters which affect the condition of the land and groundwater.

4.1.2 The operator shall keep on site all records, plans and the management system required to be maintained by this permit, unless otherwise agreed in writing by Natural Resources Wales.

4.1.3 For the following activities referenced in schedule 1, table S1.1 (A8 and A9), the operator shall maintain a record of the type and quantity of fuel used and the total annual hours of operation for each MCP and/or Specific Generator.

4.1.4 For the following activities referenced in schedule 1, table S1.1 (A8 and A9), the operator shall maintain a record of any events of non-compliance and the measures taken to ensure compliance is restored in the shortest possible time.

4.2 Reporting

4.2.1 The operator shall send all reports and notifications required by the permit to Natural Resources Wales using the contact details supplied in writing by Natural Resources Wales.

4.2.2 Within 28 days of the end of the reporting period the operator shall, unless otherwise agreed in writing by Natural Resources Wales, submit reports of the monitoring and assessment carried out in accordance with the conditions of this permit, as follows:

- (a) in respect of the parameters and emission points specified in schedule 4 table S4.1;
- (b) for the reporting periods specified in schedule 4 table S4.1 and using the forms specified in schedule 4 table S4.4; and
- (c) giving the information from such results and assessments as may be required by the forms specified in those tables.

4.2.3 A report or reports on the performance of the activities over the previous year shall be submitted to Natural Resources Wales by 31 January (or other date agreed in writing by Natural Resources Wales) each year. The report(s) shall include as a minimum:

- (a) a review of the results of the monitoring and assessment carried out in accordance with the permit including an interpretive review of that data;
- (b) the annual production / treatment data set out in schedule 4 table S4.2; and
- (c) the performance parameters set out in schedule 4 table S4.3 using the forms specified in table S4.4 of that schedule.

4.2.4 The operator shall, unless notice under this condition has been served within the preceding four years, submit to Natural Resources Wales, within six months of receipt of a written notice, a report assessing whether there are other appropriate measures that could be taken to prevent, or where that is not practicable, to minimise pollution.

4.3 Notifications

- 4.3.1 (a) In the event that the operation of the activities gives rise to an incident or accident which significantly affects or may significantly affect the environment, the operator must immediately—
- (i) inform Natural Resources Wales,
 - (ii) take the measures necessary to limit the environmental consequences of such an incident or accident, and
 - (iii) take the measures necessary to prevent further possible incidents or accidents;
- (b) in the event of a breach of any permit condition the operator must immediately—
- (i) inform Natural Resources Wales, and
 - (ii) take the measures necessary to ensure that compliance is restored within the shortest possible time;
- (c) in the event of a breach of permit condition which poses an immediate danger to human health or threatens to cause an immediate significant adverse effect on the environment, the operator must immediately suspend the operation of the activities or the relevant part of it until compliance with the permit conditions has been restored.
- 4.3.2 Any information provided under condition 4.3.1 (a)(i), or 4.3.1 (b)(i) where the information relates to the breach of a limit specified in the permit, shall be confirmed by sending the information listed in schedule 5 to this permit within the time period specified in that schedule.
- 4.3.3 Where Natural Resources Wales has requested in writing that it shall be notified when the operator is to undertake monitoring and/or spot sampling, the operator shall inform Natural Resources Wales when the relevant monitoring and/or spot sampling is to take place. The operator shall provide this information to Natural Resources Wales at least 14 days before the date the monitoring is to be undertaken.
- 4.3.4 Natural Resources Wales shall be notified within 14 days of the occurrence of the following matters, except where such disclosure is prohibited by Stock Exchange rules:
- Where the operator is a registered company:
- (a) any change in the operator's trading name, registered name or registered office address; and
 - (b) any steps taken with a view to the operator going into administration, entering into a company voluntary arrangement or being wound up.
- Where the operator is a corporate body other than a registered company:
- (a) any change in the operator's name or address; and
 - (b) any steps taken with a view to the dissolution of the operator.
- In any other case:
- (a) the death of any of the named operators (where the operator consists of more than one named individual);
 - (b) any change in the operator's name(s) or address(es).
- 4.3.5 Where the operator proposes to make a change in the nature or functioning, or an extension of the activities, which may have consequences for the environment and the change is not otherwise the subject of an application for approval under the Regulations or this permit:

- (a) Natural Resources Wales shall be notified at least 14 days before making the change;
and
 - (b) the notification shall contain a description of the proposed change in operation.
- 4.3.6 Natural Resources Wales shall be given at least 14 days' notice before implementation of any part of the site closure plan.
- 4.3.7 Where the operator has entered into a climate change agreement with the Government, Natural Resources Wales shall be notified within one month of:
 - (a) a decision by the Secretary of State not to re-certify the agreement;
 - (b) a decision by either the operator or the Secretary of State to terminate the agreement;
and
 - (c) any subsequent decision by the Secretary of State to re-certify such an agreement.

4.4 Interpretation

- 4.4.1 In this permit the expressions listed in schedule 6 shall have the meaning given in that schedule.
- 4.4.2 In this permit references to reports and notifications mean written reports and notifications, except where reference is made to notification being made "immediately", in which case it may be provided by telephone.

Schedule 1 - Operations

Table S1.1 activities			
Activity reference	Activity listed in Schedule 1 of the EP Regulations	Description of specified activity	Limits of specified activity
A1	S6.8 A(1)(e) – Treating and processing milk, the quantity of milk received being more than 200 tonnes per day (average value of an annual basis).	Processing of milk to produce cheese, whey and butter products.	From receipt and storage of raw materials to despatch of finished product from the installation. Maximum production capacity limited to 1487 tonnes of milk per day.
A2	S5.4 A(1)(a)(i) – Disposal of non-hazardous waste with a capacity exceeding 50 tonnes per day involving one or more of the following activities - (i) biological treatment.	Treatment of process effluent.	From receipt of crude and condensate effluent from the cheese plant to discharge to Western Cleddau.
Directly Associated Activity			
A3	Directly associated activity	Storage and handling of wastes.	From generation of wastes to despatch of wastes.
A4	Directly associated activity	Operation of refrigeration systems.	The whole of the refrigeration systems including storage, handling and use of refrigerants. Preference shall be given to lower global warming potential alternatives where technically and economically feasible. Ammonia is stored in one 2000-litre tank.
A5	Directly associated activity	Operation of passive carbon filters for odour abatement.	From release of air from each of the sludge holding tanks, DAF clarifier unit and sludge thickener through the carbon filters to release to air.
A6	Directly associated activity	Raw materials storage.	From receipt of raw materials to input to process.
A7	Directly associated activity	Finished products storage and packaging.	From receipt of finished products to despatch from the permitted installation.
Medium Combustion Plant			
Activity reference	Activity listed in the EP Regulations	Description of MCP and/or Specified Generator	Limits of specified activity

Table S1.1 activities

Activity reference	Activity listed in Schedule 1 of the EP Regulations	Description of specified activity	Limits of specified activity
A8	Schedule 25A – Medium Combustion Plant as detailed in Schedule 8 and Specified Generator that is excluded	3 x 8MWth input boilers for steam and electrical power supply fuelled on natural gas.	From receipt of fuel to release of combustion products to air. No more than two boilers shall operate at any one time, resulting in a maximum simultaneous thermal input of 16 MWth. Operating hours not restricted.
A9 NGR: SM 94846 14458	Schedule 25A – Medium Combustion Plant as detailed in Schedule 8 and Specified Generator that is excluded	1 x 2.7 MWth input Combined Heat and Power Engine fuelled on natural gas.	From receipt of fuel to release of combustion products to air. Operating hours not restricted.

Table S1.2 Operating techniques

Description	Parts	Date Received
Application	The response to questions 2.1 and 2.2 given in pages 9 to 40 of the application.	08/03/2005
Variation Application	Variation Application sections 1.1 – 1.9, 2.0 and 3.0. Non-technical summary Site Plan	31/12/2009
Response to request for further information	Response to Schedule 5 – Items 2 - 6	27/05/2010
Variation Application EPR/XP3830UR/V003	Section M – Non technical summary of the intended plant design Section O – Nitrate Management Plans for First Milk farmers Section 1 – Emergency preparedness and critical incident management plans Section 2 – Raw materials and chemical inventory	20/03/2013
Variation application EPR/XP3830UR/V005	Responses to questions 2b, 3d, 4, 5a and 6 of Form C2 including all supporting documentation. Responses to questions 1a, 1b, 2, 3a, 3b, 4a, 4b, 6a, 6b, 6c, 7, Appendix 8 of Form C3 including all supporting documentation.	21/05/2020
Response to Schedule 5 Notice dated 03/06/2020	Response to Schedule 5 Notice – document reference: CE-HW-1730-RP01-Final, Rev A	09/06/2020

Table S1.2 Operating techniques

Description	Parts	Date Received
Response to regulation 61(1) Notice – request for information dated 28/04/2020 detailing how the Operator will comply with the BAT conclusions for Food, Drink and Milk Industries under Directive 2010/75/EU of the European Parliament and of the Council	All	12/10/2020
Pack of documents named 'Farm Pack'	Document references: FP 1.1 Nutrient losses report p1 FP 1.2 Nutrient losses report p2 FP 2. Field list FP 3.1 Field record sheet and FP 12.0 applications p1 FP 3.2 Field record sheet p2 and FP 12.1 applications p2 FP 4. Farm map and FP 11.2 manure management plan example FP 5.1 Farm details profile form p1 FP 5.2 Farm details profile form p2 FP 5.3 Farm details profile form p3 FP 6.1 Nutrient management plan p1 FP6.2 Nutrient management plan p2 FP 6.3 Nutrient management plan soil results ex FP 7. Action plan FP 8.1 Reference book and action plan p1 FP 8.2 Reference book and action plan p2 FP 9.1 Mitigation method baseline calcs p1 FP 9.2 Mitigation method baseline calcs p2 FP 10. ADAS mitigation method guide RP11.1 RT Manure Management Plan template	16/04/2021
Document reference: Nutrient Mitigation Procedure, Issue Date February 2021, Version 1.0	All	16/04/2021
Operating technique for Effluent Treatment Plant	Document Reference: STS Haverfordwest DAF Report July 2021	27/07/2021
IC6 submission	Documents referenced: SHE-POL-016 Noise Management Plan v4, 2024.J004582-7849-02 First Milk Haverfordwest Noise Assessment Issue 02 Full	15/11/2024
IC7 submission	Documents Referenced: SHE-POL-015 Odour Management Plan v6	22/08/2025
IC10 submission	Documents Referenced: IC10 FMCC Haverfordwest Improvement Condition 10 – BAT 9 – June 2023, IC10 FMCC Haverfordwest Improvement Condition 10 – BAT 9 – v2 Jan 2024	30/01/24

Table S1.2 Operating techniques

Description	Parts	Date Received
Variation Application EPR/XP3830UR/V007	Documents contained in 2024.10 Final submission email 1 and 2, including responses to questions in Form C2 and Form C3, and all supporting documentation. Additional documents App 1 to App 11.	07/10/24
Response to Not Duly Made Information Request	Response to questions in emails received 24/12/25, 09/01/26 and 27/01/26. Documents referenced: Environmental Risk Assessment v5 2025.09, HAV Site boundary updates and emission points 2026.01, BAT BREF Review v3 2026.01, Haverfordwest H1 Surface Water Risk Assessment.	27/01/26
Response to Schedule 5 Notice	Response to questions in emails received 03/03/26, 18/03/26, 31/03/26, 20/04/26, 24/04/26. Documents referenced: 2026.02 Permit application NRW Sch5 Qs v1, Annex A – Hazardous Substance Emissions, Annex B – MSDS. SHE-POL-016 Noise Management Plan v5, 24-139-20B Effluent Attenuation Design, RAB – First Milk Haverfordwest – Water Pollution Management technical Note v1.	24/04/26

Table S1.2A Operating techniques for Medium Combustion Plant as detailed in Schedule 8

Description
Each MCP must be operated in accordance with the manufacturer's instructions and records must be made and retained to demonstrate this
The operator must keep periods of start-up and shut-down of each MCP as short as possible
There must be no persistent emission of 'dark smoke' as defined in Section 3(1) of The Clean Air Act 1993

Table S1.3 Improvement programme requirements

Reference	Requirement	Date
IC1	On agreement of pre-operational condition 2 (POC2) the Operator will provide a progress report based on the agreed mitigation report.	Complete
IC2	The Operator shall submit to Natural Resources Wales, for approval, a revised odour management plan that incorporates and identifies potential sources of odour from the new effluent treatment plant.	Complete
IC3	The Operator shall submit to Natural Resources Wales, for approval, a revised noise management plan that incorporates and identifies potential sources of noise from the new effluent treatment plant.	Superseded by IC7
IC4	The Operator shall submit to Natural Resources Wales, for approval, a revised emissions management plan that incorporates and identifies potential sources of fugitive emissions from the new effluent treatment plant.	Withdrawn
IC5	The Operator shall submit to Natural Resources Wales details of the conversion to natural gas for the emission points A1, A2 and A3 and the associated timeframe for the conversion.	Complete

Table S1.3 Improvement programme requirements

Reference	Requirement	Date
IC6	<p>The Operator shall submit to Natural Resources Wales an updated written procedure(s) following additional investigative work describing how they intend to meet the following BAT requirements in accordance with requirements specified within:</p> <ul style="list-style-type: none"> • BAT Conclusion 13 of the Food, Drink and Milk Industries BRef Document (EU 2019) – In order to prevent or, where that is not practicable, to reduce noise emissions, BAT is to set up, implement and regularly review a noise management plan, as part of the environmental management system that includes all of the following elements: <ul style="list-style-type: none"> - a protocol containing actions and timelines - a protocol for conducting noise emissions monitoring - a protocol for response to identified noise events e.g. complaints - a noise reduction programme designed to identify the source(s), to measure/estimate noise and vibration exposure, to characterise the contributions of the sources and to implement prevention and/or reduction measures. 	Complete
IC7	<p>The Operator shall submit to Natural Resources Wales an updated written procedure(s) following additional investigatory work describing how they intend to meet the following BAT requirements in accordance with requirements specified within:</p> <ul style="list-style-type: none"> • BAT Conclusion 15 of the Food, Drink and Milk Industries BRef Document (EU 2019) – In order to prevent or, where that is not practicable, to reduce odour emissions, BAT is to set up, implement and regularly review an odour management plan, as part of the environmental management system, that includes all of the following elements: <ul style="list-style-type: none"> - a protocol containing actions and timelines - a protocol for conducting odour monitoring. It may be complemented by measurement/estimation of odour exposure or estimation of odour impact. - a protocol for response to identified odour incidents e.g. complaints - an odour reduction programme designed to identify the source(s), to measure/estimate odour exposure, to characterise the contributions of the sources and to implement prevention and/or reduction measures. 	Complete
IC8	<p>The Operator shall complete and submit for approval in writing by Natural Resources Wales:</p> <ul style="list-style-type: none"> • A baseline report containing information necessary to determine the current state of soil and groundwater contamination; or • Provide a summary report referring to information previously submitted where you are satisfied that such information represents the current state of soil and groundwater contamination; <p>so as to enable a quantified comparison to be made with the state of soil and groundwater contamination upon definitive cessation of activity.</p>	4 June 2023 or otherwise agreed in writing with Natural Resources Wales
IC9	<p>The Operator shall submit to Natural Resources Wales an updated Environment Management System which incorporates recent changes made to the Effluent Treatment Process.</p>	12 weeks from issue date of variation V006

Table S1.3 Improvement programme requirements

Reference	Requirement	Date
IC10	<p>The Operator shall submit to Natural Resources Wales an updated written procedure following additional investigative work describing how they intend to meet the following BAT requirements in accordance with the requirements specified within:</p> <ul style="list-style-type: none"> BAT Conclusion 9 of the Food, Drink and Milk Industries BRef Document (EU 2019) – In order to prevent emissions of ozone depleting substances and of substances with a high global warming potential from cooling and freezing, BAT is to use refrigerants without ozone depletion potential and with a low global warming potential <p>The report should include but not limited to:</p> <ul style="list-style-type: none"> a review of the use of the current refrigerant(s) as to whether they meet the BAT requirements as specified above and; a feasibility study and implementation plan (if appropriate) regarding the replacement of the current refrigerant(s) with one with a lower global warming potential and no ozone depletion potential. Suitable alternatives include but not limited to ammonia, water and carbon dioxide. <p>The report shall be submitted to Natural Resources Wales by the date specified for review. Natural Resources Wales will review the report to determine if the above BAT requirements have been achieved.</p>	Complete
IC11	<p>(a) The Operator shall submit to NRW the maximum capacity of the installation that was used in the most recent risk assessment submitted to NRW.</p> <p>(b) The Operator shall submit to NRW for approval the maximum capacity of the installation at the current time.</p> <p>(c) If the maximum capacity of the installation has increased from the time of the last submitted risk assessment and the current time, the Operator shall review and update the risk assessment to account for the current maximum capacity. The risk assessment shall be submitted to NRW for review.</p> <p>Notes: The capacity is to be taken and presented using the same units from the relevant sub-section of Section 6.8, Part 2, Schedule 1 of the Environmental Permitting Regulations 2016 (as from time to time amended). Capacity is to be taken as the maximum possible capacity of the installation, not the maximum actual production. The risk assessment should follow the methodology set out in The Environmental Risk Assessment (EPR-H1). You may use a methodology other than EPR-H1 however the methodology must address the same issues as in EPR-H1 to an equivalent level of detail.</p>	Complete
IC12	<p>The operator shall submit for written approval a report by a qualified engineer (or equivalent) confirming that the proposed containment system has been constructed to the standards and descriptions provided in the documents referenced: RAB - 24-07-02 First Milk WPM Report Issue 01, RAB WPM Technical Note v1, 24-139-208 Effluent Attenuation Design. The report should reference the CIRIA 736 guidance. The operator shall submit the report to Natural Resources Wales for approval by the date specified.</p>	Within 3 months of construction of the containment system
IC13	<p>The operator shall submit written confirmation to Natural Resources Wales that the necessary environmental management system elements have been updated to account for the new containment system. This includes the environmental risk assessment, operational and accident management procedures, and associated training.</p>	Within 3 months of construction of the containment system

Table S1.4 Pre-operational measures for future development

Reference	Operation	Pre-operational measures	Status
POC 1	Effluent treatment plant	The Operator shall provide to Natural Resources Wales details of the soil investigation undertaken as part of the borehole survey for the effluent treatment plant and the associated pipeline. This information will form part of the site condition report submitted as part of the variation application EPR/XP3830UR/V003.	Complete
POC 2	Effluent treatment plant	<p>The Operator shall submit a report, for agreement with Natural Resources Wales, detailing the mitigation measures to be adopted by the farms linked to the proposed scheme. The report will consist of, but not be limited to, the following requirements:</p> <ol style="list-style-type: none"> 1) Scheme scope and methodology. 2) Organogram detailing roles and responsibilities. 3) Details of the participating farms. 4) Details of the measures to be employed at the farms. 5) Methodology of how a baseline will be set to enable comparison. 6) Timeframe for implementation. 7) How reductions will be measured / monitored at each farm. 8) Frequency of review to confirm the status /summary of the measures implemented on each farm (to demonstrate continued compliance) 9) List of guidance to be utilised to calculate or measure the off-set. 10) Contingency measures. For example if a farm leaves the scheme. 11) Collation and reporting of information. <p>The scheme must ensure that pollution reductions at farms within the scheme will equal, or be greater than, the amount of nutrients discharged by the effluent plant to the Cleddau Catchment.</p>	Complete
POC 3	Effluent treatment plant	The Operator will submit plans, for agreement with Natural Resources Wales, detailing the associated timelines for the commissioning of the new effluent treatment plant (activity reference A2).	Complete
POC4	Production capacity increase to 1487 tonnes per day	The Operator shall not operate above a production capacity of 1260 tonnes (of milk imported) per day until Improvement Conditions IC12 and IC13 have been completed. Once IC12 and IC13 have been completed, the maximum allowed production capacity will be 1487 tonnes per day, as detailed in activity referenced A1 in Schedule 1 Table S1.1.	

Schedule 2 - Waste types, raw materials and fuels

Table S2.1 Raw materials and fuels	
Raw materials and fuel description	Specification
Raw milk	Maximum quantity 1,678,000 litres

Schedule 3 – Emissions and monitoring

Table S3.1 Point source emissions to air – emission limits and monitoring requirements

Emission point ref. & location	Source	Parameter	Limit (including unit)	Reference period	Monitoring frequency	Monitoring standard or method ^{Note 1}
A1 on site plan in Schedule 7	Boiler no.1 (600 boiler)	Oxides of Nitrogen (NO and NO ₂ expressed as NO ₂)	200 mg/Nm ³	In line with web guide: Monitoring stack emissions: low risk MCPs and specified generators	Every 3 years	In line with web guide: Monitoring stack emissions: low risk MCPs and specified generators
		Carbon monoxide	No limit set			
A2 on site plan in Schedule 7	Boiler no.2 (800 boiler)	Oxides of Nitrogen (NO and NO ₂ expressed as NO ₂)	200 mg/Nm ³	In line with web guide: Monitoring stack emissions: low risk MCPs and specified generators	Every 3 years	In line with web guide: Monitoring stack emissions: low risk MCPs and specified generators
		Carbon monoxide	No limit set			
A3 on site plan in Schedule 7	Boiler no.3 (Danks boiler)	Oxides of Nitrogen (NO and NO ₂ expressed as NO ₂)	200 mg/Nm ³	In line with web guide: Monitoring stack emissions: low risk MCPs and specified generators	Every 3 years	In line with web guide: Monitoring stack emissions: low risk MCPs and specified generators
		Carbon monoxide	No limit set			
A4 on site plan in Schedule 7	2.7 MWth input CHP engine	Oxides of Nitrogen (NO and NO ₂ expressed as NO ₂)	95 mg/Nm ³	Periodic	Annually	MCERTS BS EN 14792
		Carbon monoxide	No limit set	Periodic	Annually	MCERTS BS EN 15058

Note 1: Monitoring requirements are defined at a temperature of 273.15 K, a pressure of 101.3 kPa and after correction for the water vapour content of the waste gases at a standardised O₂ content of 6 % for solid fuels, 15 % for engines and gas turbines and 3 % all other MCPs

Table S3.2 Point Source emissions to water (other than sewer) and land – emission limits and monitoring requirements

Emission point ref. & location	Source	Parameter	Limit (incl. unit)	Reference Period	Compliance Statistic	Monitoring frequency	Monitoring standard or method
W1 on site plan in Schedule 7. NGR 94651454	Uncontaminated site drainage water from site to Merlins Brook	No parameters set	No limit set	-	-	-	-
W2 on site plan in Schedule 7. Location 196342, 214759.	Discharge from effluent treatment plant activity reference A2	Maximum daily discharge volume	2500 m ³ /day	Total daily volume	Absolute maximum	Continuous	Flow meter
		Maximum rate of discharge	120 m ³ /hr	Instantaneous	Absolute maximum	Continuous	Flow meter
		Temperature	35 °C	Instantaneous	Absolute maximum	Continuous	Standard thermocouple
		Biochemical oxygen demand (BOD)	40 mg/L	Instantaneous (spot sample)	Absolute maximum	Weekly	BS EN 1899-1
			20 mg/L	Instantaneous (spot sample)	95 th percentile ^{Note 1}		
		Chemical oxygen demand (COD)	125 mg/L	24 hour flow proportional composite	Daily average	Weekly	BS 6068-2.34
		Total suspended solids	50 mg/L	24 hour flow proportional composite	Daily average	Weekly	BS EN 872
		Ammonia	10 mg/L	Instantaneous (spot sample)	Absolute maximum	Weekly	BS EN ISO 11732
			3.5 mg/L	Instantaneous (spot sample)	95 th percentile ^{Note 1}		
		Total nitrogen	20 mg/L	24 hour flow proportional composite	Daily average	Weekly	BS EN 12260 or BS EN ISO 11905-1

Table S3.2 Point Source emissions to water (other than sewer) and land – emission limits and monitoring requirements

Emission point ref. & location	Source	Parameter	Limit (incl. unit)	Reference Period	Compliance Statistic	Monitoring frequency	Monitoring standard or method
		Total phosphorus	4 mg/L	24 hour flow proportional composite	Daily average	Weekly	BS EN ISO 15681-1
		Iron	10 mg/L	Instantaneous (spot sample)	Absolute maximum	Weekly	BS EN ISO 11885
			5 mg/L	Instantaneous (spot sample)	95 th percentile ^{Note 1}		
		Aluminium	2 mg/L	Instantaneous (spot sample)	Absolute maximum	Weekly	BS EN ISO 11885
			1 mg/L	Instantaneous (spot sample)	95 th percentile ^{Note 1}		
		pH	6 - 9	Instantaneous (continuous)	Absolute maximum	Continuous	BS ISO 10523
		Chloride (Cl ⁻)	No limit set	24 hour flow proportional composite	Not applicable	Monthly	Various EN standards available including ES ISO 10304-1 and EN ISO 15682
WL1 on site plan in Schedule 7. East side of site	Discharge of two uncontaminated land drains to one soakaway	No parameters set	No limit set	-	No limit set	-	-

Note 1: For 95 % of all measured values according to look up table

Table S3.3 Annual limits

Substance	Medium	Limit (including unit)
Mercury and its compounds	Water	228g – Compliance based on mass balance calculation
Cadmium and its compounds	Water	96g – Compliance based on mass balance calculation

Schedule 4 – Reporting

Parameters, for which reports shall be made, in accordance with conditions of this permit, are listed below.

Table S4.1 Reporting of monitoring data			
Parameter	Emission or monitoring point/reference	Reporting period	Period begins
Emissions to air Parameters as required by condition 3.5.1.	A1, A2, A3	Every 3 years From date of acceptance of first monitoring measurements under condition 3.5.5	1 January
Emissions to air Parameters as required by condition 3.5.1.	A4	Every 12 months	1 January
Emissions to water Parameters as required by condition 3.5.1	W2	Every 6 months	1 January, 1 July

Table S4.2: Annual production	
Parameter	Units
Production of dairy products	tonnes
Milk imported	tonnes

Table S4.3 Performance parameters		
Parameter	Frequency of assessment	Units
Energy usage	Annually	MWh
Potable water usage	Annually	tonnes
Non potable water usage	Annually	tonnes
Waste disposal and/or recovery	Annually	tonnes
Mass of ammonia released to water	Annually	tonnes
Mass of refrigerants released	Annually	tonnes
Annual report with the amount of nitrates, suspended solids and phosphates reduced from the farm nutrient efficiency (offset) scheme.	Annually	kg

Table S4.4 Reporting forms		
Media/parameter	Reporting format	Date of form
Air	Form air 1 or other form as agreed in writing by Natural Resources Wales	TBC
Water	Form water 1 or other form as agreed in writing by Natural Resources Wales	04/12/23
Energy usage	Form energy 1 or other form as agreed in writing by Natural Resources Wales	21/07/20
Water usage	Form water usage 1 or other form as agreed in writing by Natural Resources Wales	21/07/20

Table S4.4 Reporting forms

Media/parameter	Reporting format	Date of form
Other performance indicators	Form performance 1 or other form as agreed in writing by Natural Resources Wales	21/07/20

Schedule 5 - Notification

These pages outline the information that the operator must provide.

Units of measurement used in information supplied under Part A and B requirements shall be appropriate to the circumstances of the emission. Where appropriate, a comparison should be made of actual emissions and authorised emission limits.

If any information is considered commercially confidential, it should be separated from non-confidential information, supplied on a separate sheet and accompanied by an application for commercial confidentiality under the provisions of the EP Regulations.

Part A

Permit Number	EPR/XP3830UR
Name of operator	
Location of Facility	
Time and date of the detection	

(a) Notification requirements for any malfunction, breakdown or failure of equipment or techniques, accident, or emission of a substance not controlled by an emission limit which has caused, is causing or may cause significant pollution	
To be notified within 24 hours of detection	
Date and time of the event	
Reference or description of the location of the event	
Description of where any release into the environment took place	
Substances(s) potentially released	
Best estimate of the quantity or rate of release of substances	
Measures taken, or intended to be taken, to stop any emission	
Description of the failure or accident.	

(b) Notification requirements for the breach of a limit	
To be notified within 24 hours of detection unless otherwise specified below	
Emission point reference/ source	
Parameter(s)	
Limit	
Measured value and uncertainty	
Date and time of monitoring	
Measures taken, or intended to be taken, to stop the emission	

Time periods for notification following detection of a breach of a limit	
Parameter	Notification period

(c) Notification requirements for the detection of any significant adverse environmental effect	
To be notified within 24 hours of detection	
Description of where the effect on the environment was detected	
Substances(s) detected	
Concentrations of substances detected	
Date of monitoring/sampling	

Part B - to be submitted as soon as practicable

Any more accurate information on the matters for notification under Part A.	
Measures taken, or intended to be taken, to prevent a recurrence of the incident	
Measures taken, or intended to be taken, to rectify, limit or prevent any pollution of the environment which has been or may be caused by the emission	
The dates of any unauthorised emissions from the facility in the preceding 24 months.	

Name*	
Post	
Signature	
Date	

* authorised to sign on behalf of the operator

Schedule 6 - Interpretation

“accident” means an accident that may result in pollution.

“application” means the application for this permit, together with any additional information supplied by the operator as part of the application and any response to a notice served under Schedule 5 to the EP Regulations.

“authorised officer” means any person authorised by Natural Resources Wales under section 108(1) of The Environment Act 1995 to exercise, in accordance with the terms of any such authorisation, any power specified in section 108(4) of that Act.

“background concentration” means such concentration of that substance as is present in:

- for emissions to surface water, the surface water quality up-gradient of the site; or
- for emissions to sewer, the surface water quality up-gradient of the sewage treatment works discharge.

“building” means a construction that has the objective of providing sheltering cover and minimising emissions of noise, particulate matter, odour and litter.

“combined heat and power” or *“CHP”* or *“Cogeneration”* means the simultaneous generation in one process of thermal energy and electrical or mechanical energy

“disposal” or *“D”* means any of the operations provided for in Annex I to Directive 2008/98/EC of the European Parliament and of the Council on waste.

“emissions to land” includes emissions to groundwater.

“existing MCP” means an MCP first put into operation before 20/12/2018.

“EP Regulations” means The Environmental Permitting (England and Wales) Regulations SI 2010 No.675 and words and expressions used in this permit which are also used in the Regulations have the same meanings as in those Regulations.

“emissions of substances not controlled by emission limits” means emissions of substances to air, water or land from the activities, either from the emission points specified in schedule 3 or from other localised or diffuse sources, which are not controlled by an emission limit.

“first put into operation” means that the plant must have been fired with its design fuel up to its full load. This can be, but does not have to be, during commissioning

“groundwater” means all water, which is below the surface of the ground in the saturation zone and in direct contact with the ground or subsoil.

“hazardous property” has the meaning in Annex III of the Waste Framework Directive

“hazardous waste” has the meaning given in the Hazardous Waste (Wales) Regulations 2005 (as amended)

“hazardous substance” means a substance classified as hazardous as a consequence of fulfilling the criteria laid down in parts 2 to 5 of Annex I to Regulation (EC) No 1272/2008

“Industrial Emissions Directive” means DIRECTIVE 2010/75/EU OF THE EUROPEAN PARLIAMENT AND OF THE COUNCIL of 24 November 2010 on industrial emissions

“Look up table” The limit for any of the relevant parameters set out in tables S3.2 may be exceeded where: in a series of samples of the discharge taken at regular but randomised intervals in a period of 12

consecutive months as listed in in the look up table, no more than the relevant number of samples, as listed in column 2, exceed the applicable limit for that relevant parameter.

Look up table	
Number of samples taken in any period of 12 months	Maximum number of samples permitted to exceed limit for given determinand
4–7	1
8–16	2
17–28	3
29–40	4
41–53	5
54–67	6
68–81	7
82–95	8
96–110	9
111–125	10

“mass balance calculation” means that for the purposes of demonstrating compliance or non-compliance with a specified limit the release shall be calculated. Annual mass releases for Mercury and Cadmium shall be calculated from the maximum potential concentration of the metal present as contamination multiplied by the volume of the chemicals used on site during the Year. An allowance may be deducted for any proportion of the chemicals used that can be demonstrated not to have reached the emission point. The concentration of Mercury and Cadmium shall be calculated from the annual mass release and the volume of effluent discharged during the Year.

“MCERTS” means the Environment Agency’s Monitoring Certification Scheme.

“medium combustion plant” or “MCP” means a combustion plant with a rated thermal input equal to or greater than 1 MW but less than 50 MW

“Medium Combustion Plant Directive” or “MCPD” means Directive 2015/2193/EU of the European Parliament and of the Council of the limitation of emissions of certain pollutants into the air from medium combustion plants.

“new MCP” means an MCP first put into operation on or after 20/12/2018.

“Natural gas” means naturally occurring methane with no more than 20% by volume of inert or other constituents

“operating hours” means the time, expressed in hours, during which a combustion plant is operating and discharging emissions into the air, excluding start-up and shut-down periods

“quarter” means a calendar year quarter commencing on 1 January, 1 April, 1 July or 1 October.

“specified generator” or “SG” means has the meaning given in paragraph 2(1) of Schedule 25B of the EP Regulations

“year” means calendar year ending 31 December.


Where a minimum limit is set for any emission parameter, for example pH, reference to exceeding the limit shall mean that the parameter shall not be less than that limit.

Unless otherwise stated, any references in this permit to concentrations of substances in emissions into air means:

- (a) in relation to emissions from combustion processes, the concentration in dry air at a temperature of 273K, at a pressure of 101.3 kPa and with an oxygen content of 3% dry for liquid and gaseous fuels, 6% dry for solid fuels; and/or
- (b) in relation to emissions from non-combustion sources, the concentration at a temperature of 273K and at a pressure of 101.3 kPa, with no correction for water vapour content.

Schedule 7 - Site plan





© Crown Copyright and database right 2026. Ordnance Survey licence number 100019741.

Schedule 8 – Annex 1 of MCPD

1. Rated thermal input (MW) of the medium combustion plant.	3 x 8 MW thermal input boilers. Only 2 of 3 boilers can operate at the same time, resulting in a maximum simultaneous thermal input of 16MW.
2. Type of the medium combustion plant (diesel engine, gas turbine, dual fuel engine, other engine or other medium combustion plant).	Other medium combustion plant (steam boiler)
3. Type and share of fuels used according to the fuel categories laid down in Annex II.	100 % Natural gas
4. Date of the start of the operation of the medium combustion plant or, where the exact date of the start of the operation is unknown, proof of the fact that the operation started before 20 December 2018.	Installed in 2008 and ran on gas oil. Converted to natural gas between March and June 2015.
5. Sector of activity of the medium combustion plant or the facility in which it is applied (NACE code).	NACE 10.51
6. Expected number of annual operating hours of the medium combustion plant and average load in use.	5840 hours, 40% average loading. Assuming 2 out of 3 boilers are operational at all times.
7. Where the option of exemption under Article 6(3) or Article 6(8) is used, a declaration signed by the operator that the medium combustion plant will not be operated more than the number of hours referred to in those paragraphs.	N/A
8. Name and registered office of the operator and, in the case of stationary medium combustion plants, the address where the plant is located.	Registered office address: The First Milk Cheese Company Limited, The Lake District Creamery, Station Road, Aspatria, CA7 2AR MCP Location: Haverfordwest Creamery, Pembroke Road, Merlins Bridge, Haverfordwest, SA61 1JN

1. Rated thermal input (MW) of the medium combustion plant.	2.7 MW thermal input
2. Type of the medium combustion plant (diesel engine, gas turbine, dual fuel engine, other engine or other medium combustion plant).	Combined Heat and Power Engine
3. Type and share of fuels used according to the fuel categories laid down in Annex II.	100 % Natural gas
4. Date of the start of the operation of the medium combustion plant or, where the exact date of the start of the operation is unknown, proof of the fact that the operation started before 20 December 2018.	01/07/2020
5. Sector of activity of the medium combustion plant or the facility in which it is applied (NACE code).	NACE 10.51

6. Expected number of annual operating hours of the medium combustion plant and average load in use.	8760 hours
7. Where the option of exemption under Article 6(3) or Article 6(8) is used, a declaration signed by the operator that the medium combustion plant will not be operated more than the number of hours referred to in those paragraphs.	N/A
8. Name and registered office of the operator and, in the case of stationary medium combustion plants, the address where the plant is located.	Registered office address: The First Milk Cheese Company Limited, The Lake District Creamery, Station Road, Aspatria, CA7 2AR MCP Location: Haverfordwest Creamery, Pembroke Road, Merlins Bridge, Haverfordwest, SA61 1JN

END OF PERMIT