

**Water Resources Act 1991**  
as amended by the Environment Act 1995

**Consent to Discharge**  
**Certificate of Holder**



**ENVIRONMENT**  
**AGENCY**

**Part A**

To: DWR CYMRU CYFYNGEDIG  
CONSENTS REGULATION OFFICER  
PLAS-Y-FFYNNON  
CAMBRIAN WAY  
BRECON LD3 7HP

The Environment Agency ("the Agency") hereby confirm that the above named person is a/the registered holder of consent BN0194103

Nature of Discharge(s); SEWAGE EFF/STORM EFF/RAINFALL  
at FFAIRFACH STW - SETTLED STORM

Note: This certificate should be kept with the consent document for future reference. If you transfer responsibility for the discharge to somebody else you must pass the consent to them and tell the Agency within 21 days. **Responsibility for the consent cannot be disclaimed by the holder but the registration of holder may be transferred to a successor.** To do this please complete the form below, then tear it off and return it to the address shown. If you fail to transfer the consent, even though you are no longer on the site, you may still be liable for prosecution for pollution. If you transfer the consent but do not tell us, you will be committing an offence. In case of any queries please contact your local Environment Agency office.

**Part B** Please complete in block capitals or type.

To:

**Water Resources Act 1991: Notice of transfer of consent to discharge**

Consent: Name:  
Address:

I/We\* hereby serve notice on the Agency that I/we\* am/are\* no longer a/the\* Holder of the above consent which will be/was\* transferred to: \* delete as appropriate

Name(s) of new holder(s):  
Address:

Post Code:

Date of Transfer to new Holder(s):

Signed: Dated:

Name (block capitals): Position:





WATER ACT 1973  
RIVERS (PREVENTION OF POLLUTION) ACTS 1951-61  
THE WATER AUTHORITIES (CONTROL OF OUTLETS AND DISCHARGES) REGULATIONS 1975

NOTIFICATION OF CONSENT

*to the bringing into use of a new or altered outlet*

*and/or*

*making of a new discharge of effluent to a stream or controlled waters*

TO:

WELSH WATER AUTHORITY  
West Wales Sewage Division  
3 Goat Street  
Haverfordwest  
Dyfed  
SA61 1PX

*In pursuance of the powers conferred by the above-mentioned Acts and in accordance with the Water Authorities (Control of Outlets and Discharges) Regulations 1975, this Consent is issued as a CONSENT DEEMED TO HAVE BEEN GRANTED by the Secretary of State for Wales in respect of*

*the bringing into use of a ~~new or altered~~  
300 mm diameter outlet and the making of a  
new discharge of settled storm sewage  
from Ffairfach Sewage Treatment Works, Llandeilo*

*to the River Towy*

*at National Grid reference SN 617 212*

*being a stream/~~controlled waters~~ situated within the South West Wales River Division area of the Welsh Water Authority in accordance with the draft consent submitted to the Secretary of State for Wales on the 13th day of November 19 78*

*SUBJECT to the following conditions:-*

1. *The outlet by means of which the effluent is discharged shall*
  - a) *be the existing 300 mm diameter cast iron pipe.*
  - b) *be used for the discharge of settled storm sewage.*
  
2. *The effluent discharged shall consist of settled storm sewage only.*



The effluent discharged shall not

have a pH value of less than 6.0 nor greater than 8.5

(b) ~~have a Biochemical Oxygen Demand over 5 days of greater than milligrams per litre at 20°C~~

(c) contain suspended solids in excess of 150 milligrams per litre

(d) ~~contain any of the following substances in concentrations greater than that set out below:~~

~~milligrams per litre~~

4. The temperature of the effluent discharged shall not exceed 21 °C

5. ~~The volume of effluent discharged under any weather conditions shall not exceed cubic metres any period of twenty four hours.~~

6. ~~The rate at which the effluent is discharged shall not exceed litres per second.~~

(a) "The rate of discharge of effluent to the stream shall be limited to the amount by which the rate of flow at the storm separating weir is at the time of discharge in excess of 62.4 litres per second and the discharge of effluent shall take place only so long as an overflow is occurring from the storm sewage tanks."



adequate means of taking samples of effluent at the outfall shown as point 'A'  
on plan no. 23/C 1941 C/00/01 attached hereto.

The terms of this Consent will not, without the consent in writing of the  
person to whom this Consent is given (or his successor), be altered before  
the expiration of the period ending with the 12th day of  
February 1981.

WELSH WATER AUTHORITY  
CAMBRIAN WAY  
BRECON  
POWYS

DATE:

9/11/80

