

G. ~~1225~~/1292

WELSH OFFICE

CONTROL OF POLLUTION ACT 1974: SECTION 34
THE CONTROL OF POLLUTION (DISCHARGES BY AUTHORITIES) REGULATIONS 1984
CONSENT FOR A DISCHARGE

WHEREAS

1. The WELSH WATER AUTHORITY (hereinafter referred to as 'the Water Authority') proposes to discharge filter wash water to a tributary of the Nant Gwernol at Abergynolwyn at national grid reference SH 6716 0645 as shown on the attached plan.
2. The proposals require the consent of the Secretary of State for WALES in pursuance of sections 34 and 55 of the Control of Pollution Act 1974 as modified by the Control of Pollution (Discharges by Authorities) Regulations 1984 (hereinafter referred to as 'the Regulations').
3. In accordance with the provisions of Article 2 of the Regulations the Water Authority have submitted the proposals to the Secretary of State in the form of an application for consent dated 2 July 1986.

THE SECRETARY OF STATE FOR WALES hereby consents to the proposed discharge subject to the conditions specified in the Schedule hereto attached.

Dated this 31 day of July
1986

SignedK. E. Taylor.....

On behalf of the Secretary
of State for Wales

SCHEDULE

Conditions prescribed for the discharge of Dechlorinated Filter Backwash Water and Reservoir Washout Liquors to a Tributary of the Nant Gwernol at Abergynolwy at National Grid Reference SH 6716 0645.

1. The effluent discharged shall consist only of Dechlorinated Filter Backwash water and reservoir washout liquors.
2. Facilities shall be provided to the Secretary of State's representatives so as to enable samples of the discharge to be conveniently obtained at all times.
3. The WWA shall maintain the Dechlorination equipment properly and closely inspect at intervals no greater than 6 monthly. Samples of the effluent shall be taken at this time, records of which, and the results of analyses thereof, shall be kept for inspection by the Secretary of State's representative.
4. The maximum daily volume discharged to the River shall not exceed 7 cubic metres per day and the maximum rate of discharge shall not exceed 12.3 litres per second at any time.
5. The suspended solids concentration shall not exceed 150 milligrams per litre.
6. The chlorine concentration, expressed as free chlorine shall not exceed 0.01 milligrams per litre in the discharge at any time.

REGISTER OF CONDITIONS

AND OTHER TERMS

IMPOSED UNDER SECTION 7 OF THE RIVERS (PREVENTION OF POLLUTION) ACT, 1951
(AS APPLIED BY THE CLEAN RIVERS (ESTUARIES AND TIDAL WATERS) ACT, 1960)
AND THE RIVERS (PREVENTION OF POLLUTION) ACT, 1961.

No. G 1292

DATE ON WHICH CONDITION CAME INTO FORCE AND PERIOD OF EFFECT	FULL ADDRESS OR OTHER SUFFICIENT DESCRIPTION OF LAND OR PREMISES TO WHICH THE TERM OR CONDITION RELATES
31 July 1986	Dechlorinated filter backwash water and Reservoir Washout Liquores to a tributary of the Nant Gwernol at Abergynolwyn.
USE OF NEW OR ALTERED OUTLET	DISCHARGE OF TRADE OR SEWAGE EFFLUENT
CONDITIONS IMPOSED WITH RESPECT TO:- (i) PRECISE LOCATION OF OUTLET To a tributary of the Nant Gwernol at Abergynolwyn at NGR SH 6716 0645. (ii) CONSTRUCTION OF OUTLET (OTHER THAN CONDITIONS TO BE SATISFIED BEFORE OUTLET IS BROUGHT INTO USE) (iii) USE OF OUTLET For a discharge of filter wash water. (iv) USE OF ANY OTHER OUTLET FOR TRADE OR SEWAGE EFFLUENT FROM THE SAME LAND OR PREMISES	CONDITIONS IMPOSED WITH RESPECT TO:- (i) NATURE AND COMPOSITION OF DISCHARGE 1. The effluent discharged shall consist only of Dechlorinated Filter Backwash water and reservoir washout liquors. 2. Facilities shall be provided to the Secretary of States's representatives so as to enable samples of the discharge to be conveniently obtained at all times. 3. The WWA shall maintain the Dechlorination equipment properly and closely inspect at intervals no greater than 6 monthly. Samples of the effluent shall be taken at this time, records of which, and the results of analyses thereof, shall be kept for inspection by the Secretary of State's representative. 4. The maximum daily volume discharged to the River shall not exceed 7 cubic metres per day and the maximum rate of discharge shall not exceed 12.3 litres per second at any time. 5. The suspended solids concentration shall not exceed 150 milligrams per litre. 6. The chlorine concentration, expressed as free chlorine shall not exceed 0.01 milligrams per litre in the discharge at any time. (vi) DATE OF EXPIRATION OF PERIOD SPECIFIED UNDER S-5(2) OF 1961 ACT 30 July 1988
REMARKS- Addressee: Welsh Water Authority Northern Division Penrhosgarnedd Bangor Gwynedd	REMARKS-