

Water Resources Act 1991 .
as amended by the Environment Act 1995
Consent to Discharge
Certificate of Holder



ENVIRONMENT
AGENCY

Part A

To: DWR CYMRU CYFYNGEDIG
CONSENTS REGULATION OFFICER
PLAS-Y-FFYNNON
CAMBRIAN WAY
BRECON LD3 7HP

The **Environment Agency** ("the Agency") hereby confirm that the above named person is a/the registered holder of consent BN0254401

Nature of Discharge(s); SEWAGE EFF/CRUDE EFF/EMERGENCY
at P.S.CATSHOLE QUARRY PEM PEMB

Note: This certificate should be kept with the consent document for future reference. If you transfer responsibility for the discharge to somebody else you must pass the consent to them and tell the Agency within 21 days. Responsibility for the consent cannot be disclaimed by the holder but the registration of holder may be transferred to a successor. To do this please complete the form below, then tear it off and return it to the address shown. If you fail to transfer the consent, even though you are no longer on the site, you may still be liable for prosecution for pollution. If you transfer the consent but do not tell us, you will be committing an offence. In case of any queries please contact your local Environment Agency office.

Part B Please complete in block capitals or type.

To:

Water Resources Act 1991: Notice of transfer of consent to discharge

Consent:

Name:
Address:

I/We* hereby serve notice on the Agency that I/we* am/are* no longer a/the* Holder of the above consent which will be/was* transferred to:

* delete as appropriate

Name(s) of new holder(s):

Address:

Post Code:

Date of Transfer to new Holder(s):

Signed:

Dated:

Name (block capitals):

Position:



WELSH WATER AUTHORITY
SOUTH WEST WALES RIVER DIVISION
RIVERS (PREVENTION OF POLLUTION) ACTS, 1951-1961

Consent to discharge of effluent

The South-West Wales River Division pursuant to the provisions of the above mentioned Acts, hereby consent to the construction of an outlet and to the discharge of effluent therefrom upon the following conditions :—

1. NAME AND ADDRESS OF PERSON
to whom consent is given

Dyfed County Council,
County Hall, Carmarthen

2. PREMISES to which consent relates

Emergency overflow from Pumping Station
Catshole Quarry Gipsy Site, Pembroke

3. OUTLET

(a) Location—situated on right/left bank of River Pembroke River
~~a tributary of the River~~

Map reference OS21" SM90, Grid reference SN 97380189

See below
"

* (b) Construction— 150mm diameter Glazed Clay Pipe

* (c) Use—restricted to Sewage/Storm Sewage/Trade/Farm Effluent produced at the
above mentioned premises. emergency discharge of screened
domestic sewage only.

4. DISCHARGE

(a) Nature - screened domestic sewage only.

(b) Volume or rate of discharge 0.25 m³/day (Dry Weather Flow)
Maximum rate of discharge

(c) Temperature not to exceed °C. N/A

(d) Composition :—

(i) pH value not less than or more than N/A

(ii) Suspended solids not more than N/A

(iii) 5 day B.O.D. at 20 °C. not more than N/A

(iv) Effluent shall not contain any other polluting substance or substances in
concentrations toxic to fish and other animals.

See 3 (b) above

* Pump sump construction should include dip pipe to
exclude gross solids from emergency discharges.

See 3 (c) above

* Effluent to be discharged under emergency conditions
only i.e. power failure or mechanical failure of both pumps.

(e) Sampling point to be located at outlet from 150mm diam. glazed clay pipe.

5. PERIOD OF CONSENT

The terms of this consent will not without the consent in writing of the person to whom this consent is given be
altered before the expiration of the period ending with the 30th day of April 19 84

Dated this 21st day of April 19 82

Divisional Manager

Penyfai House,
19, Penyfai Lane,
Furnace,

Naylor House,
St. Thomas Green,
Haverfordwest,