

Conwy Touring Park Treatment Plant

Final effluent discharge quality

The treatment plant is designed to achieve the following final effluent discharge quality

Determinand	Value	Unit
Biochemical Oxygen Demand	20	mg/l
Suspended Solids	30	mg/l
pH	5.0 – 8.0	
Ammonia	20	mg/l