

**Water Resources Act 1991**  
**as amended by the Environment Act 1995**  
**Consent to Discharge**  
**Certificate of Holder**



**ENVIRONMENT  
AGENCY**

**Part A**

**To:** ST MARY'S GOLF & COUNTRY CLUB  
COMPANY SECRETARY  
PENCOED  
  
BRIDGEND CF35 5EA

The Environment Agency ("the Agency") hereby confirm that the above named person is a/the registered holder of consent BP0158001

Nature of Discharge(s); SEWAGE EFF/TREATED EFF/CONTINUOUS  
at  
PENCOED BRIDGEND

Note: This certificate should be kept with the consent document for future reference. If you transfer responsibility for the discharge to somebody else you must pass the consent to them and tell the Agency within 21 days. **Responsibility for the consent cannot be disclaimed by the holder but the registration of holder may be transferred to a successor.** To do this please complete the form below, then tear it off and return it to the address shown. If you fail to transfer the consent, even though you are no longer on the site, you may still be liable for prosecution for pollution. If you transfer the consent but do not tell us, you will be committing an offence. In case of any queries please contact your local Environment Agency office.

**Part B** Please complete in block capitals or type.

**To:**

**Water Resources Act 1991: Notice of transfer of consent to discharge**

**Consent:**

**Name:**

**Address:**

I/We\* hereby serve notice on the Agency that I/we\* am/are\* no longer a/the\* Holder of the above consent which will be/was\* transferred to:

\* delete as appropriate

**Name(s) of new holder(s):**

**Address:**

**Post Code:**

**Date of Transfer to new Holder(s);** .....

**Signed:** .....

**Dated:** .....

**Name (block capitals):** .....

**Position:** .....





Our ref: 2/EQ/BP0158001/AR/KSP  
Your ref:

Date: November 3, 1995

ST Mary's Golf Club Ltd  
Trallwynl  
Llanilid  
Pencoed  
Mid Glamorgan



Dear Sir/Madam,

**RE: WATER RESOURCES ACT 1991 SECTION 88 SCHEDULE 10  
REVIEW OF CONSENT TO DISCHARGE**

Further to our recent correspondence concerning the consent to discharge sewage effluent from Sewage Treatment Works at St Mary's Golf Club, Trallwyn, Llanilid, Pencoed, Mid Glamorgan, I enclose the Authority's formal notice of the modifications made to the conditions of the consent.

Under the present Scheme of Charges for Discharges to Controlled Waters an annual charge will be made for all consents to discharge, except where the discharge is of sewage effluent of five cubic metres or less per day. This charge is based on information derived from the conditions attached to the consent to discharge, as outlined in the enclosed leaflet. A change in conditions may therefore result in a change in annual charge, you may therefore receive a revised bill in due course.

Where there is a change of ownership of the discharge, the Authority should be informed in writing in order that an apportioned charge may be raised.

If you are not satisfied with the new conditions of the consent you may appeal against the decision to the Secretary of State for Wales at the Welsh Office, Cathays Park, Cardiff CF1 3NQ.


Yours faithfully,

A handwritten signature in dark ink, appearing to read 'S J Brown', is written over the closing 'Yours faithfully,'.

PP S J BROWN  
Area Environmental Quality Manager

Enc


Please ask for: Mr Anthony Rogers



Dr JOHN STONER Rheolwr Cyffredinol Rhanbarthol / Regional General Manager

Awdurdod Afonydd Cenedlaethol, Rhanbarth Cymru / National Rivers Authority, Welsh Region  
Llys Afon, Hawthorn Rise, Hwlfordd, Dyfed SA61 2BQ. Ffôn: (01437) 760081, Ffacs: (01437) 760881  
Llys Afon, Hawthorn Rise, Haverfordwest, Dyfed SA61 2BQ. Tel: (01437) 760081, Fax: (01437) 760881

Date Stamp



Officer's Signature

DR 9170 8447 7 GB

Sent To

ST MARYS GOLF  
CLUB LTD.

Address

TRALLWYNL  
LLANILID  
PENCOED

MID GLAMORGAN

Postcode



Royal Mail

*Recorded*  
for a signature on delivery

|             |           |
|-------------|-----------|
| Consent No. | BP0158001 |
|-------------|-----------|

WATER RESOURCES ACT 1991

Under Section 88 and Schedule 10 of the Water Resources Act 1991  
 and all other enabling powers  
 the National Rivers Authority hereby serves this Notice

R E V I E W   O F   C O N S E N T

Page 1 of 4

To : ST MARY'S GOLF CLUB LTD

Of : TRALLWYN, LLANILID, PENCOED, MID GLAMORGAN

In respect of the previous Consent No BP0158001 issued on : 30 MARCH 1990

For : A DISCHARGE OF SEWAGE EFFLUENT

To : LAND

From : SEWAGE TREATMENT WORKS AT ST MARY'S GOLF CLUB, TRALLWYN,  
 LLANILID, PENCOED, MID GLAMORGAN

THE FOLLOWING REPLACE ALL PREVIOUS CONDITIONS

1. (i) The discharge shall not contain any poisonous, noxious or polluting matter or solid waste matter.
- (ii) Provided that the discharge hereby consented is made in accordance with the following conditions of this consent, such discharge shall not be taken to be in breach of condition i) above by reason of containing substances or having properties identified in and controlled by those conditions.
2. The discharge shall consist solely of biologically treated sewage sewage effluent containing no authorised trade effluent, from the sewage treatment works at St Mary's Golf Club.
3. The volume of effluent discharged shall not exceed 20 cubic metres in any period of 24 consecutive hours. The rate of discharge shall not exceed 0.7 litres per second.

Cont/d ....

Consent No.

BP0158001

WATER RESOURCES ACT 1991  
 Continuation Sheet

Page 2 of 4

4. The discharge shall be made in the manner and at the place specified as follows:-

Discharging via: a pipe  
 Discharging to: Land  
 At OS Grid Ref: SS 9790 8040  
 As shown marked: Consent point 'A' on the attached  
 Drawing/Plan No BP0158001

5. Adequate facilities, approved in writing by the Authority, shall be provided to enable representative samples of the discharge to be safely and conveniently obtained at any time at the outlet to the soakaway as shown marked 'Sample Point' on the attached drawing no. BP0158001.
6. No part of the sub-surface soakaway system shall lie within 10 metres of the nearest watercourse.
7. The discharge shall not cause any adverse effects on sources of water used for public or private potable supply.
8. The works shall be operated so as to prevent the effluent from causing ecological damage or from having any adverse aesthetic impact.
9. The works shall be operated and maintained in accordance with good operational practice such that:
- (i) It remains fully operational except at times of unavoidable mechanical or electrical breakdown which shall be attended to, and the NRA informed of the failure, as soon as practicable after the failure;
  - (ii) Following a failure all equipment shall be returned to normal operation as soon as practicable;

Cont/d ....

|             |           |
|-------------|-----------|
| Consent No. | BP0158001 |
|-------------|-----------|

WATER RESOURCES ACT 1991  
 Continuation Sheet

Page 3 of 4

- (iii) Tanks shall be desludged at sufficient frequency and in such a manner to prevent excessive carryover of suspended solids.
- 10. (i) The discharger shall establish and operate a documented maintenance programme and record all non-routine actions undertaken. Copies of the programme shall be made available for inspection by the Authority's officers at all reasonable times.
- (ii) The discharger shall supply the Authority with an annual written report on the operation of the maintenance programme and all non-routine actions. The contents and the format of the report to be agreed in writing with the Authority.
- 11. As far as is reasonably practicable, the works shall be operated so as to prevent the discharge from containing any significant trace of visible oil or grease.
- 12. (i) No inspection of the sewage treatment works, made at a time when Sections 87 (2) or 89 (1) of the Water Resources Act 1991 apply, and the operation of the sewage treatment works is consequently adversely affected, shall be taken into account in deciding whether or not the conditions contained paragraphs 8 and 9 of this consent have been complied with.
- (ii) On each occasion that the sewage treatment works is not under normal operating conditions for the reasons in 12(i), the discharger shall use its best endeavours to mitigate any adverse effect and shall notify the Authority by telephone as soon as practicable and confirm in writing within 14 days of the occurrence of such conditions. That notification shall include a full description of the abnormal operating condition and their impact on the operation of the works.
- 13. (i) No inspection of the sewage treatment works, made at a time when unusual weather conditions are adversely affecting the operation of the sewage treatment works, shall be taken into account in deciding whether or not the conditions contained paragraphs 8 and 9 of this consent have been complied with.

Cont/d ....

Consent No.

BP0158001

WATER RESOURCES ACT 1991  
 Continuation Sheet

Page 4 of 4

13. Continued

(ii) For the purpose of this condition "unusual weather conditions" shall include:-

(I) low ambient temperatures as evidenced by effluent temperatures of 5°C or less, or by the freezing of mechanical equipment in the works;

(II) significant snow deposits;

(III) tidal or fluvial flooding;


(IV) weather conditions causing unforeseen loss of power supply to the sewage treatment which could not be ameliorated by the reasonable provision and operation of standby generation facilities.

(iii) On any occasion where unusual weather conditions adversely affect operation of the sewage treatment works, the discharger shall use its best endeavours to mitigate that adverse affect. The discharger shall notify the NRA by telephone as soon as unusual weather conditions are known to have adversely affected operations and shall confirm the circumstances in writing as soon as possible thereafter (and in any event within 14 days of the occurrence of such conditions). That notification shall include a full description of the unusual weather conditions and their impact in the operation of the works.

Subject to the provisions of Paragraphs 6 and 7 of Schedule 10 of the Water Resources Act 1991, no notice shall be served by the Authority, which alters the modifications made by this notice, without the agreement in writing of the discharger, during a period of 2 years from the date this notice is served.

Dated this 31<sup>st</sup> day of October 1995

Signed:

  
 Area Environmental Quality Manager.

Dr JOHN STONER Rheolwr Cyffredinol Rhanbarthol / Regional General Manager

Awdurdod Afonydd Cenedlaethol, Rhanbarth Cymru / National Rivers Authority, Welsh Region

Glan Tawe, 154 Ffordd Sant Helen, Abertawe, Gorllewin Morgannwg, SA1 4DF. Ffôn: (01792) 645300, Ffacs: (01792) 648652

Glan Tawe, 154 St. Helens Road, Swansea, West Glamorgan, SA1 4DF. Tel: (01792) 645300, Fax: (01792) 648652



Awdurdod Afonydd Cenedlaethol  
Rhanbarth Cymru

National Rivers Authority  
Welsh Region

**WATER ACT 1989**

Consent No. BP0158001


**Under Section 113 and Schedule 12 of the Water Act 1989 and all other enabling powers the National Rivers Authority hereby gives this**

**C O N S E N T**

**To** : St Mary's Golf Club Ltd  
**Of** : Trallwyn, Llanilid, Pencoed, Mid Glamorgan.  
**For** : A discharge of sewage effluent.  
**InTo** : Land  
**From** : St Mary's Golf Club, Trallwyn, Llanilid, Pencoed, Mid Glamorgan.

**CONDITIONS OF CONSENT**

1. The nature of the effluent shall be biologically treated sewage effluent.
2. Adequate facilities shall be provided so as to enable samples of the treated effluent to be conveniently obtained at grid reference SS9790 8040.
3. The maximum rate of flow discharged to land at any time shall not exceed 0.7 litres per second. All sewage flow rates up to the maximum quoted shall receive biological treatment.
4. The quality of the effluent discharged into land at all flow rates up to the maximum, quoted in Paragraph 3 above, shall not be inferior to the following numerical quality limits (determinands).
  - 4a. The suspended solids concentration (dried at 105 degrees celcius) shall not exceed 30 milligrams per litre.
  - 4b. The BOD (Biochemical Oxygen Demand) concentration determined in the presence of allyl-thiourea shall not exceed 20 milligrams per litre

This Consent is given on: 30 March 1990 on behalf of the Authority  
by:  Divisional Scientist

During the period ending with the: 29 March 1992 the terms of this  
Consent will not be altered without the written agreement of the person  
making this discharge

Cadeirydd Rhanbarthol  
Yr Athro Ron Edwards  
Rheolwr Rhanbarth Cyffredinol  
Dr John Stoner  
Llys Afon  
Hawthorn Rise  
Hwlfordd  
Dyfed, SA61 2BQ  
Ffôn: Hwlfordd (0437) 760081  
Ffôn: (0437) 760081

Regional Chairman  
Professor Ron Edwards  
Regional General Manager  
Dr John Stoner  
Llys Afon  
Hawthorn Rise  
Haverfordwest  
Dyfed, SA61 2BQ  
Tel: Haverfordwest (0437) 760081



Drawing/Plan No. BP0158001

8844  
1.550ha  
3.83

B M 54.52m

Sewage Treatment Works

Pond

8836  
0.065ha  
16

TENNIS COURT

Consent Point A

SAMPLING POINT

Trallwyn

CLUB HOUSE

0032  
3.48ha  
86

9222  
3.541ha  
8.75

9722  
6.11ha  
1.51

55.8m

0051  
5.87ha  
1.45

0046  
0.12ha  
03

54.6m

