


Schedule 6 - Notification

Part B - to be submitted as soon as practicable

Permit Number	BR9383ID	Notification Reference	EP_EX_235
Name of operator	Knauf Insulation Ltd		
Location of Facility	Chemistry Lane, Queensferry, Deeside, Flintshire, CH5 2DA		
Time and date of the detection	10:00 19 th August 2019		

Any more accurate information on the matters for notification under Part A.	Trends of the measurement of particulates at emission point A, cupola stack after the oxidizer, had become elevated and static compared to normal. Initial investigation found the probe to be in an alarm state. Flow was also reading low.
Measures taken, or intended to be taken, to prevent a recurrence of the incident	The Durag probe was checked and cleaned during the plant shut 22 nd August. The probe needed to be turned to have the airflow holes facing into the direction of flow. Dust readings were restored 22 nd August. Flow readings were restored 23 rd August when the pipes to the DP cell were swapped round
Measures taken, or intended to be taken, to rectify, limit or prevent any pollution of the environment which has been or may be caused by the emission	We believe that no permanent harm will result from the incident. The pressure drops at the dust filters and the dust emission results achieved since re-aligning the probe tend to confirm that dust abatement effectiveness was being maintained throughout the period where readings were affected. There is nothing to indicate that an ELV was breached.
The dates of any unauthorised emissions from the facility in the preceding 24 months.	06/09/17, 14/09/17, 16-20/09/17, 26/09/17, 1-3/10/17, 9-11/10/17, 21/10/17, 23/10/17, 31/10/17, 08/12/17, 29/12/17, 09-11/01/18, 24/01/18, 26/03/18, 30/03/18, 17/04/18, 21/04/18, 26-27/04/18, 16/05/18, 11/7/18, 3-4/9/18, 5/9/18, 7/9/18, 9/9/18, 10/9/18, 16/9/18, 15/10/18, 16/10/18, 17/10/18, 19/10/18, 22/10/18, 6/11/18, 13/11/18, 2/1/19, 8/1/19, 9/1/19, 7/2/19, 20/2/19, 12/4/19, 19/4/19, 8/05/19, 12/06/19, 13/6/19, 18/06-17/07/19, 3/07/19, 8/07-17/07/19, 16/07/19, 16-22/8/19

Name*	Graham Jones
Post	Process and Energy Manager
Signature	
Date	27/08/19

* authorised to sign on behalf of Knauf Insulation Ltd