

20-8-19

# Schedule 6 - Notification

Q3 - Point A - ~~CO2~~ Durag probe.  
Particulates.

These pages outline the information that the operator must provide.


Units of measurement used in information supplied under Part A and B requirements shall be appropriate to the circumstances of the emission. Where appropriate, a comparison should be made of actual emissions and authorised emission limits.

If any information is considered commercially confidential, it should be separated from non-confidential information, supplied on a separate sheet and accompanied by an application for commercial confidentiality under the provisions of the EP Regulations.

## Part A

Permit Number	BR9383ID	Notification Reference	EP_EX_235
Name of operator	Knauf Insulation Ltd		
Location of Facility	Chemistry Lane, Queensferry, Deeside, Flintshire, CH5 2DA		
Time and date of the detection	10:00 19 <sup>th</sup> August 2019		


<b>(a) Notification requirements for any malfunction, breakdown or failure of equipment or techniques, accident, or fugitive emission which has caused, is causing or may cause significant pollution</b>	
<b>To be notified within 24 hours of detection</b>	
Date and time of the event	17:00 16 <sup>th</sup> August 2019
Reference or description of the location of the event	Trends of the measurement of particulates at emission point A, cupola stack after the oxidizer, have become elevated and static compared to normal. Initial investigation found the probe to be in an alarm state
Description of where any release into the environment took place	No known release above permitted levels
Substances(s) potentially released	Particulates from Emission point A, Cupola stack after oxidiser
Best estimate of the quantity or rate of release of substances	Plant is operating normally. Emissions should be at normal levels. Process readings at the bag filters indicate normal operation, no sign of holes in filter bags as differential pressures are normal.
Measures taken, or intended to be taken, to stop any emission	Enviro Technology technician is scheduled to investigate and clean the Durag probe during the next plant downtime on 22 <sup>nd</sup> August
Description of the failure or accident.	Suspect that the probe is contaminated affecting the measurement of dust.



<b>(b) Notification requirements for the breach of a limit</b>	
<b>To be notified within 24 hours of detection unless otherwise specified below</b>	
Emission point reference/ source	
Parameter(s)	
Limit	
Measured value and uncertainty	
Date and time of monitoring	
Measures taken, or intended to be taken, to stop the emission	

<b>Time periods for notification following detection of a breach of a limit</b>	
<b>Parameter</b>	<b>Notification period</b>

<b>(c) Notification requirements for the detection of any significant adverse environmental effect</b>	
<b>To be notified within 24 hours of detection</b>	
Description of where the effect on the environment was detected	
Substances(s) detected	
Concentrations of substances detected	
Date of monitoring/sampling	

<b>Name*</b>	G A Jones
<b>Post</b>	Process and Energy Manager
<b>Signature</b>	
<b>Date</b>	20 <sup>th</sup> August 2019

\* authorised to sign on behalf of Knauf Insulation Ltd