

Permit Number : EPR/EP3738NG

Operator: Wepa UK Ltd

Facility: Bridgend Paper Mills

Form Number: Air-1

Reporting of emissions to air for the period from

01-Jan-19

to

31-Dec-19

Emission Point	Substance / Parameter	Emission Limit Value	Reference Period	Result [1]	Test Method [2]	Sample Dates and Times [3]	Uncertainty [4]
A1	Oxides of Nitrogen (NO and NO2 expressed as NO2)	250 mg/m3	Hourly Average	221.7	BS EN 14792	11/01/2019 11.05-13.42	+/-4.2
A1	Sulphur dioxide	50 mg/m3	Hourly Average	2.35	EA MID 21	11/01/2019 11.05-13.43	+/- 0.2
A1	Particulates	10 mg/m3	Hourly Average	1.5	BS EN 13284-1	11/01/2019 11.05-13.44	+/- 0.09
A1	Carbon Monoxide	150 mg/m3	Hourly Average	10.65	BS EN 15058	11/01/2019 11.05-13.45	+/- 0.4
A2	Oxides of Nitrogen (NO and NO2 expressed as NO2)	250 mg/m3	Hourly Average	86.6	BS EN 14792	12/12/2018 15:03 to 16:03	+/- 0.2
A2	Sulphur dioxide	50 mg/m3	Hourly Average	2.9	EA MID 21	12/12/2018 15:03 to 16:04	+/- 0.2
A2	Particulates	10 mg/m3	Hourly Average	2.07	BS EN 13284-1	12/12/2018 15:03 to 16:05	+/- 0.08
A2	Carbon Monoxide	150 mg/m3	Hourly Average	8.7	BS EN 15058	12/12/2018 15:03 to 16:06	+/- 0.2
A4	Oxides of Nitrogen (NO and NO2 expressed as NO2)	40 mg/m3	Hourly Average	37.4	BS EN 14792	12/12/2018 11:30 to 12:30	+/-0.5

The result given is the maximum value (or minimum value in the case of a limit that is expressed as a minimum) obtained during the reporting period, expressed in the same terms as the emission limit value. Where the emission limit is expressed as a range, the result is given as the 'minimum - maximum' measured values.

Where an Internationally recognised standard is used the reference number is given. Where another method that has been agreed with the Environment Agency is used, then the appropriate identifier is given. In other cases the principle technique is used, for example gas chromatography.

For non-continuous measurements the date and time of the sample that produced the result given. For continuous measurements the percentage of the process operating time covered by the result is given.

The uncertainty associated with the quoted result at the 95% confidence interval, unless otherwise stated.

Signed .....  .....

Date ..... 21/12/2020 .....

(Authorised to sign as representative of Operator)