

RELEASES TO AIR

QUARTERLY RETURN

CUMULATIVE ROLLING MALFUNCTION AND BREAKDOWN HOURS (12 MONTH PERIOD)^(a)

Operator: RWE Generation UK

Form: IED BD1

Location: Aberthaw Power Station

Version/date: V.10.9 Dec 2015

Permit/Variation Number: EPR/RP3133LD

Year: 2019 LCP: LCP 283	SO ₂		NO _x		Dust	
Month ^(b)	Malfunction (hours)	Breakdown (hours)	Malfunction (hours)	Breakdown (hours)	Malfunction (hours)	Breakdown (hours)
Jan 2019	0	0	0	0	0	1
Feb 2019	0	0	0	0	0	1
Mar 2019	0	0	0	0	0	1
Apr 2019	0	0	0	0	0	1
May 2019	0	0	0	0	0	1
Jun 2019	0	0	0	0	0	1
Jul 2019	0	0	0	0	0	1
Aug 2019	0	0	0	0	0	1
Sep 2019	0	0	0	0	0	0
Oct 2019	0	0	0	0	0	0
Nov 2019	0	0	0	0	0	0
Dec 2019	0	0	0	0	0	0
Annual cap (hours)	120	120	120	120	120	120

NOTES:


(a) Cumulative rolling malfunction and breakdown hours (12 month period) updated monthly

(b) Insert the relevant months for the preceding 12 month period, e.g., starting with March 2016

(c) Gas turbines with CO abatement only (columns may be deleted)

Signed on behalf of the Operator by:

Date of return:


02 January 2020
NEIL UBBORN