IR/ 20 / 01

PART A

Permit Number	**BM3965IA** (Variation NP3235MQ)
Location of Installation	**Airbus UK**, Chester Road, Broughton, Chester CH4 0DR
Time and date of detection	21/01/2020 @ 11:30

(a) Notification requirements for any malfunction, breakdown or failure of equipment or techniques, accident, or fugitive emission which has caused, is causing or may cause significant pollution	
To be notified within 24hours of detection	
Date and time of the event	
Reference or description of the location of the event	
Description of where any release into the environment took place	
Substance(s) potentially released	
Best estimate of the quantity or rate of release of substances	
Measures taken, or intended to be taken, to stop any emission	
Description of the failure or accident	

(b) Notification requirements for the breach of a limit	
To be notified within 24hours of detection	
Emission point reference / source	CHP-A3 Skin and creep boiler
Parameter(s)	Nox-mg/m3
Limit	200
Measured value and uncertainty	202.11
Date and time of monitoring	04/12/2019
Measures taken, or intended to be taken, to stop the emission	This was a 15 min average value. The average for the full 30 minute sample period was 173.42
Time periods for notification following detection of a breach of limit	
Parameter	**Notification period**

(c) Notification requirements for the detection of any significant adverse environmental effect	
To be notified within 24hours of detection	
Description of where the effect on the environment was detected	
Substance(s) detected	
Concentrations of substances detected	
Date of monitoring / sampling	