

Toyota Motor Manufacturing (UK) Ltd

Burnaston
Derbyshire
East Midlands
DE1 9TA
United Kingdom

Tel 01332 282121
Fax 01332 282801
www.toyotauk.com

TOYOTA

Emma Pierce
Regulatory Officer
Natural Resources Wales
Chester Road
Buckley
Flintshire, CH7 3AJ

Ref: Environmental Permit EPR/BK6483IU

Date: 28/01/2020

Dear Emma,

With reference to permit improvement condition 9.22 and our subsequent response on 24/04/2010, I attach the 2019 Quarter 4 report for monitoring of our Waste Water Treatment Plant emissions. The report compares sample analysis by Toyota and a UKAS accredited lab, using methods based on TGN M18.

If you have any queries, please do not hesitate to contact me.

Yours sincerely,



Keith Martin
Principal Engineer
Facilities and Environment

Enc: Reporting Form "Sewer2/280709A" (Q4)

Permit Number: EPR/BK6483IU/V003
Facility: Deeside engine Casting

Operator: Toyota Motor Manufacturing (UK) Ltd
Form Number: Sewer2 / 280709A

Reporting of emissions to sewer for				Q4 Oct - Dec 2019		TMUK		UKAS Accredited Lab.	
Emission Point	Substance / Parameter	ELV	Reference Period	Sample Date	Test Method	Result	Test Method	Result	Uncertainty
S1	pH	5 - 10	Daily Composite Sample	25/10/2019	Laboratory bench pH probe.	7.24	Based on "The Measurement of Electrical Conductivity and Laboratory Determination of the pH Value of Natural, Treated and Wastewaters 1978".	7.1	10.00%
S1	Total Suspended Solids	200 mg/l	Daily Composite Sample	25/10/2019	Internal Method: Filter Paper + balance	36.0 mg/l	Based on "Suspended, Settleable and Total Dissolved Solids in Waters and Effluents 1980."	49.0 mg/l	10.00%
S1	COD	1500 mg/l	Daily Composite Sample	25/10/2019	Internal Titration Method	304.0 mg/l	Dichromate oxidation / digestion.	311.0 mg/l	5.00%
S1	Total Hydrocarbon Oil	150 mg/l	Daily Composite Sample	25/10/2019	Internal Gravimetric Method	0.0 mg/l	Solvent extract of the sample / GCFID	0.78 mg/l	15.00%
S1	Sulphate	1000 mg/l	Daily Composite Sample	25/10/2019	Internal Method AA Spectrophotometer	480.0 mg/l	Determination by ICPOES.	427 mg/l	5.00%
S1	Copper	1 mg/l	Daily Composite Sample	25/10/2019	Internal Method AA Spectrophotometer	0.11 mg/l	Determination by ICPMS	0.07 mg/l	5.00%
S1	Zinc	2 mg/l	Daily Composite Sample	25/10/2019	Internal Method AA Spectrophotometer	0.1 mg/l	Determination by ICPMS	0.205 mg/l	5.00%
S1	Lead	1 mg/l	Daily Composite Sample	25/10/2019	Internal Method AA Spectrophotometer	0.1 mg/l	Determination by ICPMS	<0.005 mg/l	5.00%
S1	Nickel	1 mg/l	Daily Composite Sample	25/10/2019	Internal Method AA Spectrophotometer	0.1 mg/l	Determination by ICPMS	0.007 mg/l	5.00%

Signed:  Date: 25/01/20
(authorised to sign on behalf of operator)