


Schedule 6 - Notification

Part B - to be submitted as soon as practicable

Permit Number	BR9383ID	Notification Reference	EP_EX_240
Name of operator	Knauf Insulation Ltd		
Location of Facility	Chemistry Lane, Queensferry, Deeside, Flintshire, CH5 2DA		
Time and date of the detection	08:00 hours on 19th September 2019		

Any more accurate information on the matters for notification under Part A.	The flow dropped off at 02:00 hours and a stable flow returned at 08:15 hours.
Measures taken, or intended to be taken, to prevent a recurrence of the incident	The actuator valve was replaced and the automated system re-commenced.
Measures taken, or intended to be taken, to rectify, limit or prevent any pollution of the environment which has been or may be caused by the emission	It is believed that no permanent harm will result from the incident.
The dates of any unauthorised emissions from the facility in the preceding 24 months.	08/12/17, 29/12/17, 09-11/01/18, 24/01/18, 06-06/02/18, 26/03/18, 30/03/18, 17/04/18, 21/04/18, 26/04/18, 27/04/18, 16/05/18, 17/05/18, 24/05/18, 11/07/18, 03-04/09/18, 05/09/18, 07/09/18, 09/09/18, 10/09/18, 16/09/18, 15/10/18, 16/10/18, 17/10/18, 18/10/18, 19/10/18, 22/10/18, 6/11/18, 13/11/18, 02/01/19, 08/01/19, 10/01/19, 07/02/19, 20/02/19, 12/04/19, 19/04/19, 08/05/19, 12/06/19, 13/06/19, 18/06/19, 04/07/19, 08/07/19, 16/07/19, 06/08/19, 08/08/19, 16/08/19, 07-09/09/19, 16/09/19.

Name*	C. Keouski
Post	Environmental Manager
Signature	
Date	8 th January 2020

* authorised to sign on behalf of Knauf Insulation Ltd