

Confirmation data sheet

Manufacturer: **ceATec Engineering GmbH**
4906 Eberschwang, Antiesen 15, Austria

Customer: **Kronospan Ltd Chirk**
LL14 5NT, Wrexham, UK

Project: **A-204/13, Chip Preparation Building (former Palmann)**

Designation: **Line filter**
Type: **CDRW-12-05-4500-06**
Serial number: **CDRW012/13**

Filter area: **839 m²**
Filter loads per surface: **114 m³/m²/h**
Filter medium: **PE 520 LO**

Material: **Wood dust**
Air volume: **96.000 m³/h**
Temperature: **20°C**

Outlet gas: **<5mg/Nm³**

Remark: **The filter is just to separate solid material**

Eberschwang, 03.12.2019

ceATec
CLEAN ENVIRONMENT AIR TECHNOLOGIES
ceATEC ENGINEERING GmbH
Antiesen 15, 4906 Eberschwang, Austria
P +43 (0) 7472 2000-0, F +43 (0) 7472 2000-100, E office@ce.at, www.ceATec.at
Peter Pichler
Managing Director