

RELEASES TO AIR
RETURN OF DISCONTINUOUS MONITORING RESULTS
Operator: Dow Silicones UK Ltd

Location: Barry Cogeneration Plant

Permit/Variation Number: EPR/JP3632ZH/V002

Form: IED PM1

Version: V.11 Mar 2016

Year - 2019	LCP 60 (A1 & A3 HR-001A & B)				
Six months to -31/12/19					
Measurement approach	NO _x	SO ₂	CO	Hg	Dust
Time					
Date					
Measurement 1 (mg/m ³) ^(b)					
Measurement 2 (mg/m ³) ^(b)					
Measurement 3 (mg/m ³) ^(b)					
Alternative approach ^(c)					
Method ^(d)		FS			DF
Calculation (mg/m ³)		0.24			0
Operational data ^(a)					
Load (%MCR)					
Fuel 1 Natural Gas (%)		100			100
Fuel 2 name (%)					
Fuel 3 name (%)					
Daily Emission Limit Value (mg/m ³)					

NOTES:

(a) Operational data for the test period (measurement approach) or the six month period to date (Alternative approach)

(b) Reference conditions for mg/m³ are 15% O₂ CCGT, 6% O₂ solid fuels, 3% O₂ for oil and gas, dry, 0°C, 101.325 kPa

(c) Alternative approach to discontinuous monitoring by agreement with the Competent Authority

(d) Use abbreviation: NF for agreed NO_x factor, FS for fuel sulphur content, CS for agreed CO factor, DF for agreed dust factor

Signed on behalf of the Operator by:

Judith Sartor, Environmental Specialist


Date of return:

30th January 2020

RELEASES TO AIR
RETURN OF DISCONTINUOUS MONITORING RESULTS

Operator: Dow Silicones UK Ltd
 Location: Barry Cogeneration Plant
 Permit/Variation Number: EPR/JP3632ZH/V002

Form: IED PM1
 Version: V.11 Mar 2016

Year - 2019	LCP 60 (A2 FB-001)				
Six months to -31/12/19					
Measurement approach	NO _x	SO ₂	CO	Hg	Dust
Time					
Date					
Measurement 1 (mg/m ³) ^(b)					
Measurement 2 (mg/m ³) ^(b)					
Measurement 3 (mg/m ³) ^(b)					
Alternative approach ^(c)					
Method ^(d)		FS			DF
Calculation (mg/m ³)		0.72			0
Operational data ^(a)					
Load (%MCR)					
Fuel 1 Natural Gas (%)		100			100
Fuel 2 name (%)					
Fuel 3 name (%)					
Daily Emission Limit Value (mg/m ³)					

NOTES:

- (a) Operational data for the test period (measurement approach) or the six month period to date (Alternative approach)
 (b) Reference conditions for mg/m³ are 15% O₂ CCGT, 6% O₂ solid fuels, 3% O₂ for oil and gas, dry, 0°C, 101.325 kPa
 (c) Alternative approach to discontinuous monitoring by agreement with the Competent Authority
 (d) Use abbreviation: NF for agreed NO_x factor, FS for fuel sulphur content, CS for agreed CO factor, DF for agreed dust factor

Signed on behalf of the Operator by: Judith Sartor, Environmental Specialist



Date of return: 30th January 2020