

SCHEDULE 5
NOTIFICATION
Part A

Permit Number	EPR/EP3830GH
Name of Operator	LIBERTY STEEL NEWPORT LIMITED
Location of Facility	CORPORATION ROAD NEWPORT S WALES NP19 4XE
Time and Date of Detection	04/12/2019 1pm

(a) Notification requirements for any activity that gives rise to an incident or accident which significantly affects or may significantly affect the environment

To be notified immediately

Date and time of event	
Reference or description of the location of the event	
Description of where any release into the environment took place	
Substance(s) potentially released	
Best estimate of quantity or rate of release of substances	
Measures taken or intended to be taken to stop any emission	
Description of the failure or accident	

(b) Notification requirements for the breach of a permit condition

To be notified immediately


Emission point reference source	W1
Parameters	Ph
Limit	10
Measured Value	10.2
Date and time of Monitoring	04/12/2019 at 13:00
Measures to be taken or intended to be taken to stop the emission	Initial monthly monitoring and analysis of trends

(c) In the event of a breach of permit condition which poses an immediate danger to human health or threatens to cause an immediate significant adverse effect on the environment

To be notified immediately

Description of where the effect on the environment was detected	
Substance(s) detected	
Concentration of substances detected	
Date of monitoring/sampling	

SCHEDULE 5**NOTIFICATION****Part B - To be submitted as soon as practicable**

Any more accurate information on the matter for notification in Part A	The analysis of these samples from W1 was received by Liberty Steel Newport Ltd on 14th January 2020
Measures taken, or intended to be taken to prevent a recurrence of the incident	See Below
Measure taken or intended to be taken to rectify limit or prevent any pollution of the environment which has been or may be caused by the emission	Communication of incidences is reported along the management chain to Director level and an annual contract to undergo monthly water sampling is in place (reviewed and changed from weekly by the enforcing authority) Each monthly exceedence will be reported to NRW. The current incumbent has given consideration to installing a permanent water treatment facility however given the overall pleasing results for the year the environmental benefit in pursuing this is negligible. It is generally agreed that these adverse results are related to run off from stockpiled slag which is the subject of improvement on commencement of melting operations within the Environmental Permit.
The dates of any unauthorised emissions from the facility in the preceeding 24 months	4th December 2019 PH 10.2 (Max 10)
Name	Richard Steed
Post	Acting Environmental Manager
Signature	
Date	30th January 2020