

**RELEASES TO AIR
RETURN OF DISCONTINUOUS MONITORING RESULTS**

Location: Baglan Energy Park, Seaway
Parade, Port Talbot, SA12 7GE
Permit/Variation Number:EPR/BJ7891IT

Form:
Version:

ESI/05
V.10.6 Oct 2015

Year: 2020	LCP 15 LM2500 Gas Turbine Emission point A2 CCGT				
Six months to - 30/06/2020					
Measurement approach	NO _x	SO ₂	CO	Hg	Dust
Time	no run	no run	no run		no run
Date					
Measurement 1 (mg/m ³) ^(b)					
Measurement 2 (mg/m ³) ^(b)					
Measurement 3 (mg/m ³) ^(b)					
Alternative approach ^(c)					
Method ^(d)		FS			DF
Calculation (mg/m ³)					
Operational data ^(a)					
Load (%MCR)				N/A	
Fuel 1 name (%)					
Fuel 2 name (%)					
Fuel 3 name (%)					
Daily Emission Limit Value					
(mg/m ³)	105	N/A	110	N/A	N/A

NOTES:

- (a) Operational data for the test period (measurement approach) or the six month period to date (Alternative approach)
- (b) Reference conditions for mg/m³ are 15% O₂ CCGT, 6% O₂ solid fuels, 3% O₂ for oil and gas, dry, 0°C, 101.325 kPa
- (c) Alternative approach to discontinuous monitoring by agreement with the Competent Authority
- (d) Use abbreviation: NF for agreed NO_x factor, FS for fuel sulphur content, CS for agreed CO factor, DF for agreed dust factor

Signed on behalf of the Operator by:

Jayne Mason

Date of return:

16/07/2020