

CONTINUOUS MEASUREMENT SYSTEMS INVALIDATION LOG**QUARTERLY RETURN****Year: 2020****Operator: Baglan Operations Limited****Form: IED CEM1****Monitor positioned on release point/LCP No: A1 / LCP15****Version/Date: V 3.1 31 Dec 2016****Permit/Variation Number: EPR/BJ7891IT****9H**

Date	Period of invalidation (hours)	Invalidated days in month	Comments
No invalid data recorded			

NOTES:

(a) Compliance in Chapter III of the IED is on the basis of validated hourly averages, measured by continuous monitors (except where discontinuous exemption applies). And confidence intervals are incorporated to convert the measured hourly value into a validated measurement for the purpose of compliance assessment. However, any day in which more than 3 hourly average values are invalid (due to malfunction or maintenance of the continuous measurement system) shall be invalidated for the purpose of compliance assessment. If more than 10 days are invalid over a year the operator shall, within 28 days of becoming aware of this fact, review the causes of the invalidations and submit to the Environment Agency for approval, proposals for measures to improve the reliability of the continuous measurement systems, including a timetable for the implementation of those measures; and implement the approved proposals.

Signed on behalf of the Operator by: Jayne Mason

Date of return: 16/07/2020