

Permit Number: EPR/BV9683IH

Operator: Dunbia (Wales)

Facility: Teify Park Abattoir and Meat Processing Plant

Form Number: Q2 Water 23/07/2020


Reporting of emissions to water (other than to sewer) and land for the period from 01/04/2020 to 30/06/2020

Emission Point	Substance / Parameter	Emission Limit Value	Reference Period	Result ⁽¹⁾	Test Method ⁽²⁾	Sample Date and Times ⁽³⁾	Uncertainty ⁽⁴⁾
W2	Total suspended solids	50 mg/l	24 hour flow	7.45 mg/l	HMSO ISBN 011751957X	16 th June 2020	13.4%
W2	pH	6-9	24 hour flow	7.7 – Min 8.3 – Max	On-line pH electrode/ meter	26 th May 2020 28 th April 2020	9%
W2	BOD	30 mg/l	24 hour flow	4.16 mg/l	BS 6068-250:1995	16 th June 2020	16%
W2	Ammonia	10mg/l	24 hour flow	0.74 mg/l	BSENISO 11732:1997	09 th June 2020	6.6%
W2	Volume/flow rate	630m ³ /day	24 hour flow	462 m ³ /day - Max	On-line flow meter	18 th June 2020	-

The result given is the maximum value (or the minimum value in the case of a limit that is expressed as a minimum) obtained during the reporting period, expressed in the same terms as the emission limit value. Where the emission limit value is expressed as a range, the result is given as the 'minimum – maximum' measured values.

Where an internationally recognised standard test method is used the reference number is given. Where another method that has been formally agreed with Natural Resources Wales is used, then the appropriate identifier is given. In other cases, the principal technique is stated, for example gas chromatography.

For non-continuous measurements the date and time of the sample that produced the result is given. For continuous measurements the percentage of the process operating time covered by the result is given.

Signed  (Authorised to sign as representative of Operator)

Date... 24/07/2020

FORM 4.2.5 – Quarterly Waste Effluent inputs to ETP

Teifi Park Abattoir and Meat processing plant BV9683IH/V003

This is the only waste type permitted to be received.


Blank/Nil returns are required

Quarter	EWG Waste Code	Tonnes / m ³ received	Tonnes / m ³ removed
Q1 Jan -Mar	02 02 01	0 m3	0 m3
Q2 Apr-June	02 02 01	0 m3	0 m3
Q3 July – Sept			
Q4 Oct - Dec			

Notes - Permit condition 4.2.5

‘Within one month of the end of each quarter, the Operator shall submit to Natural Resources Wales using the form made available (this form) for the purpose the information specified on the form relating to the site and the waste accepted and removed from it during the previous quarter’.

Table 2.2.1 – the annual throughput of the effluent treatment plant shall not exceed 32,500 tonnes per year. Note – this applies to the input received from the Company’s Nantmel site.

Signed.....

Position.....Environmental Officer

Date.....24/07/2020