

Reporting of Emission to Surface Water for the period from 1st July to 31st December 2019.

Operator : RWE Generation UK plc

Form: Water1

Location: Aberthaw Quarry Ash Disposal Site

Permit/Variation Number: BP3339BH

Emission point	Substance/ Parameter	Emission Limit Value	Result ^[1]	Test Method ^[2]	Sample Date and Times ^[3]	Accreditation/ Certification ^[4]	Uncertainty ^[5]
SW12	Aluminium, Dissolved		<10 µg/l		29/08/2019	Sampling Amec/Testing EA NLS	
	Antimony, Dissolved		<1 µg/l				
	Arsenic Dissolved		1.7 µg/l				
	Boron, Dissolved		1100 µg/l				
	Cadmium, Dissolved		<2 µg/l				
	Calcium, Dissolved		310 mg/l				
	Chromium, Dissolved		4.3 µg/l				
	Copper, Dissolved		<3 µg/l				
	Iron, Dissolved		1.2 µg/l				
	Magnesium, Dissolved		54 mg/l				
	Manganese, Dissolved		<10 µg/l				
	Molybdenum, Dissolved		2900 µg/l				
	Nickel, Dissolved		5.3 µg/l				
	Selenium Dissolved		0 µg/l				
	Vanadium, Dissolved		<2 µg/l				
	Mercury, Dissolved		<0.01 µg/l				
	Total Alkalinity as CaCO3		60 mg/l				
	Electrical Conductivity at 20C		3900 mS/cm				
	Potassium, Dissolved		48 mg/l				
	Sodium, Dissolved		470 mg/l				
	Sulphate, Dissolved		700 mg/l				
	Total Oxidised Nitrogen		14 mg/l				
	Chloride		880 mg/l				
	Fluoride		0.2 mg/l				
	Ammoniacal Nitrogen		0.11 mg/l				
	Total Organic Carbon		6.1 mg/l				
	Nitrate		0.48 mg/l				

Emission point	Substance/ Parameter	Emission Limit Value	Result ^[1]	Test Method ^[2]	Sample Date and Times ^[3]	Accreditation/ Certification ^[4]	Uncertainty ^[5]
	pH		8.4 pH Units				

Emission point	Substance/ Parameter	Emission Limit Value	Result ^[1]	Test Method ^[2]	Sample Date and Times ^[3]	Accreditation/ Certification ^[4]	Uncertainty ^[5]
SW12	Aluminium, Dissolved		<10 µg/l		04/12/2019	Sampling Amec/Testing EA NLS	
	Antimony, Dissolved		<1 µg/l				
	Arsenic Dissolved		1.2 µg/l				
	Boron, Dissolved		500 µg/l				
	Cadmium, Dissolved		<0.1 µg/l				
	Calcium, Dissolved		190 mg/l				
	Chromium, Dissolved		3.5 µg/l				
	Copper, Dissolved		1 µg/l				
	Iron, Dissolved		<30 µg/l				
	Magnesium, Dissolved		32 mg/l				
	Manganese, Dissolved		<10 µg/l				
	Molybdenum, Dissolved		1100 µg/l				
	Nickel, Dissolved		3.8 µg/l				
	Selenium Dissolved		0 µg/l				
	Vanadium, Dissolved		2.3 µg/l				
	Mercury, Dissolved		<0.01 µg/l				
	Total Alkalinity as CaCO3		160 mg/l				
	Electrical Conductivity at 20C		2000 mS/cm				
	Potassium, Dissolved		26 mg/l				
	Sodium, Dissolved		210 mg/l				
	Sulphate, Dissolved		400 mg/l				
	Total Oxidised Nitrogen		0.26 mg/l				
	Chloride		350 mg/l				
	Fluoride		0.29 mg/l				
	Ammoniacal Nitrogen		0.26 mg/l				
	Total Organic Carbon		2.6 mg/l				
	Nitrate		9.1 mg/l				
	pH		8.1 pH Units				

Emission point	Substance/ Parameter	Emission Limit Value	Result ^[1]	Test Method ^[2]	Sample Date and Times ^[3]	Accreditation/ Certification ^[4]	Uncertainty ^[5]
Settlement Ponds	Aluminium, Dissolved		<50 µg/l		31/07/2019	Sampling Station/Testing EA NLS	
	Antimony, Dissolved		<1 µg/l				
	Arsenic Dissolved	50	2.90 µg/l				
	Boron, Dissolved	2000	1610.00 µg/l				
	Cadmium, Dissolved	5	<5 µg/l				
	Calcium, Dissolved		480.00 mg/l				
	Chromium, Dissolved	50	17.40 µg/l				
	Copper, Dissolved		8.10 µg/l				
	Iron, Dissolved		<30 µg/l				
	Magnesium, Dissolved		66.20 mg/l				
	Manganese, Dissolved		<10 µg/l				
	Molybdenum, Dissolved		5500.00 µg/l				
	Nickel, Dissolved		9.13 µg/l				
	Selenium Dissolved		51.00 µg/l				
	Vanadium, Dissolved	60	7.32 µg/l				
	Mercury, Dissolved		<0.01 µg/l				
	Total Alkalinity as CaCO3		79.00 mg/l				
	Electrical Conductivity at 20C		6120.00 mS/cm				
	Potassium, Dissolved		78.30 mg/l				
	Sodium, Dissolved		791.00 mg/l				
	Sulphate, Dissolved	400	1130.00 mg/l				
	Total Oxidised Nitrogen		41.50 mg/l				
	Chloride		1450.00 mg/l				
	Fluoride		0.16 mg/l				
	Ammoniacal Nitrogen	0.6	4.38 mg/l				
	Total Organic Carbon		4.20 mg/l				
	Nitrate		0.00 mg/l				
	pH	<9	8.15 pH Units				

Emission point	Substance/ Parameter	Emission Limit Value	Result ^[1]	Test Method ^[2]	Sample Date and Times ^[3]	Accreditation/ Certification ^[4]	Uncertainty ^[5]
Settlement Ponds	Aluminium, Dissolved		17.00 µg/l		02/09/2019	Sampling Station/Testing EA NLS	
	Antimony, Dissolved		<2 µg/l				
	Arsenic Dissolved	50	2.70 µg/l				
	Boron, Dissolved	2000	1600.00 µg/l				
	Cadmium, Dissolved	5	<5 µg/l				
	Calcium, Dissolved		470.00 mg/l				
	Chromium, Dissolved	50	15.00 µg/l				
	Copper, Dissolved		5.60 µg/l				
	Iron, Dissolved		<30 µg/l				
	Magnesium, Dissolved		60.00 mg/l				
	Manganese, Dissolved		<10 µg/l				
	Molybdenum, Dissolved		5400.00 µg/l				
	Nickel, Dissolved		12.00 µg/l				
	Selenium Dissolved		48.00 µg/l				
	Vanadium, Dissolved	60	6.40 µg/l				
	Mercury, Dissolved		<0.01 µg/l				
	Total Alkalinity as CaCO3		95.00 mg/l				
	Electrical Conductivity at 20C		<0.01 mS/cm				
	Potassium, Dissolved		80.00 mg/l				
	Sodium, Dissolved		840.00 mg/l				
	Sulphate, Dissolved	400	1000.00 mg/l				
	Total Oxidised Nitrogen		41.00 mg/l				
	Chloride		1500.00 mg/l				
	Fluoride		0.16 mg/l				
	Ammoniacal Nitrogen	0.6	3.00 mg/l				
	Total Organic Carbon		2.80 mg/l				
	Nitrate		0.00 mg/l				
	pH	<9	8.20 pH Units				

Emission point	Substance/ Parameter	Emission Limit Value	Result ^[1]	Test Method ^[2]	Sample Date and Times ^[3]	Accreditation/ Certification ^[4]	Uncertainty ^[5]
Settlement Ponds	Aluminium, Dissolved		21.00 µg/l		01/10/2019	Sampling Station/Testing EA NLS	
	Antimony, Dissolved		<1 µg/l				
	Arsenic Dissolved	50	3.60 µg/l				
	Boron, Dissolved	2000	1200.00 µg/l				
	Cadmium, Dissolved	5	<5 µg/l				
	Calcium, Dissolved		390.00 mg/l				
	Chromium, Dissolved	50	13.00 µg/l				
	Copper, Dissolved		6.90 µg/l				
	Iron, Dissolved		<30 µg/l				
	Magnesium, Dissolved		47.00 mg/l				
	Manganese, Dissolved		<10 µg/l				
	Molybdenum, Dissolved		3700.00 µg/l				
	Nickel, Dissolved		10.00 µg/l				
	Selenium Dissolved		39.00 µg/l				
	Vanadium, Dissolved	60	8.20 µg/l				
	Mercury, Dissolved		<0.01 µg/l				
	Total Alkalinity as CaCO3		140.00 mg/l				
	Electrical Conductivity at 20C		4900.00 mS/cm				
	Potassium, Dissolved		65.00 mg/l				
	Sodium, Dissolved		660.00 mg/l				
	Sulphate, Dissolved	400	700.00 mg/l				
	Total Oxidised Nitrogen		31.00 mg/l				
	Chloride		1200.00 mg/l				
	Fluoride		0.15 mg/l				
	Ammoniacal Nitrogen	0.6	3.40 mg/l				
	Total Organic Carbon		2.60 mg/l				
	Nitrate		0.00 mg/l				
	pH	<9	8.00 pH Units				

Emission point	Substance/ Parameter	Emission Limit Value	Result ^[1]	Test Method ^[2]	Sample Date and Times ^[3]	Accreditation/ Certification ^[4]	Uncertainty ^[5]
Settlement Ponds	Aluminium, Dissolved		10.00 µg/l		07/11/2019	Sampling Station/Testing EA NLS	
	Antimony, Dissolved		<1 µg/l				
	Arsenic Dissolved	50	2.30 µg/l				
	Boron, Dissolved	2000	680.00 µg/l				
	Cadmium, Dissolved	5	<2 µg/l				
	Calcium, Dissolved		220.00 mg/l				
	Chromium, Dissolved	50	7.20 µg/l				
	Copper, Dissolved		9.20 µg/l				
	Iron, Dissolved		<30 µg/l				
	Magnesium, Dissolved		33.00 mg/l				
	Manganese, Dissolved		<10 µg/l				
	Molybdenum, Dissolved		1600.00 µg/l				
	Nickel, Dissolved		8.80 µg/l				
	Selenium Dissolved		17.00 µg/l				
	Vanadium, Dissolved	60	4.60 µg/l				
	Mercury, Dissolved		0.02 µg/l				
	Total Alkalinity as CaCO3		210.00 mg/l				
	Electrical Conductivity at 20C		2400.00 mS/cm				
	Potassium, Dissolved		33.00 mg/l				
	Sodium, Dissolved		290.00 mg/l				
	Sulphate, Dissolved	400	400.00 mg/l				
	Total Oxidised Nitrogen		16.00 mg/l				
	Chloride		480.00 mg/l				
	Fluoride		0.19 mg/l				
	Ammoniacal Nitrogen	0.6	1.70 mg/l				
	Total Organic Carbon		1.90 mg/l				
	Nitrate		0.00 mg/l				
	pH	<9	8.10 pH Units				

Emission point	Substance/ Parameter	Emission Limit Value	Result ^[1]	Test Method ^[2]	Sample Date and Times ^[3]	Accreditation/ Certification ^[4]	Uncertainty ^[5]
Settlement Ponds	Aluminium, Dissolved		<2 µg/l		10/12/2019	Sampling Station/Testing EA NLS	
	Antimony, Dissolved		<1 µg/l				
	Arsenic Dissolved	50	2 µg/l				
	Boron, Dissolved	2000	640 µg/l				
	Cadmium, Dissolved	5	<2 µg/l				
	Calcium, Dissolved		210 mg/l				
	Chromium, Dissolved	50	10 µg/l				
	Copper, Dissolved		3 µg/l				
	Iron, Dissolved		<30 µg/l				
	Magnesium, Dissolved		33 mg/l				
	Manganese, Dissolved		<10 µg/l				
	Molybdenum, Dissolved		1700 µg/l				
	Nickel, Dissolved		8 µg/l				
	Selenium Dissolved		19 µg/l				
	Vanadium, Dissolved	60	5 µg/l				
	Mercury, Dissolved		<0.01 µg/l				
	Total Alkalinity as CaCO3		190 mg/l				
	Electrical Conductivity at 20C		2300 mS/cm				
	Potassium, Dissolved		32 mg/l				
	Sodium, Dissolved		270 mg/l				
	Sulphate, Dissolved	400	390 mg/l				
	Total Oxidised Nitrogen		19 mg/l				
	Chloride		430 mg/l				
	Fluoride		0 mg/l				
	Ammoniacal Nitrogen	0.6	2 mg/l				
	Total Organic Carbon		2 mg/l				
	Nitrate		19 mg/l				
	pH	<9	8 pH Units				

Emission point	Substance/ Parameter	Emission Limit Value	Result ^[1]	Test Method ^[2]	Sample Date and Times ^[3]	Accreditation/ Certification ^[4]	Uncertainty ^[5]
Settlement Ponds	Aluminium, Dissolved		13 µg/l		19/12/2019	Sampling Station/Testing EA NLS	
	Antimony, Dissolved		<1 µg/l				
	Arsenic Dissolved	50	2.1 µg/l				
	Boron, Dissolved	2000	740 µg/l				
	Cadmium, Dissolved	5	<5 µg/l				
	Calcium, Dissolved		250 mg/l				
	Chromium, Dissolved	50	13 µg/l				
	Copper, Dissolved		2.9 µg/l				
	Iron, Dissolved		<30 µg/l				
	Magnesium, Dissolved		36 mg/l				
	Manganese, Dissolved		21 µg/l				
	Molybdenum, Dissolved		2000 µg/l				
	Nickel, Dissolved		9.4 µg/l				
	Selenium Dissolved		24 µg/l				
	Vanadium, Dissolved	60	4.7 µg/l				
	Mercury, Dissolved		<0.01 µg/l				
	Total Alkalinity as CaCO3		230 mg/l				
	Electrical Conductivity at 20C		2700 mS/cm				
	Potassium, Dissolved		36 mg/l				
	Sodium, Dissolved		290 mg/l				
	Sulphate, Dissolved	400	460 mg/l				
	Total Oxidised Nitrogen		24 mg/l				
	Chloride		500 mg/l				
	Fluoride		0.18 mg/l				
	Ammoniacal Nitrogen	0.6	2.70 mg/l				
	Total Organic Carbon		1.4 mg/l				
	Nitrate		24 mg/l				
	pH	<9	8.00 pH Units				

Emission point	Substance/ Parameter	Emission Limit Value	Result ^[1]	Test Method ^[2]	Sample Date and Times ^[3]	Accreditation/ Certification ^[4]	Uncertainty ^[5]
DP2	Aluminium, Dissolved		<50 µg/l		31/07/2019	Sampling Station/Testing EA NLS	
	Antimony, Dissolved		<1 µg/l				
	Arsenic Dissolved		2.2 µg/l				
	Boron, Dissolved		1380 µg/l				
	Cadmium, Dissolved		<5 µg/l				
	Calcium, Dissolved		549 mg/l				
	Chromium, Dissolved		12.2 µg/l				
	Copper, Dissolved		<5 µg/l				
	Iron, Dissolved		<30 µg/l				
	Magnesium, Dissolved		54.5 mg/l				
	Manganese, Dissolved		119 µg/l				
	Molybdenum, Dissolved		5230 µg/l				
	Nickel, Dissolved		14.9 µg/l				
	Selenium Dissolved		50 µg/l				
	Vanadium, Dissolved		5.05 µg/l				
	Mercury, Dissolved		<0.01 µg/l				
	Total Alkalinity as CaCO3		231 mg/l				
	Electrical Conductivity at 20C		6690 mS/cm				
	Potassium, Dissolved		80.9 mg/l				
	Sodium, Dissolved		888 mg/l				
	Sulphate, Dissolved		1090 mg/l				
	Total Oxidised Nitrogen		42.1 mg/l				
	Chloride		1630 mg/l				
	Fluoride		0.185 mg/l				
	Ammoniacal Nitrogen		11.6 mg/l				
	Total Organic Carbon		1.8 mg/l				
	Nitrate		40 mg/l				
	pH		7.23 pH Units				

Emission point	Substance/ Parameter	Emission Limit Value	Result ^[1]	Test Method ^[2]	Sample Date and Times ^[3]	Accreditation/ Certification ^[4]	Uncertainty ^[5]
DP2	Aluminium, Dissolved		29 µg/l		02/09/2019	Sampling Station/Testing EA NLS	
	Antimony, Dissolved		<2 µg/l				
	Arsenic Dissolved		3.2 µg/l				
	Boron, Dissolved		1700 µg/l				
	Cadmium, Dissolved		<5 µg/l				
	Calcium, Dissolved		490 mg/l				
	Chromium, Dissolved		20 µg/l				
	Copper, Dissolved		5.6 µg/l				
	Iron, Dissolved		<30 µg/l				
	Magnesium, Dissolved		59 mg/l				
	Manganese, Dissolved		100 µg/l				
	Molybdenum, Dissolved		5700 µg/l				
	Nickel, Dissolved		17 µg/l				
	Selenium Dissolved		52 µg/l				
	Vanadium, Dissolved		8.9 µg/l				
	Mercury, Dissolved		<0.01 µg/l				
	Total Alkalinity as CaCO3		260 mg/l				
	Electrical Conductivity at 20C		6000 mS/cm				
	Potassium, Dissolved		76 mg/l				
	Sodium, Dissolved		830 mg/l				
	Sulphate, Dissolved		960 mg/l				
	Total Oxidised Nitrogen		46 mg/l				
	Chloride		1400 mg/l				
	Fluoride		0.2 mg/l				
	Ammoniacal Nitrogen		10 mg/l				
	Total Organic Carbon		5.1 mg/l				
	Nitrate		0 mg/l				
	pH		7.00 pH Units				

Emission point	Substance/ Parameter	Emission Limit Value	Result ^[1]	Test Method ^[2]	Sample Date and Times ^[3]	Accreditation/ Certification ^[4]	Uncertainty ^[5]
DP2	Aluminium, Dissolved		15 µg/l		01/10/2019	Sampling Station/Testing EA NLS	
	Antimony, Dissolved		<1 µg/l				
	Arsenic Dissolved		3 µg/l				
	Boron, Dissolved		1200 µg/l				
	Cadmium, Dissolved		<5 µg/l				
	Calcium, Dissolved		420 mg/l				
	Chromium, Dissolved		8.9 µg/l				
	Copper, Dissolved		11 µg/l				
	Iron, Dissolved		<30 µg/l				
	Magnesium, Dissolved		54 mg/l				
	Manganese, Dissolved		66 µg/l				
	Molybdenum, Dissolved		3500 µg/l				
	Nickel, Dissolved		14 µg/l				
	Selenium Dissolved		640 µg/l				
	Vanadium, Dissolved		5.6 µg/l				
	Mercury, Dissolved		<0.01 µg/l				
	Total Alkalinity as CaCO3		210 mg/l				
	Electrical Conductivity at 20C		4900 mS/cm				
	Potassium, Dissolved		59 mg/l				
	Sodium, Dissolved		640 mg/l				
	Sulphate, Dissolved		770 mg/l				
	Total Oxidised Nitrogen		31 mg/l				
	Chloride		1100 mg/l				
	Fluoride		0.19 mg/l				
	Ammoniacal Nitrogen		5.8 mg/l				
	Total Organic Carbon		0 mg/l				
	Nitrate		0 mg/l				
	pH		7.92 pH Units				

Emission point	Substance/ Parameter	Emission Limit Value	Result ^[1]	Test Method ^[2]	Sample Date and Times ^[3]	Accreditation/ Certification ^[4]	Uncertainty ^[5]
DP2	Aluminium, Dissolved		<10 µg/l		07/11/2019	Sampling Station/Testing EA NLS	
	Antimony, Dissolved		<1 µg/l				
	Arsenic Dissolved		<1 µg/l				
	Boron, Dissolved		340 µg/l				
	Cadmium, Dissolved		<1 µg/l				
	Calcium, Dissolved		190 mg/l				
	Chromium, Dissolved		1.9 µg/l				
	Copper, Dissolved		3.4 µg/l				
	Iron, Dissolved		<30 µg/l				
	Magnesium, Dissolved		30 mg/l				
	Manganese, Dissolved		10 µg/l				
	Molybdenum, Dissolved		750 µg/l				
	Nickel, Dissolved		8.1 µg/l				
	Selenium Dissolved		8.5 µg/l				
	Vanadium, Dissolved		<2 µg/l				
	Mercury, Dissolved		0.011 µg/l				
	Total Alkalinity as CaCO3		260 mg/l				
	Electrical Conductivity at 20C		2400 mS/cm				
	Potassium, Dissolved		22 mg/l				
	Sodium, Dissolved		210 mg/l				
	Sulphate, Dissolved		490 mg/l				
	Total Oxidised Nitrogen		19 mg/l				
	Chloride		390 mg/l				
	Fluoride		0.24 mg/l				
	Ammoniacal Nitrogen		3.4 mg/l				
	Total Organic Carbon		1.6 mg/l				
	Nitrate		0 mg/l				
	pH		7.30 pH Units				

Emission point	Substance/ Parameter	Emission Limit Value	Result ^[1]	Test Method ^[2]	Sample Date and Times ^[3]	Accreditation/ Certification ^[4]	Uncertainty ^[5]
DP2	Aluminium, Dissolved		<10 µg/l		10/12/2019	Sampling Station/Testing EA NLS	
	Antimony, Dissolved		<1 µg/l				
	Arsenic Dissolved		1.6 µg/l				
	Boron, Dissolved		580 µg/l				
	Cadmium, Dissolved		<2 µg/l				
	Calcium, Dissolved		300 mg/l				
	Chromium, Dissolved		10 µg/l				
	Copper, Dissolved		1.9 µg/l				
	Iron, Dissolved		<30 µg/l				
	Magnesium, Dissolved		35 mg/l				
	Manganese, Dissolved		24 µg/l				
	Molybdenum, Dissolved		1800 µg/l				
	Nickel, Dissolved		9.2 µg/l				
	Selenium Dissolved		23 µg/l				
	Vanadium, Dissolved		3.5 µg/l				
	Mercury, Dissolved		<0.01 µg/l				
	Total Alkalinity as CaCO3		240 mg/l				
	Electrical Conductivity at 20C		3100 mS/cm				
	Potassium, Dissolved		32 mg/l				
	Sodium, Dissolved		370 mg/l				
	Sulphate, Dissolved		430 mg/l				
	Total Oxidised Nitrogen		24 mg/l				
	Chloride		670 mg/l				
	Fluoride		0.16 mg/l				
	Ammoniacal Nitrogen		2.4 mg/l				
	Total Organic Carbon		1.5 mg/l				
	Nitrate		24 mg/l				
	pH		7.30 pH Units				

Emission point	Substance/ Parameter	Emission Limit Value	Result ^[1]	Test Method ^[2]	Sample Date and Times ^[3]	Accreditation/ Certification ^[4]	Uncertainty ^[5]
DP2	Aluminium, Dissolved		19.00 µg/l		19/12/2019	Sampling Station/Testing EA NLS	
	Antimony, Dissolved		<1 µg/l				
	Arsenic Dissolved		2.20 µg/l				
	Boron, Dissolved		470.00 µg/l				
	Cadmium, Dissolved		<2 µg/l				
	Calcium, Dissolved		200.00 mg/l				
	Chromium, Dissolved		7.30 µg/l				
	Copper, Dissolved		1.90 µg/l				
	Iron, Dissolved		<30 µg/l				
	Magnesium, Dissolved		<30 mg/l				
	Manganese, Dissolved		27.00 µg/l				
	Molybdenum, Dissolved		1200.00 µg/l				
	Nickel, Dissolved		6.80 µg/l				
	Selenium Dissolved		14.00 µg/l				
	Vanadium, Dissolved		4.10 µg/l				
	Mercury, Dissolved		<0.01 µg/l				
	Total Alkalinity as CaCO3		250.00 mg/l				
	Electrical Conductivity at 20C		2100.00 mS/cm				
	Potassium, Dissolved		25.00 mg/l				
	Sodium, Dissolved		210.00 mg/l				
	Sulphate, Dissolved		310.00 mg/l				
	Total Oxidised Nitrogen		17.00 mg/l				
	Chloride		360.00 mg/l				
	Fluoride		1.70 mg/l				
	Ammoniacal Nitrogen		1.70 mg/l				
	Total Organic Carbon		1.40 mg/l				
	Nitrate		0.57 mg/l				
	pH		7.30 pH Units				

[1] The result given is the maximum value (or the minimum value in the case of a limit that is expressed as a minimum) obtained during the reporting period, expressed in the same terms

[2] Where an internationally recognised standard test method is used the reference number is given. Where another method that has been formally agreed with the Agency is used, then


[3] For non-continuous measurements the date and time of the sample that produced the result is given. For continuous measurements, or flow/time proportional samples, the percentage

[4] The accreditation status of the equipment and/or the monitoring organisation, as appropriate, for the methods used for both sampling and analysis.

[5] The uncertainty associated with the quoted result at the 95% confidence interval, unless otherwise stated.

Substance/ Emission point Parameter	Emission Limit Value	Result ^[1]	Test Method ^[2]	Sample Date and Times ^[3]	Accreditation/ Certification ^[4]	Uncertainty ^[5]
--	-------------------------	-----------------------	-------------------------------	---	--	-------------------------------

[6] The emission limit values for all substances is expressed as a maximum individual value, unless otherwise stated.



Signed Date 14/02/2020

(authorised to sign as representative of the Operator)