

**Reporting 4.2.2 (a) – AB3093CA Tremorfa Anaerobic Digestion Facility – 2018 Review.**

During 2018 both digestion tanks – Fermenter 1 and Fermenter 2 were offline for 7 months to carryout maintenance.

Both fermenters required complete shutdown for cleaning, due to the build-up of biodegradable bags which had reduced the capacity of each fermenter tank.

As the site was shutdown, waste imports were transferred off site to be processed at other facilities.

Therefore, this reduced significantly the following –

Biogas generation  
Electricity generation  
Digestate production  
Water usage

The clean out of both fermenters in total took seven months to complete and significantly impacted the running of the site.

Now that the work is complete the site is fully operational and performing well.