


Schedule 6 - Notification

Part B - to be submitted as soon as practicable

Permit Number	BR9383ID	Notification Reference	EP_EX_250
Name of operator	Knauf Insulation Ltd		
Location of Facility	Chemistry Lane, Queensferry, Deeside, Flintshire, CH5 2DA		
Time and date of the detection	4/08/2020 (test results from 8/07/2020)		

Any more accurate information on the matters for notification under Part A.	Emission point C is being tested again this week (5 to 9 October). The effectiveness of the refurbishment and change of packing material will be assessed on receipt of the test results
Measures taken, or intended to be taken, to prevent a recurrence of the incident	<p>Since the tests the ceilcote abatement filters have been cleaned, the internal packing medium has been entirely replaced with new packing and all the distribution sprays for the ceilcotes have been renewed.</p> <p>The baskets that contain the tellerette packing medium were also changed and the recirculating water tanks were emptied and cleaned</p>
Measures taken, or intended to be taken, to rectify, limit or prevent any pollution of the environment which has been or may be caused by the emission	
The dates of any unauthorised emissions from the facility in the preceding 24 months.	03-04/09/18, 05/09/18, 07/09/18, 09/09/18, 10/09/18, 16/09/18, 15/10/18, 16/10/18, 17/10/18, 18/10/18, 19/10/18, 22/10/18, 6/11/18, 13/11/18, 02/01/19, 08/01/19, 10/01/19, 07/02/19, 20/02/19, 12/04/19, 19/04/19, 08/05/19, 12/06/19, 13/06/19, 18/06/19, 04/07/19, 08/07/19, 16/07/19, 06/08/19, 08/08/19, 16/08/19, 07-09/09/19, 16/09/19, 19/09/19, 02/10/19, 03/10/19, 25-27/10/19, 31/10/19, 24/11/19, 25/2/20, 12-14/5/20, 22-26/5/20, 22/6-2/7/20, 8/7/20

Name*	Graham Jones
Post	Process and Energy Manager
Signature	
Date	7 th October 2020

* authorised to sign on behalf of Knauf Insulation Ltd