

Permit Reference Number: BL3986ID

Operator: Tarmac Cement & Lime Ltd

Installation: Aberthaw Works

Form Number: Water 1 / 19/07/16

**Quarterly Reporting of Emissions to Surface Water – Emission Points W1 & W2
for the period 01/03/2020 to 31/03/20**

Emission Point	Parameter	Emission Limit Value	Result	Date of Measurement	Method
W1	pH (minimum)	6	8.1	23.3.20	BS ISO10523
W1	pH (maximum)	9	-	-	BS ISO10523
W1	Total Suspended Solids (Maximum)	50 mg/l	23 mg/l	23.3.20	BS EN 872
W1	Oil or Grease	None Present	None Visible	23.3.20	Visual Check
W2	pH (minimum)	6	-	-	BS ISO10523
W2	pH (maximum)	9	-	-	BS ISO10523
W2	Total Suspended Solids (Maximum)	50 mg/l	-	-	BS EN 872
W2	Oil or Grease	None Present	-	-	Visual Check

*Rainfall was consistently heavy for a number of weeks preceding the water sampling as a result of Storm Ciara (7-16th Feb) and Storm Dennis (11th – 18th Feb). Such exceptional volumes of flow and run off had a detrimental effect on solids in surface water catchment and water clarity. This was beyond the control of the site.

Signed : **G Taubman** Date :**14.04.2020**
(Authorised to sign as representative of Tarmac Cement & Lime Ltd)