Permit Reference Number: BL3986ID **Operator: Tarmac Cement & Lime Ltd**

Installation: Aberthaw Works **Form Number: Water 1 / 19/07/16**

Quarterly Reporting of Emissions to Surface Water – Emission Points W1 & W2 for the period 01/02/2020 to 29/02/20

Emission Point	Parameter	Emission Limit Value	Result	Date of Measurement	Method
W1	pH (minimum)	6	**8.0**	**17.02.20**	BS ISO10523
W1	pH (maximum)	9	**-**	**-**	BS ISO10523
W1	Total Suspended Solids (Maximum)	50 mg/l	**48 mg/l***	**17.02.20**	BS EN 872
W1	Oil or Grease	None Present	**None Visible**	**17.02.20**	Visual Check
W2	pH (minimum)	6	**-**	**-**	BS ISO10523
W2	pH (maximum)	9	**-**	**-**	BS ISO10523
W2	Total Suspended Solids (Maximum)	50 mg/l	**-**	**-**	BS EN 872
W2	Oil or Grease	None Present	**-**	**-**	Visual Check

*Rainfall was consistently heavy for a number of weeks preceding the water sampling as a result of Storm Ciara (7-16th Feb) and Storm Dennis (11th – 18th Feb). Such exceptional volumes of flow and run off had a detrimental effect on solids in surface water catchment and water clarity. This was beyond the control of the site.

Signed : G Taubman **Date :14.04.2020**
(Authorised to sign as representative of Tarmac Cement & Lime Ltd)