

Permit Reference Number: BL3986ID

Operator: Tarmac Cement & Lime Ltd

Installation: Aberthaw Works

Form Number: Water 1 / 19/07/16

**Quarterly Reporting of Emissions to Surface Water – Emission Points W1 & W2  
for the period 01/06/2020 to 30/06/20**

Emission Point	Parameter	Emission Limit Value	Result	Date of Measurement	Method
<b>W1</b>	pH (minimum)	6	<b>7.6</b>	<b>16.6.20</b>	BS ISO10523
<b>W1</b>	pH (maximum)	9	-	-	BS ISO10523
<b>W1</b>	Total Suspended Solids (Maximum)	50 mg/l	<b>5mg/l</b>	<b>16.6.20</b>	BS EN 872
<b>W1</b>	Oil or Grease	None Present	<b>None Visible</b>	<b>16.6.20</b>	Visual Check
<b>W2</b>	pH (minimum)	6	-	-	BS ISO10523
<b>W2</b>	pH (maximum)	9	-	-	BS ISO10523
<b>W2</b>	Total Suspended Solids (Maximum)	50 mg/l	-	-	BS EN 872
<b>W2</b>	Oil or Grease	None Present	-	-	Visual Check

Signed : G Taubman  
(Authorised to sign as representative of Tarmac Cement & Lime Ltd)

Date : 1.7.2020