

Schedule 1 – 5.1.1 Notification

PART A

Permit Number:	BR9715B
Name of Operator:	Solutia UK Ltd
Location of Installation:	Corporation Road, Newport, Gwent, NP194XF
Location of the emission:	T66 pumphouse
Time and date of the emission:	09/06/2020

Substance(s) emitted	Media e.g. air /water	Best estimate of the quantity or the rate of emission	Time during which the emission took place
Therminol 66	Discharge to concrete area (contained with drum & spill kit)	~200L	10:40 for ~1hr

Description of the failure or accident, and...	Leak from T66 (heat transfer fluid) transfer line resulting in a release of liquid. This was largely contained in a drum, with spill granules deployed to clear up the remainder. No loss to ground / effluent
Measures taken, or intended to be taken, to stop the emission:	

* Signed: 

Date: 09/06/2020

* authorised to sign on behalf of Solutia UK Ltd