

OPERATIONAL PARAMETERS

SUMMARY FOR **QUARTER 3 – 01 JUL 2020 to 30 SEPT 2020.**

Operator: Dragon LNG

Location: Waterston, Milford Haven, SA73 1DR

Authorisation/Variation Number: EA/EPR/AP3136UA/V004

Parameter – Effluent discharge

Parameter		1Spot Sample			Limit
		Jul 2020	Aug 2020	Sep 2020	
(1)E2 A Purge water	Oil (mg/l)	No Flow	No Flow	No Flow	5
	Suspended Solids (mg/l)	No Flow	No Flow	No Flow	50
	pH	No Flow	No Flow	No Flow	6 - 9
(1)E2 B Effluent water	Oil (mg/l)	No Flow	No Flow	No Flow	5
	Suspended Solids (mg/l)	No Flow	No Flow	No Flow	50
	pH	No Flow	No Flow	No Flow	6 - 9
(1)E3 Overflow from firewater reservoir	Oil (mg/l)	1.0	1.0	1.0	5
	Suspended Solids (mg/l)	2.1	2.0	2.0	50
	pH	7.51	7.38	7.47	6 - 9
	Total Flow (m³)	0.00	0.06	0.00	
	(2)TON (mg/l as N)	6.7	6.0	3.2	45
	TON (kg / month)	0.00	0.00	0.00	

Notes

- 1) Values reported in above table for Oil, pH & SS are average values for the month from a series of weekly spot samples. **Zero (0)** notifications of individual breaches have been necessary during Q3 as the individual spot sample results **have not** been in breach of permit limits.
- 2) TON calculated from online continuous analyser that measures Nitrates & Nitrites concentrations (mg/l as N) directly and reports average values for the month.

Signed on behalf of the Operator by

Name: **Kerry Watkins**

Designation: **Compliance Engineer**

Date: 07/10/2020