

**CONTINUOUS MEASUREMENT SYSTEMS INVALIDATION LOG**

**QUARTERLY RETURN**

**Operator: Baglan Operations Limited**

**Monitor positioned on release point/LCP No: A2 & A4 / LCP15**

**Permit/Variation Number: EPR/BJ7891IT**

<b>Date</b>	<b>Period of invalidation (hours)</b>	<b>Invalidated days in month</b>
No invalid data recorded		

**NOTES:**

(a) Compliance in Chapter III of the IED is on the basis of validated hourly averages, measured by continuous monitors (exemption applies). And confidence intervals are incorporated to convert the measured hourly value into a validated measure of compliance assessment. However, any day in which more than 3 hourly average values are invalid (due to malfunction of continuous measurement system) shall be invalidated for the purpose of compliance assessment. If more than 10 days are the operator shall, within 28 days of becoming aware of this fact, review the causes of the invalidations and submit to the E approval, proposals for measures to improve the reliability of the continuous measurement systems, including a timetable for those measures; and implement the approved proposals.

Signed on behalf of the Operator by: Jayne Mason

Date of return: 13/10/2020

Year: 2020

Form: IED CEM1

Version/Date: V 3.1 31 Dec 2016

LM2500

Comments

cept where discontinuous  
urement for the purpose  
r maintenance of the  
invalid over a year  
Environment Agency for  
for the implementation of