

# REGISTER OF CONDITIONS

AND OTHER TERMS

IMPOSED UNDER SECTION 7 OF THE RIVERS (PREVENTION OF POLLUTION) ACT, 1951  
(AS APPLIED BY THE CLEAN RIVERS (ESTUARIES AND TIDAL WATERS) ACT, 1960)  
AND THE RIVERS (PREVENTION OF POLLUTION) ACT, 1961.

No. 274

CAT. No. R.B.12 SHAW & SONS LTD., FETTER LANE, E.C.4.

DATE ON WHICH CONDITION CAME INTO FORCE AND PERIOD OF EFFECT	FULL ADDRESS OR OTHER SUFFICIENT DESCRIPTION OF LAND OR PREMISES TO WHICH THE TERM OR CONDITION RELATES	
25th August, 1978	Rhymney Valley District Council, Council's Public Works Depot, rear of Omnibus Garage, TIRYBERTH.	
File 3364		
USE OF NEW OR ALTERED OUTLET		
CONDITIONS IMPOSED WITH RESPECT TO:-		DISCHARGE OF TRADE OR SEWAGE EFFLUENT
(I) PRECISE LOCATION OF OUTLET	Depot, Tiryberth. Point "A" discharging to River Rhymney	CONDITIONS IMPOSED WITH RESPECT TO:-
(II) CONSTRUCTION OF OUTLET (OTHER THAN CONDITIONS TO BE SATISFIED BEFORE OUTLET IS BROUGHT INTO USE)	existing outlet as per drawing (connected to existing 600 mm dia s.w. culvert to discharge into Rhymney river via existing outlet)	(I) NATURE AND COMPOSITION OF DISCHARGE
(III) USE OF OUTLET	Discharge of treated sewage effluent	1. Total Suspended Solids must not exceed 30 mg/l 2. Biochemical Oxygen Demand must not exceed 20 mg/l 3. pH range = 5-9
(IV) USE OF ANY OTHER OUTLET FOR TRADE OR SEWAGE EFFLUENT FROM THE SAME LAND OR PREMISES	-	(II) TEMPERATURE OF DISCHARGE
REMARKS-	ambient	
	(III) VOLUME OR RATE OF DISCHARGE OF EFFLUENT FROM LAND OR PREMISES 7.274 m <sup>3</sup> per day	
	* (IV) PROVISION OF FACILITIES FOR TAKING SAMPLES	
	at outlet	
	* (V) DATE OF EXPIRATION OF PERIOD SPECIFIED UNDER S-5(2) OF 1961 ACT	
	27.8.1980	
	REMARKS-	

\* IF DISCHARGE NOT CONTROLLED UNDER S.7 OF 1951 ACT.