

Confirmation data sheet

Manufacturer: **ceATec Engineering GmbH**
4906 Eberschwang, Antiesen 15, Austria

Customer: **Kronospan Ltd. Chirk**
Chirck, Wrexham LL14 5NT U.K.

Project: **3620B-12**
Entstaubung KT - Presse

Designation: **Jet-Impulse-filter**
Type: **JDRT-12/05-3375-02**
Serial number: **F719-12**

Filter area: **210 m²**
Filter loads per surface: **115,0 m³/m²/h**
Filter medium: **PE520LO**

Material: **Wood dust**
Air volume: **24.050 m³/h**
Temperature: **20°C**

Outlet gas: **<5mg/Nm³**

Remark: **The filter is just to separate solid material**

Eberschwang, 09.12.2020



Peter Pichler
Managing Director