

Confirmation data sheet

Manufacturer: **ceATec Engineering GmbH**
4906 Eberschwang, Antiesen 15, Austria

Customer: **KRONOSPAN LIMITED**
Chirck, Wrexham LL14 5NT U.K.

Project: A-466/19, Kronospan Chirck,
Boardbreaker MDF 1+2

Designation: **Row filter**
Type: **CDRT 12-05-4500-02**
Serial number: **CDRW 016/15**

Filter area: **280,00 m²**
Filter loads per surface: **89,31 m³/m²/h**
Filter medium: **PE 520 LO**

Material: **Wood dust**
Air volume: **25.000 m³/h**
Temperature: **50°C**

Outlet gas: **<5mg/Nm³**

Remark: The filter is just to separate solid material

Eberschwang, 11.11.2020



Peter Pichler
Managing Director